

IEC 61850 Certificate Level A¹

No. 74108008-OPE/INC 15-2319 Rev.1

Issued to:

ABB Oy Medium Voltage Products Muottitie 2 FI-65101 Vaasa Finland

For the server product:

REF620 Feeder Protection and Control Relay

Product version: 2.0 FP1 Software version: 2.1 Hardware version: G

The server product has not been shown to be non-conforming to:

IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 1.0 with TPCL² 1.0.2 with product's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement for the IEC 61850 interface in 620 series, Revision B", "IEC 61850 ED2 Model Implementation Conformance Statement (MICS) for 620 SERIES, revision A" and "TISSUES Implementation Conformance Statement for the IEC61850 Ed2 interface in 620 series, Revision A" and the extra information for testing: "Protocol Implementation extra Information for Testing (PIXIT) for the IEC 61850 interface in 620 series, Revision B".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

- 1 Basic Exchange (20/26)
- 2 Data Sets (4/7)
- 4 Setting Group Selection (4/4)
- 4+ Setting Group Definition (12/13)
- 5 Unbuffered Reporting (16/20)
- 6 Buffered Reporting (23/29)

- 9a GOOSE Publish (10/13)
- 9b GOOSE Subscribe (12/14)
- 12a Direct Control (6/18)
- 12d Enhanced SBO Control (14/28)
- 13 Time Synchronization (6/7)
- 14 File Transfer (7/8)

This certificate includes a summary of the test results as carried out at ABB in Finland with UniCA 61850 Client Simulator 4.29.03 with test suite Ed2 3.29.05 and UniCA 61850 Analyzer 5.29.02. This document has been issued for information purposes only, and the original paper copy of the DNV GL verification report No. 74108008-OPE/INC 15-2318 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV GL by ABB. The manufacturer's production process has not been assessed. This certificate does not imply that DNV GL has approved any product other than the specimen tested.

Arnhem, September 4, 2015

M. Adriaensen

Head of Department Operational Excellence Issued by:



DNV KEMA is now DNV GL

R. Schimmel
Verification Manager

¹ Level A - Independent test lab with certified ISO 9001 Quality System

² TPCL - Test procedures change list

Copyright © KEMA Nederland B.V. Arnhem, the Netherlands. All rights reserved. It is prohibited to update or change this certificate in any manner whatsoever, including but not limited to dividing it into parts.



IEC 61850 Certificate Level A No. 74108008-OPE/INC 15-2319 Rev.1

Applicable Test Procedures from the UCA International Users Group Edition 2 Server Test Procedures version 1.0 with TPCL 1.0.2

Conformance Block		Mandatory	Conditional
1:	Basic Exchange	sAss1, sAss2, sAss3, sAssN2, sAssN3, sAssN4, sAssN5, sSrv1, sSrv2, sSrv3, sSrv4, sSrv5, sSrvN1abcd, sSrvN4	sSrv6, sSrv8, sSrv13, sSrvN1e, sSrvN1f, sSrvN3
2:	Data Sets	sDs1, sDs10a, sDsN1ae	sDs15
4:	Setting Group Selection	sSg1, sSg3, sSgN1	sSg11
4+:	Setting Group Definition	sSg2, sSg4, sSg7, sSg8, sSg10, sSg12, sSgN2, sSgN3, sSgN4, sSgN5	sSg6, sSg9
5:	Unbuffered Reporting	sRp1, sRp2, sRp3, sRp4, sRp9, sRp14, sRpN1, sRpN2, sRpN3, sRpN4, sRpN8	sRp5, sRp8, sRp11, sRp12, sRpN5
6:	Buffered Reporting	sBr1, sBr2, sBr3, sBr4, sBr9, sBr14, sBr20, sBr21, sBr22, sBr25, sBr26, sBr27, sBr28, sBrN1, sBrN2, sBrN3, sBrN4, sBrN5, sBrN8	sBr5, sBr8, sBr11, sBr12
9a:	GOOSE publish	sGop2a, sGop3, sGop4, sGop7, sGop9, sGop10, sGop11	sGop1, sGop6, sGopN1
9b:	GOOSE subscribe	sGos1, sGos2, sGos3, sGos5, sGos6a, sGos7, sGosN1, sGosN2, sGosN3, sGosN4, sGosN5, sGosN6	
12a:	Direct control	sCtl5, sCtl10, sDOns1, sDOns2	sCtl16, sCtl17
12d:	Enhanced SBO Control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOes1, sSBOes2, sSBOes6, sSBOes8	sCtl4, sCtl6, sCtl16, sCtl26,
13:	Time sync	sTm1, sTm2, sTmN1	sTm3, sTm4, sTm5
14:	File transfer	sFt1, sFt2ab, sFt4, sFt5, sFtN1ab	sFt2c, sFtN1c

All configuration file and data model tests have been successfully performed for the product variants using the same communication hardware and software version:

- REM620 Motor Protection and Control Relay
- RET620 Transformer Protection and Control Relay