ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV

ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 2160021

Ordering firm: ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82, 69123 Heidelberg, Germany

Manufacturer/Licence holder: ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82, 69123 Heidelberg, Germany

Name of product: Circuit-Breakers

Trade name:

Type of product: S20.P

Rating: 230/400 V AC; B 6, 10-63 A; C 0,5-63 A; D 0,5-25 A
number of poles: 1, 2, 3, 4, 1+N, 3+N
25 kA (0,5-25 A), 15 kA (32 -63 A)

Electrotechnical Testing Institute on the basis of fulfillment the requirements of the „ESČ Mark" certification scheme is granting a licence for using the following mark

This mark may be used for the product specified in this certificate within validity of the Agreement on the use of the ESC Mark by implementing all the rules stated in the Agreement.

The right to use the above mentioned mark for the product is based on:
- Test report No. 601192-02/01 of: 24.06.2016

A sample of the product was tested and found to be in conformity with:
ČSN EN 60898-1:03+A1:05+1:05+A11:06+A12:08+A13:13

- based on the Notification of Test Results, the certificate No. CCA/ DE1 34491 issued by VDE of 19.06.2015
- the Agreement on the use of the ESC Mark No. 601192 concluded between the ordering firm and the Electrotechnical Testing Institute

Other data:

elektrotechnický zkušební ústav ezú -1- Pod Lisem 129, 171 02 Praha 8 - Troja

20.07.2016

Prague

Mgr. Miroslav Sedláček
Head of Certification Body

Stamp

* C E R / 2 1 6 0 0 2 1 *

601192-02