



中国国家强制性产品认证证书

证书编号: 2004010307128224

委托人名称、地址

北京ABB低压电器有限公司
北京经济技术开发区康定街17号

生产者(制造商)名称、地址

北京ABB低压电器有限公司
北京经济技术开发区康定街17号

生产企业名称、地址

北京ABB低压电器有限公司
北京经济技术开发区康定街17号

产品名称和系列、规格、型号

塑料外壳式断路器

详见参数附件

产品标准和技术要求

GB 14048.2-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2015年04月21日

有效期至: 2020年04月21日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2004年08月25日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1130360



中国国家强制性产品认证证书

附录:

第 1 页 共 3 页

证书编号: 2004010307128224

纸号: 1130360

S261 K, S262 K, S263 K, S263NA K, S264 K;

Ue: AC230V(1P), AC400V(2P,3P,3P+N,4P);

In: 0.5A,0.75A,1A,1.6A,2A,3A,4A,6A,10A,16A,20A,25A,32A,40A,50A,63A;

过电流脱扣器类型:电磁式;

使用类别:A 类;

Ics=Icu: 6kA;

极数:1P,2P,3P,3P+N,4P。

S261-M K, S262-M K, S263-M K, S264-M K;

Ue: AC230V(1P), AC400V(2P,3P,4P);

In: 0.5A,0.75A,1A,1.6A,2A,3A,4A,6A,10A,16A,20A,25A,32A,40A,50A,63A;

过电流脱扣器类型:电磁式;

使用类别:A 类;

Ics=Icu: 6kA;

极数:1P,2P,3P,4P。

S261UC K, S262UC K, S263UC K, S264UC K;

Ue:AC230V(1P),AC400V(2P,3P,4P);DC220V(1P),DC440V(2P),DC630V(3P),

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 3 页

证书编号: 2004010307128224

纸号: 1130360

DC800V(4P);

In: 0.5A, 0.75A, 1A, 1.6A, 2A, 3A, 4A, 6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A;

过电流脱扣器类型: 电磁式;

使用类别: A 类;

Ics=Icu: AC6kA, DC10kA;

极数: 1P, 2P, 3P, 4P

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 3 页 共 3 页

证书编号: 2004010307128224

纸号: 1130360

型号的解释:

S26...K 系列型号的解释:

S 26 3 NA - K 63

1 2 3 4 5 6

1—塑壳断路器

2—设计代号

3—保护极数

4—中性极

5—特性分类

6—脱扣器整定电流

S26...-MK 系列型号的解释:

S 26 3 -M - K 63

1 2 3 4 5 6

1—塑壳断路器

2—设计代号

3—保护极数

4—单磁型

5—特性分类

6—脱扣器整定电流

S26...UCK 系列型号的解释:

S 26 3 UC - K 63

1 2 3 4 5 6

1—塑壳断路器

2—设计代号

3—保护极数

4—交直流通用

5—特性分类

6—脱扣器整定电流

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2004010307128224

NAME AND ADDRESS OF THE APPLICANT

ABB LV Installation Materials Co., Ltd. Beijing
No. 17 Kangding Street, Beijing Economic-Technological Development Area
100176, P. R. China

NAME AND ADDRESS OF THE MANUFACTURER

ABB LV Installation Materials Co., Ltd. Beijing
No. 17 Kangding Street, Beijing Economic-Technological Development Area
100176, P. R. China

NAME AND ADDRESS OF THE FACTORY

ABB LV Installation Materials Co., Ltd. Beijing
No. 17 Kangding Street, Beijing Economic-Technological Development Area
100176, P. R. China

NAME, MODEL AND SPECIFICATION

Moulded Case Circuit-breaker

See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.2-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification (REF NO. CNCA-C03-02:2014).

Date of issue: Apr. 21, 2015 Date of expiry: Apr. 21, 2020

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Aug. 25, 2004

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>



Q 1130360