CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2008010307283274

NAME AND ADDRESS OF THE APPLICANT

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82, 69123 Heidelberg, Germany

TRADE MARK: ABB

NAME AND ADDRESS OF THE MANUFACTURER

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82, 69123 Heidelberg, Germany

NAME AND ADDRESS OF THE FACTORY

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82, 69123 Heidelberg, Germany

NAME, MODEL AND SPECIFICATION

Miniature Circuit-breaker

S20..P...; Ue:AC230V(1P+N), AC230V/400V(1P), AC400V(2P, 3P, 3P+N, 4P);
In:6A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A Type B;
0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A Type C;
0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A, 13A, 16A, 20A, 25A Type D; Icn:25kA(In:0.5A-25A), 15kA(In:32A-63A); Ics:12.5kA(In:0.5A-25A), 7.5kA(In:32A-63A); 1P, 1P+N, 2P, 3P, 3P+N, 4P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB10963.1-2005

THIS IS TO CERTIFY THAT THE ABOVE MENTIONED PRODUCTS HAVE QUALIFIED FOR THE REQUIREMENTS OF IMPLEMENTATION RULES FOR COMPULSORY CERTIFICATION

ISSUED DATE:Aug. 07, 2008

THE VALIDITY OF THE CERTIFICATE DEPEND ON THE FOLLOW UP INSPECTION BY THE CERTIFICATION BODY AT REGULAR INTERVALS

(ORIGINAL ISSUED DATE: Jul.04,2008)

President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9,No.188,Nansihuan Xilu, Beijing 100070 P.R.China

http://www.cqc.com.cn

Q 0000504

中国国家强制性产品认证证书

证书编号：2008010307283274

申请人名称及地址

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82, 69123 Heidelberg, 德国

商标：ABB

制造商名称及地址

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82, 69123 Heidelberg, 德国

生产企业名称及地址

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82, 69123 Heidelberg, 德国

产品名称和系列、规格、型号

微型断路器

S20..P...; Ue:AC230V(1P+N), AC230V/400V(1P), AC400V(2P, 3P, 3P+N, 4P);
In:6A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A B型;
0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A C型;
0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A, 13A, 16A, 20A, 25A D型; Icn:25kA(In:0.5A-25A), 15kA(In:32A-63A); Ics:12.5kA(In:0.5A-25A), 7.5kA(In:32A-63A); 1P, 1P+N, 2P, 3P, 3P+N, 4P

产品标准和技术要求

GB10963.1-2005

上述产品符合强制性产品认证实施规则的要求，特发此证。

发证日期：2008年08月07日

本证书的有效性依据发证机构的定期监督获得保持。

（本证书为变更证书，证书首次颁发日期：2008年07月04日）

主　任：

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

http://www.cqc.com.cn

Q 0000504