



中国国家强制性产品认证证书

证书编号: 2010010307398812

委托人名称、地址

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

生产者(制造商)名称、地址

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

生产企业名称、地址

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

产品名称和系列、规格、型号

微型断路器

S281, S282, S283, S284; Ue: AC230V/400V (1P); AC400V (2P, 3P, 4P); Ie: 80A, 100A; 瞬时
脱扣类型: B, C; Icu=Ics: 6kA; 1P, 2P, 3P, 4P

产品标准和技术要求

GB 10963.1-2005

上述产品符合强制性产品认证实施规则
CNCA-01C-012: 2007的要求, 特发此证。

发证日期: 2010年03月30日

有效期至: 2015年03月30日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 0222264



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2010010307398812

NAME AND ADDRESS OF THE APPLICANT

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND ADDRESS OF THE MANUFACTURER

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND ADDRESS OF THE FACTORY

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME, MODEL AND SPECIFICATION

Miniature Circuit-breakers

S281, S282, S283, S284; Ue: AC230V/400V (1P); AC400V (2P, 3P, 4P); Ie: 80A, 100A; type
B, C; Icu=Ics: 6kA; 1P, 2P, 3P, 4P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 10963.1-2005

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification (REF
NO. CNCA-01C-012:2007).

Date of issue: Mar. 30, 2010

Date of expiry: Mar. 30, 2015

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>



Q 0222264