

Zertifikat mit SEV Konformitätszeichen

Electrosuisse CERTIFEL CoC SEV

(Verfahren mit Typenprüfung und Fertigungsüberwachung)

Zertifikatsnummer

IK-3323

Lizenznummer



Produkt

Leitungsschutzschalter

Lizenzinhaber

ABB Stotz-Kontakt GmbH
Eppelheimerstrasse 82, 69123 Heidelberg, DEUTSCHLAND

Hersteller

ABB Stotz-Kontakt GmbH
Eppelheimerstrasse 82, 69123 Heidelberg, DEUTSCHLAND

Fertigungsstätte

ABB Stotz-Kontakt GmbH
Eppelheimerstrasse 82, 69123 Heidelberg, DEUTSCHLAND

Handelsmarke

ABB

Typ/Modell

S20.P

Nenndaten

Ue: 230 VAC, 230/400 VAC, 400 VAC, In: 0.5 A bis 63 A
I_{tc}: "B", 6 A + 10...63 A, "C" 0.5 A...63 A, "D" 0.5 A...25 A
I_{cn}: 15000 A (32 A...63 A), 25000 A (0.5 A...25 A)
Pole: 1, 1+N, 2, 3+N, 4

Normen

EN 60898-1:03 + A1:04 + A11:05 + A12:08 + A13:12
IEC 60898-1(ed.1);am1;am2

Zusätzliche Angaben

Siehe Seite 2

EU-Richtlinien und
Verordnungen

2006/95/EC Niederspannungsrichtlinie

CH-Verordnungen

SR 734.26 NEV

Das beschriebene Produkt wurde nach den oben aufgeführten normativen Dokumenten typengeprüft. Electrosuisse bestätigt mit diesem Zertifikat die Normenkonformität. Es kann angenommen werden, dass damit der Nachweis erbracht wurde und das Produkt den Anforderungen der schweizerischen Verordnungen und den europäischen Richtlinien genügt. Die Konformität während der Produktionsphase wird durch die kontinuierliche Fertigungsüberwachung nach harmonisierten europäischen Verfahren garantiert. Dieses Zertifikat wurde unter der Annahme ausgestellt, dass der Auftraggeber im Besitz sämtlicher Produktrechte ist.

Die Prüfergebnisse sind in folgendem Bericht festgehalten: 14-IK-0188.01

Dieses Zertifikat wird alle drei Jahre erneuert.

Electrosuisse
Swiss Certification Body

Martin Plüss
Product Certification



Anhang zum Zertifikat
Electrosuisse CERTIFEL CoC SEV

Zertifikatsnummer

IK-3323

Zusätzliche Angaben

Typenschlüssel:

S20 $\frac{\quad}{a}$ P $\frac{\quad}{b}$ $\frac{\quad}{c}$

a: Anzahl Pole
b: Auslösecharakteristik
c: Nennstrom

Typenliste siehe Test Report.

Certificate of Conformity with SEV mark

Electrosuisse CERTIFEL CoC SEV

(type testing with assurance of conformity by production surveillance)

Certificate number

IK-3323

Licence number



Product

Circuit breaker

Licensee/License holder

ABB Stotz-Kontakt GmbH
Eppelheimerstrasse 82, DE-69123 Heidelberg, GERMANY

Manufacturer

ABB Stotz-Kontakt GmbH
Eppelheimerstrasse 82, DE-69123 Heidelberg, GERMANY

Manufactured at/Factory

ABB Stotz-Kontakt GmbH
Eppelheimerstrasse 82, DE-69123 Heidelberg, GERMANY

Trade mark

ABB

Type/Model

S20.P

Ratings, characteristics

Ue: 230 VAC, 230/400 VAC, 400 VAC; In: 0.5 A up to 63 A
I_{tc}: "B", 6 A + 10...63 A, "C" 0.5 A...63 A, "D" 0.5 A...25 A
I_{cn}: 15000 A (32 A...63 A), 25000 A (0.5 A...25 A)
Poles: 1, 1+N, 2, 3+N, 4

Standards

EN 60898-1:03 + A1:04 + A11:05 + A12:08 + A13:12
IEC 60898-1(ed.1);am1;am2

Additional information

See page 2

EU-Directives

2006/95/EC

Low voltage directive

Commission Regulations

Swiss regulations

SR 734.26

NEV

The products submitted by the applicant was type tested in accordance with the requirements of the mentioned standards. Electrosuisse certifies the conformity of the product with the standards. Presumption of conformity with the mentioned European directives and Swiss regulations can be assumed. Continuous surveillance based on harmonized European procedures assures the ongoing conformity of the tested products. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product presented for testing and certification.

Results of testing are shown in report number: 14-IK-0188.01

This certificate has to be reissued every three years.

**Electrosuisse
Swiss Certification Body**

Martin Plüss
Product Certification



Annex to certificate
Electrosuisse CERTIFEL CoC SEV

certificate number

IK-3323

Additional information

Nomenclature:

S20 $\frac{\quad}{a}$ P $\frac{\quad}{b}$ $\frac{\quad}{c}$

a: Number of poles

b: Tripping class

c: Rated current

Type list see test report.