

# RCC

## (REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO

**ABB SOUTH AFRICA (PTY) LTD**

IN TERMS OF SANS 10142 CLAUSE 4.

ISSUED BY

**National Regulator for Compulsory Specifications**

*PRODUCT: MINIATURE CIRCUIT BREAKERS (ABB) S200 Series-B,C,D,K;*

*$U_e = 230/400V \sim (1P, 1P + N, 2P, 3P, 3P + N, 4P); I_n = 0.5 \text{ to } 63A;$*

*$I_{cu} = 10kA; 50/60Hz; IP20$*

### **Test Laboratory:**

VDE Testing and Certification Institute  
SABS-NETFA

### **In accordance to(Standards):**

IEC 60947-2:2003

IEC 60947-1:2005 + VC8036:1999

Test report no: 70000-4402-0008/38480-1 to 33

**RCC No: 1107363**

### **Period of Validity**

28/07/2011 to 28/07/2014

*NRCS Non-Perishable Products Acting Exec.*

DATE 29-July-2011

