

RCC

(REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO

ABB SOUTH AFRICA (PTY) LTD

IN TERMS OF SANS 10142 CLAUSE 4.

ISSUED BY

National Regulator for Compulsory Specifications

PRODUCT: MINATURE CIRCUIT BREAKERS (ABB) S200P Series (Characteristic B, C, D, K, Z);

$U_e = 230/400V \sim (1P, 1P + N, 2P, 3P, 3P + N, 4P); U_i = 440V; U_{imp} = 4kV; I_e = 0.2 \text{ to } 63A;$

$I_{cu} = 15 / 25kA; I_{cs} = 7.5 / 11.25 / 12.5kA; 50/60Hz; IP20$

Test Laboratory:

IPH Institut GmbH
SABS-NETFA

Test report no: 194678-CC2-1

RCC No: 1507068

[Signature]
NRCS - Electrotechnical General Manager.



In accordance to(Standards):

IEC 60947-2:2006 A1: 2009 + A2: 2013
IEC 60947-1:2011 + VC8036:2006

Period of Validity

06/07/2015 to 06/07/2018

DATE

10/07/2015