

Type Approval Certificate



This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the GL Type Approval System.

Certificate No. 20 420 - 04 HH

Company ABB STOTZ-KONTAKT GmbH
Eppelheimer Straße 82
69123 Heidelberg, GERMANY

Product Description Miniature circuit breaker

Type S200, S200M

Environmental Category C

Technical Data /
Range of Application

Rated current I_e (30°C) : 0,5 .. 63 A (C characteristic)
6 .. 63 A (B characteristic)

Rated operational voltage U_e : 230/ 400 V AC
(suitable in a 415/240 V system)

Rated insulation voltage U_i : 500 V

Rated frequency f_e : 50/60 Hz

Rated short circuit capacity: 6 kA (S200)
10 kA (S200M)

Utilization category : A

Tripping characteristic : B, C

Overvoltage category: III

pollution degree: 2

1-pole S201(M), 2-pole S202(M), 3-pole S203(M), 4-pole S204(M)

Test Standard Regulations for the Performance of Type Tests 2003 Edition
IEC 60898-1(ed. 1): 2002-01

Documents Test report : DE1-19884 by VDE Institute dated 2003-03-27
Technical data: Catalogue "Technical data Sytem pro M compact"
Pub. No. 2CD 002 001 D0203

Remarks None

Valid until 2015-11-23

Page 1 of 1


File No. I.K.01

Hamburg, 2010-11-23

Type Approval Symbol



Germanischer Lloyd


Christoph Kutzner


Andreas Andrecht

This certificate is issued on the basis of "Guidelines for the Performance of Type Approvals Part 1, Procedure".