

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Circuit-breaker for overcurrent protection for household and similar installation

Name and address of the applicant

ABB-Stotz-Kontakt GmbH  
Eppelheimer Straße 82, 69123 Heidelberg  
GERMANY

Name and address of the manufacturer

ABB-Stotz-Kontakt GmbH  
Eppelheimer Straße 82, 69123 Heidelberg  
GERMANY

Name and address of the factory

ABB-Stotz-Kontakt GmbH  
Eppelheimer Straße 82, 69123 Heidelberg  
GERMANY*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

☐ Additional Information on page 2AC 230/400V; B 6 - 63 A; D 0,5 - 63 A; D 0,5 - 40 A  
Number of poles: 1; 2; 3; 4; 1+N; 3+N  
Instantaneous tripping current: B; C; D

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

Series S20.M; S20.; SC20.; 520.L

Additional information (if necessary may also be reported on page 2)

10kA (S20.M); 6kA (S20.; SC20.); 4,5kA (S20.L)

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

253856-TL3-000 to -114

This CB Test Certificate is issued by the National Certification Body

**VDE** Prüf- und Zertifizierungsinstitut GmbH  
**VDE** Testing and Certification Institute  
Zertifizierungsstelle und internat. Angelegenheiten  
Certification Body and internat. Affairs

Date: 2019-04-29

Signature:



J. Richter