中国国家强制性产品认证证书

证书编号：2010010307445268

委托人名称、地址

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82, 69123 Heidelberg ,Germany

生产者(制造商)名称、地址

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82, 69123 Heidelberg ,Germany

生产企业名称、地址

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82, 69123 Heidelberg ,Germany

产品名称和系列、规格、型号

微型断路器

SH20...; Ue:AC230V(1P+N), AC230/400V(1P), AC400V (2P, 3P, 3P+N, 4P); In:6A, 8A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A(B型); 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A(C型); 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A(D型); 瞬时脱扣类型:B, C, D型; Ics=Icn:6kA; 1P, 1P+N, 2P, 3P, 3P+N, 4P; 型号详见附录

产品标准和技术要求

GB 10963.1-2005

上述产品符合强制性产品认证实施规则
CNCA-C03-02:2014的要求，特发此证。

发证日期：2015年08月05日　　有效期至：2020年08月05日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2010年11月23日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询

主　任：

中国质量认证中心

中国 · 北京 · 南四环西路188号9区 100070

http://www.cqc.com.cn

Q 1206336

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2010010307445268

NAME AND ADDRESS OF THE APPLICANT

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82, 69123 Heidelberg, Germany

NAME AND ADDRESS OF THE MANUFACTURER

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82, 69123 Heidelberg, Germany

NAME AND ADDRESS OF THE FACTORY

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82, 69123 Heidelberg, Germany

NAME, MODEL AND SPECIFICATION

Miniature Circuit-breaker

SH20...; Ue:AC230V(1P+N), AC230/400V(1P), AC400V (2P, 3P, 3P+N, 4P); In:6A, 8A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A(Type B); 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A(Type C); 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A(Type D); Type B, C, D; Ics=Icn:6kA; 1P, 1P+N, 2P, 3P, 3P+N, 4P; See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 10963.1-2005

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-C03-02:2014).

Date of issue: Aug.05, 2015 Date of expiry: Aug.05, 2020

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Nov.23, 2010

This certificate can be verified through CNCA's website: www.cnca.gov.cn

President: Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
http://www.cqc.com.cn

Q 1206336

中国国家强制性产品认证证书

附录:　　第 1 页 共 1 页

证书编号: 2010010307445268　　纸号: 1206336

型号的解释:

SH20	1	-NA	C	10
I	II	III	IV	V

I: SH20.. - Basic Type

II: Number of Pole
1- 1 Pole
2- 2 Pole
3- 3 Pole
4- 4 Pole

III: blank: without N Pole
-NA: with N Pole

IV: Instantaneous Tripping Type B, C, D

V: Rated Current
B: 6A,8A,10A,13A,16A,20A,25A,32A,40A,50A,63A
C: 0.5A,1A,1.6A,2A,3A,4A,6A,8A,10A,13A,16A,20A,25A,32A,40A,50A,63A
D: 0.5A,1A,1.6A,2A,3A,4A,6A,8A,10A,13A,16A,20A,25A,32A,40A,50A,63A

注: 此附录与证书同时使用时有效。

主　任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

http://www.cqc.com.cn