



中国国家强制性产品认证证书

证书编号: 2012010307581354

委托人名称、地址

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82, 69123 Heidelberg, Germany

生产者(制造商)名称、地址

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82, 69123 Heidelberg, Germany

生产企业名称、地址

北京ABB低压电器有限公司
北京经济技术开发区康定街17号

产品名称和系列、规格、型号

微型断路器

S201M, S201M-NA, S202M, S203M, S203M-NA, S204M(型号解释详见附件); U_i : 250V
(1P, 1P+N), 500V (2P, 3P, 4P, 3P+N); U_{imp} : 4kV; U_e : AC230/400V (1P), AC230V
(1P+N), AC400V
(2P, 3P, 3P+N, 4P); B: I_n : 6A, 8A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A;
C: I_n : 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A;
D: I_n : 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A; 瞬时
脱扣类型: B, C, D型; I_{cn} : 10000A; I_{cs} : 7500A; IP20; 极数: 1P, 1P+N(1个保护极, N极可开
闭), 2P, 3P, 3P+N(3个保护极, N极可开闭), 4P

产品标准和技术要求

GB 10963.1-2005

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2017年03月14日 有效期至: 2022年03月14日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2012年11月20日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1637375



中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2012010307581354

纸号: 1637375

型号的解释:

$\frac{S20}{1}$ $\frac{\square}{2}$ $\frac{M}{3}$ $\frac{\square}{4}$ $\frac{\square}{5}$ $\frac{\square}{6}$

- 1——产品系列
- 2——保护极数, 1-1P, 2-2P, 3-3P, 4-4P
- 3——M:10kA
- 4——中性极, 空白为无中性极, -NA 为带有中性极
- 5——瞬时脱扣特性, B-B 特性; C-C 特性; D-D 特性
- 6——额定电流, B: 6A; 8A; 10A; 13A; 16A; 20A; 25A; 32A; 40A, 50A, 63A;
C: 0.5A; 1A; 1.6A; 2A; 3A; 4A; 6A; 8A; 10A; 13A; 16A; 20A; 25A; 32A; 40A, 50A, 63A;
D: 0.5A; 1A; 1.6A; 2A; 3A; 4A; 6A; 8A; 10A; 13A; 16A; 20A; 25A; 32A; 40A, 50A, 63A

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2012010307581354

NAME AND ADDRESS OF THE APPLICANT

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82, 69123 Heidelberg, Germany

NAME AND ADDRESS OF THE MANUFACTURER

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82, 69123 Heidelberg, Germany

NAME AND ADDRESS OF THE FACTORY

ABB LV Installation Materials Co. Ltd., Beijing
No.17 Kangding Street, Beijing Economic-Technological Development Area
100176, P.R.China

NAME, MODEL AND SPECIFICATION

Miniature Circuit-breaker

S201M, S201M-NA, S202M, S203M, S203M-NA, S204M (See the Appendix); Ui:250V
(1P, 1P+N), 500V (2P, 3P, 4P, 3P+N); Uimp:4kV; Ue:AC230/400V (1P), AC230V
(1P+N), AC400V
(2P, 3P, 3P+N, 4P); B: In: 6A, 8A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A;
C: In: 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A;
D: In: 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A; Type
B, Type C, Type D; Icn=10000A; Ics=7500A; IP20; Poles: 1P, 1P+N (With one
protective pole, Switched N pole), 2P, 3P, 3P+N (With three protective
poles, Switched N pole), 4P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 10963.1-2005

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification (REF
NO. CNCA-C03-02:2014).

Date of issue: Mar.14, 2017 Date of expiry: Mar.14, 2022

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

Date of original certification: Nov. 20, 2012

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1637375