

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHIECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 2100051

Ordering firm: ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82, 69123 Heidelberg, Germany

Manufacturer/Licence holder: ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82, 69123 Heidelberg, Germany

Name of product: Circuit-breakers

Trade name:

Type of product: SH20., SH20.L

Rating: 230/400 V AC; D 0,5-63 A; B/C 50-63 A;
number of poles: 1; 2; 3; 4; 1+N; 3+N; characteristic B, C, D;
6 kA(SH20.); 4,5 kA(SH20.L)

Electrotechnical Testing Institute is granting a licence for using the following mark



This mark may be used for the product specified in this certificate within validity of the Agreement on the use of the ESC Mark by implementing all the rules stated in the Agreement.

The right to use the above mentioned mark for the product is based on:

- Test report No. 002981-01/01 of: 16.09.2010

A sample of the product was tested and found to be in conformity with:
ČSN EN 60898-1:03+A1:05+1:05+A11:06+A12:08

- inspection at manufacturing site according to Permanent Documents CIG 023 and CIG 024 performed by VDE of 3.3.2010
- the Agreement on the use of the ESC Mark No. 002981 concluded between the ordering firm and the Electrotechnical Testing Institute

11.10.2010

Prague

Miroslav Sedláček
Certification and Inspection Manager



Stamp



* C E R / 2 1 0 0 0 5 1 *

002981-01

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHIECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 2100052

Ordering firm: ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82, 69123 Heidelberg, Germany

Manufacturer/Licence holder: ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82, 69123 Heidelberg, Germany

Name of product: Circuit-breakers

Trade name:

Type of product: S20.M, S20., S20.L

Rating: 230/400 V AC; D 0,5-63 A; B/C 50-63 A;
number of poles: 1; 2; 3; 4; 1+N; 3+N; characteristic B, C, D
10 kA(S20.M); 6 kA(S20.); 4,5 kA(S20.L)

Electrotechnical Testing Institute is granting a licence for using the following mark



This mark may be used for the product specified in this certificate within validity of the Agreement on the use of the ESC Mark by implementing all the rules stated in the Agreement.

The right to use the above mentioned mark for the product is based on:

- Test report No. 002982-01/01 of: 16.09.2010

A sample of the product was tested and found to be in conformity with:
ČSN EN 60898-1:03+A1:05+1:05+A11:06+A12:08

- inspection at manufacturing site according to Permanent Documents CIG 023 and CIG 024 performed by VDE of 3.3.2010
- the Agreement on the use of the ESC Mark No. 002982 concluded between the ordering firm and the Electrotechnical Testing Institute

11.10.2010

Prague


Miroslav Sedláček
Certification and Inspection Manager



002982-01