

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit-breaker

Name and address of the applicant

ABB-Stotz-Kontakt GmbH
Eppelheimer Straße 82, 69123 Heidelberg
GERMANY

Name and address of the manufacturer

ABB-Stotz-Kontakt GmbH
Eppelheimer Straße 82, 69123 Heidelberg
GERMANY

Name and address of the factory

ABB-Stotz-Kontakt GmbH
Eppelheimer Straße 82, 69123 Heidelberg
GERMANY*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

☐ Additional Information on page 2AC 230/400 V; B 1 - 63 A; C/D 0,5 - 63 A;
Number of poles: 1; 2; 3; 4; 1+N; 3+N
Instantaneous tripping current: B; C, D; Icn: 10 kA

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

Serie/series S 20.M

Additional information (if necessary may also
be reported on page 2)☐ Additional Information on page 2A sample of the product was tested and found
to be in conformity with

IEC 60898-1:2015

As shown in the Test Report Ref. No. which
forms part of this Certificate

269784-TL3-000 to 269784-TL3-089

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH**VDE** Testing and Certification Institute

Zertifizierungsstelle und internat. Angelegenheiten

Certification Body and internat. Affairs

Date: 2020-02-04

Signature:



G. Heine