

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit-breaker

Name and address of the applicant

ABB-Stotz-Kontakt GmbH
Eppelheimer Straße 82, 69123 Heidelberg
GERMANY

Name and address of the manufacturer

ABB-Stotz-Kontakt GmbH
Eppelheimer Straße 82, 69123 Heidelberg
GERMANY

Name and address of the factory

ABB-Stotz-Kontakt GmbH
Eppelheimer Straße 82, 69123 Heidelberg
GERMANY*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

☒ Additional Information on page 2AC 230/400 V; B6 - 63A
Number of poles: 1; 2; 3; 4; 1 + N; 3 + N
Instantaneous tripping current: B; C; D; Icn: 10 kA

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

Serie(s) SH 20. M

Additional information (if necessary may also be reported on page 2)

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

256072-TL3-000 to 070

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierung Produkte / Certification Products

Date: 2018-12-18

Signature:


A. Fabian

ABB LV Installation Materials Co. Ltd., Beijing
No.17, Kangding Street, Beijing Economic-Techn.
Developm. Area, 100176 BEIJING, Beijing
CHINA

Additional information (if necessary)

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierung Produkte / Certification Products

Date: 2018-12-18

Signature:



A. Fabian