中国国家强制性产品认证证书

证书编号：2012010307532803

委托人名称、地址

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82, 69123 Heidelberg, Germany

生产者(制造商)名称、地址

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82, 69123 Heidelberg, Germany

生产企业名称、地址

北京ABB低压电器有限公司
北京市北京经济技术开发区康定街17号

产品名称和系列、规格、型号

微型断路器

S20.MUC, S20.MDC, S20.MUC V;详细型号解释见附件

产品标准和技术要求

GB 10963.1-2005, GB 10963.2-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02:2014的要求，特发此证。

发证日期：2017年02月27日　　有效期至：2022年02月27日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2012年03月23日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询

主　任：

中国质量认证中心

中国 · 北京 · 南四环西路188号9区 100070

http://www.cqc.com.cn

Q 1605269

中国国家强制性产品认证证书

附录：　　第 1 页 共 3 页

证书编号：2012010307532803　　纸号：1605269

S20.MUC, S20.MDC, S20.MUC V
Ue: S20.MUC, S20.MUC V:
AC230/400V (1P), DC220V(1P),AC400V(2P,3P,4P),DC220/440V(2P);
S20.MDC:
DC220V(1P),DC220/440V(2P),DC440V(3P,4P);
In: S20.MUC:
B: 6A,10A,13A,16A,20A,25A,32A,40A,50A,63A ;
C: 0.5A,1A,1.6A,2A,3A,4A,6A,8A,10A,13A,16A,20A,25A,32A,40A,50A,63A;
S20.MDC, S20.MUC V:
B: 1A, 2A, 3A, 4A ,6A, 10A,13A,16A,20A,25A,32A,40A,50A,63A;
C: 0.5A,1A,1.6A,2A,3A,4A,6A,8A,10A,13A,16A,20A,25A,32A,40A,50A,63A;
瞬时脱扣类型:B型,C型;
Icn=10000A;Ics=7500A
极数:1P, 2P,3P,4P

注：此附录与证书同时使用时有效。

主　任：

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070
http://www.cqc.com.cn

中国国家强制性产品认证证书

附录：　　第 2 页 共 3 页

证书编号：2012010307532803　　纸号：1605269

型号的解释

S20	2	M	C	16	UC	V
1	2	1	3	4	5	6

1——产品系列

2——保护极数，1-1pole，2-2pole，3-pole，4-4pole

3——脱扣特性，B-B 特性；C-C 特性；

4——额定电流，

B: 1A,2A,3A,4A,6A, 10A,13A,16A,20A,25A,32A,40A,50A,63A；

C: 0.5A,1A,1.6A,2A,3A,4A,6A,8A,10A,13A,16A,20A,25A,32A,40A,50A,63A;

5——UC：交流和直流通用，DC：适用于直流

6——V：接线方式

注：此附录与证书同时使用时有效。

主　任：

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070


http://www.cqc.com.cn

中国国家强制性产品认证证书


附录：　　第 3 页 共 3 页

证书编号：2012010307532803　　纸号：1605269


a. S20.M UC/S20.M DC 3P 产品在直流系统中的接线图




b. S20.M UC/S20.M DC 4P 产品在直流系统中的接线图





c. S20.M UC V 3P 产品在直流系统中的接线图



d. S200M UC V 4P 产品在直流系统中的接线图







注：此附录与证书同时使用时有效。

主　任：

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

http://www.cqc.com.cn

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2012010307532803

NAME AND ADDRESS OF THE APPLICANT

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82, 69123 Heidelberg, Germany

NAME AND ADDRESS OF THE MANUFACTURER

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82, 69123 Heidelberg, Germany

NAME AND ADDRESS OF THE FACTORY

ABB LV Installation Materials Co., Ltd. Beijing
No.17, Kangding Street, Beijing Economic-Technological Development Area, 100176, P.R.China

NAME, MODEL AND SPECIFICATION

Miniature Circuit-breaker

S20.MUC, S20.MDC, S20.MUC V; See the appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 10963.1-2005, GB 10963.2-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification (REF NO. CNCA-C03-02:2014).

Date of issue: Feb.27, 2017 Date of expiry: Feb.27, 2022

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Mar.23, 2012

This certificate can be verified through CNCA's website: www.cnca.gov.cn

President: Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
http://www.cqc.com.cn

Q 1605269