



中国国家强制性产品认证证书

证书编号: 2012010307521947

委托人名称、地址

北京ABB低压电器有限公司
北京市北京经济技术开发区康定街17号

生产者(制造商)名称、地址

北京ABB低压电器有限公司
北京市北京经济技术开发区康定街17号

生产企业名称、地址

北京ABB低压电器有限公司
北京市北京经济技术开发区康定街17号

产品名称和系列、规格、型号

塑料外壳式断路器

S201, S201NA, S202, S203, S203NA, S204, S201M, S201MNA, S202M, S203M, S203MNA, S204M;
详见参数附件

产品标准和技术要求

GB 14048.2-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2016年11月29日

有效期至: 2021年11月29日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2012年01月11日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1520577



中国国家强制性产品认证证书

附录:

第 1 页 共 3 页

证书编号: 2012010307521947

纸号: 1520577

S201, S201-NA, S202, S203, S203-NA, S204,

S201M, S201M-NA, S202M, S203M, S203M-NA, S204M

Uimp: 4kV;

Ui: 250V(1P, 2P(1 个保护极, N 极可开闭));

500V(2P, 3P, 4P(3 个保护极, N 极可开闭), 4P);

Ue: AC133V, AC230V(1P, 2P(1 个保护极, N 极可开闭));

AC230V, AC400/440V(2P, 3P, 4P(3 个保护极, N 极可开闭), 4P);

In: K 型: 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A;

Z 型: 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A;

额定运行短路分断能力 Ics:

	S20...K/Z			S20...M K/Z		
	Ue	Ics	In	Ue	Ics	In
1P, 2P(1 个保护极, N 极可开闭)	133V	15kA	0.5~63A	133V	18.75kA 15 kA	0.5~40A 50A, 63A
	230V	7.5kA	0.5~63A	230V	11.25 kA 7.5 kA	0.5~40A 50A, 63A
2P(2 个保护极), 3P, 4P(3 个保护极, N 极可开闭), 4P(4 个保护极)	230V	15kA	0.5~63A	230V	18.75kA 15 kA	0.5~40A 50A, 63A
	400V/440V	7.5kA	0.5~63A	400V/440V	11.25kA 7.5kA	0.5~40A 50A, 63A

额定极限短路分断能力 Icu:

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 3 页

证书编号: 2012010307521947

纸号: 1520577

	S20...K/Z			S20...MK/Z		
	Uc	Icu	In	Uc	Icu	In
1P, 2P (1 个保护极, N 极可开闭)	133V	20kA	0.5~63A	133V	25kA	0.5~63A
	230V	10kA	0.5~63A	230V	15 kA	0.5~63A
2P(2 个保护极), 3P, 4P(3 个保护极, N 极可开闭), 4P(4 个保护极)	230V	20kA	0.5~63A	230V	25 kA	0.5~63A
	400V/440V	10kA	0.5~63A	400V/440V	15 kA	0.5~63A

适用隔离;

使用类别: A;

过电流脱扣器类型: 热磁式;

极数: 1P, 2P(1 个保护极, N 极可开闭)), 3P, 4P(3 个保护极, N 极可开闭), 4P

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 3 页 共 3 页

证书编号: 2012010307521947

纸号: 1520577

型号的解释:

S20 1 M - NA K 16A
1 2 3 4 5 6

1——产品系列 S20...

2——保护极数, 1-1pole, 2-2pole, 3-pole, 4-4pole

3——分断能力

	空白			M		
	Uc	Icu	In	Uc	Icu	In
1P, 2P (1 个保护极, N 极可开闭)	133V	20kA	0.5~63A	133V	25kA	0.5~63A
	230V	10kA	0.5~63A	230V	15 kA	0.5~63A
2P(2 个保护极), 3P, 4P(3 个保护极, N 极可开闭), 4P(4 个保护极)	230V	20kA	0.5~63A	230V	25 kA	0.5~63A
	400V/440V	10kA	0.5~63A	400V/440V	15 kA	0.5~63A

4——空白为无可开闭的中性极, NA 为带有可开闭的中性极

5——脱扣特性, K-K 特性; Z-Z 特性;

6——额定电流 K:0.5A,1A,1.6A, 2A, 3A, 4A, 6A, 8A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A;
Z: 0.5A,1A,1.6A, 2A, 3A, 4A, 6A, 8A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A;

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2012010307521947

NAME AND ADDRESS OF THE APPLICANT

ABB LV Installation Materials Co. Ltd., Beijing
No.17, Kangding Street, Beijing Economic-Technological Development Area,
100176, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

ABB LV Installation Materials Co. Ltd., Beijing
No.17, Kangding Street, Beijing Economic-Technological Development Area,
100176, P.R.China

NAME AND ADDRESS OF THE FACTORY

ABB LV Installation Materials Co. Ltd., Beijing
No.17, Kangding Street, Beijing Economic-Technological Development Area,
100176, P.R.China

NAME, MODEL AND SPECIFICATION

Moulded Case Circuit-breaker

S201, S201NA, S202, S203, S203NA, S204, S201M, S201MNA, S202M, S203M, S203MNA, S204M;
See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.2-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-C03-02:2014).

Date of issue: Nov.29,2016 Date of expiry: Nov.29,2021

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Jan.11,2012

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1520577