



CERTIFICATE NUMBER

12-HG930299-1-PDA

DATE

14 August 2012

ABS TECHNICAL OFFICE

Hamburg Engineering Department

CERTIFICATE OF DESIGN ASSESSMENT

This is to Certify that a representative of this Bureau did, at the request of
ABB STOTZ KONTAKT GMBH - HEIDELBERG

assess design plans and data for the below listed product. This assessment is a representation by the Bureau as to the degree of compliance the design exhibits with applicable sections of the Rules. This assessment does not waive unit certification or classification procedures required by ABS Rules for products to be installed in ABS classed vessels or facilities. This certificate, by itself, does not reflect that the product is Type Approved. The scope and limitations of this assessment are detailed on the pages attached to this certificate.

PRODUCT: **Circuit Breaker**

MODEL: **S200, S200M**

This Product Design Assessment (PDA) Certificate 12-HG930299-1-PDA, dated 14/Aug/2012 remains valid until 13/Aug/2017 or until the Rules or specifications used in the assessment are revised (whichever occurs first).

This PDA is intended for a product to be installed on an ABS classed vessel, MODU or facility which is in existence or under contract for construction on the date of the ABS Rules or specifications used to evaluate the Product.

Use of the Product on an ABS classed vessel, MODU or facility which is contracted after the validity date of the ABS Rules and specifications used to evaluate the Product, will require re-evaluation of the PDA.

Use of the Product for non ABS classed vessels, MODUs or facilities is to be to an agreement between the manufacturer and intended client.

AMERICAN BUREAU OF SHIPPING

Wulf-Peter Senebald
Engineer

NOTE: This certificate evidences compliance with one or more of the Rules, Guides, standards or other criteria of ABS or a statutory, industrial or manufacturer's standards. It is issued solely for the use of ABS, its committees, its clients or other authorized entities. Any significant changes to the aforementioned product without approval from ABS will result in this certificate becoming null and void. This certificate is governed by the terms and conditions as contained in ABS Rules 1-1-A3/5.9 Terms and Conditions of the Request for Product Type Approval and Agreement (2010).

ABB STOTZ KONTAKT GMBH
EPPELHEIMER STR. 82
HEIDELBERG
D-69123
Germany
Telephone: +49-6221-701 1336
Fax: +49-6221-701 1112
Email: dirk.meyer@de.abb.com
Web: www.abb.com

MA Certificate No.: 13-HN 2328801-X

PRODUCT:
Circuit Breaker

MODEL:
S200, S200M

Intended Service:
Branch circuit and back-up protection in electric sub-distributions.

Description:
Fixed mounted automatic fuse/ miniature circuit breakers.
Poles: 1, 1+N, 2, 3, 3+N, 4.

Ratings:
Rated Operating Voltage Ue: 133/ 230 V AC, 230/ 400V, 440V AC.
Rated Frequency: 50/ 60 Hz.
Rated Current Ie (30°C):
0.5 to 63 A for characteristic C, D, K, Z
6 to 63 A for characteristic B

Rated Short Circuit Capacity:
S200: 20 kA (133/ 230 V), 10 kA (230/ 400 V, 440 V)
S200M: 25 kA (133/ 230 V), 15 kA (230/ 400 V, 440 V)

Service Restriction:
Unit Certification is not required for this product. If the manufacturer or purchaser compliance with a specification or standard, the specification or standard, including tolerances, must be clearly defined.

Comments:
Each particular application/ installation of the circuit breakers and the individual ratings specifically approved in conjunction with the relevant system in which they are used. Duplicate PDA exists with ABB Automation EOOD, Rakovski Plovdiv District, Bulgaria.

Notes / Drawings / Documentation:
This Product Design Assessment (PDA) is valid only for products intended for use in MODUs or facilities which are in existence or under contract for construction on the date to evaluate the Product.

Term of Validity:

ABB STOTZ KONTAKT GMBH

This Product Design Assessment (PDA) Certificate 12-HG930299-1-PDA, dated 14/Aug/2012 remains valid until 13/Aug/2017 or until the Rules or specifications used in the assessment are revised (whichever occurs first).

This PDA is intended for a product to be installed on an ABS classed vessel, MODU or facility which is in existence or under contract for construction on the date of the ABS Rules or specifications used to evaluate the Product.

Use of the Product on an ABS classed vessel, MODU or facility which is contracted after the validity date of the ABS Rules and specifications used to evaluate the Product, will require re-evaluation of the PDA.

Use of the Product for non ABS classed vessels, MODUs or facilities is to be to an agreement between the manufacturer and intended client.

STANDARDS**ABS Rules:**

The Manufacturer has provided a declaration about the control of, or the lack of Asbestos in this product. The Rules applicable to this assessment are:

2013 Steel Vessel Rules 1-1-4/7.7, 4-8-3/1.7/1.11.1/1.17/5.3.3/, 4-9-7/13.5

National:

NA

International:

IEC 60947-1/-2

Government Authority:

NA

EUMED:

NA

Others:

NA