



中国国家强制性产品认证证书

证书编号: 2012010307586979

委托人名称、地址

ABB-Stotz-Kontakt GmbH
Eppelheimer Strasse 82, 69123 Heidelberg, Germany

生产者(制造商)名称、地址

ABB-Stotz-Kontakt GmbH
Eppelheimer Strasse 82, 69123 Heidelberg, Germany

生产企业名称、地址

北京ABB低压电器有限公司
北京市北京经济技术开发区康定街17号

产品名称和系列、规格、型号

塑料外壳式断路器

S201, S201-NA, S202, S203, S203-NA, S204; 型号参数详见附录

产品标准和技术要求

GB 14048.2-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2016年11月29日

有效期至: 2021年11月29日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2012年12月19日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1520579



中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2012010307586979

纸号: 1520579

S201,S201-NA,S202,S203,S203-NA,S204

Ui:250V(1P,1P+N),500V(2P,3P,3P+N,4P);

Ue:AC133V/230V(1P,1P+N),AC230V/400V/440V(2P,3P,3P+N,4P);

In:B:1A,2A,3A,4A,6A,8A,10A,13A,16A,20A,25A,32A,40A,50A,63A,

C,D:0.5A,1A,1.6A,2A,3A,4A,6A,8A,10A,13A,16A,20A,25A,32A,40A,50A,63A;

过电流脱扣器类型:热磁式;

1P,1P+N: AC133V: Ics:15kA,Icu:20kA;

AC230V:Ics:7.5kA,Icu:10kA;

2P,3P,3P+N,4P: AC230V:Ics:15kA,Icu:20kA;

AC400/440V:Ics:7.5kA,Icu:10kA;

极数:1P,1P+N(一个保护极,N极可开闭,适用于隔离),2P,3P,3P+N(三个保护极,N极可开闭,适用于隔离),4P,
使用类别:A类.

型号解释:

$\frac{S20}{1} \quad \frac{1}{2} \quad - \frac{NA}{3} \quad \frac{C}{4} \quad \frac{16}{5}$

1——产品系列

2——保护极数:1-1P, 2-2P, 3-3P, 4-4P

3——中性极:空白为无中性极,-NA为带有中性极

4——瞬时脱扣特性: B: $I_i=4I_n\pm20\%$; C: $I_i=6.5I_n\pm20\%$; D: $I_i=12I_n\pm20\%$

5——额定电流:B: 1A;2A;3A;4A;6A;8A;10A; 13A; 16A; 20A; 25A; 32A; 40A, 50A, 63A;

C: 0.5A; 1A; 1.6A; 2A; 3A; 4A; 6A; 8A; 10A; 13A; 16A; 20A; 25A; 32A; 40A, 50A, 63A;

D: 0.5A; 1A; 1.6A; 2A; 3A; 4A; 6A; 8A; 10A; 13A; 16A; 20A; 25A; 32A; 40A, 50A, 63A.

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2012010307586979

NAME AND ADDRESS OF THE APPLICANT

ABB-Stotz-Kontakt GmbH
Eppelheimer Strasse 82, 69123 Heidelberg, Germany

NAME AND ADDRESS OF THE MANUFACTURER

ABB-Stotz-Kontakt GmbH
Eppelheimer Strasse 82, 69123 Heidelberg, Germany

NAME AND ADDRESS OF THE FACTORY

ABB LV Installation Materials Co. Ltd., Beijing
No.17, Kangding Street, Beijing Economic-Technological Development Area,
100176, P. R. China

NAME, MODEL AND SPECIFICATION

Moulded Case Circuit-breaker

S201, S201-NA, S202, S203, S203-NA, S204; See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.2-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-C03-02:2014).

Date of issue: Nov.29,2016 Date of expiry: Nov.29,2021

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Dec.19,2012

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1520579