

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit-breaker

Name and address of the applicant

ABB-Stotz-Kontakt GmbH
Eppelheimer Straße 82, 69123 Heidelberg
GERMANY

Name and address of the manufacturer

ABB-Stotz-Kontakt GmbH
Eppelheimer Straße 82, 69123 Heidelberg
GERMANY

Name and address of the factory

ABB Bulgaria EOOD - Rakovski Branch -
Rakovski Industrial zone 14, Industrial Road 1, 4142
RAKOVSKI
BULGARIA*Note: When more than one factory, please report on page 2*☐ Additional Information on page 2

Ratings and principal characteristics

AC 230/400 V; B 6 - 63 A; C/D 0,5 - 63 A Number of poles:
1;2:3;4; 1+N; 3+N

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

Serie / series SH 20.; SV 20. (6 kA); SH 20.L (4,5 kA); SH
20.T (3 kA)Additional information (if necessary may also be
reported on page 2)☐ Additional Information on page 2A sample of the product was tested and found
to be in conformity withIEC 60898-1:2015
IEC 60898-1:2015/AMD1:2019As shown in the Test Report Ref. No. which
forms part of this Certificate

277128-TL3-000 to 277128-TL3-137

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH**VDE** Testing and Certification Institute

Zertifizierungsstelle und internat. Angelegenheiten

Certification Body and internat. Affairs

Date: 2020-11-26

Signature:


R. Nickel