

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE CERTIFICAT D'ESSAI OC

Product
Produit

Circuit breaker

Name and address of the applicant
Nom et adresse du demandeur

ABB-Stotz-Kontakt GmbH
Eppelheimer Straße 82, 69123 Heidelberg
GERMANY

Name and address of the manufacturer
Nom et adresse du fabricant

ABB-Stotz-Kontakt GmbH
Eppelheimer Straße 82, 69123 Heidelberg
GERMANY

Name and address of the factory
Nom et adresse de l'usine

ABB Bulgaria EOOD - Rakovski Branch -
Industrial Zone, Plovdiv District, Rakovski Municipality
4150 RAKOVSKI
BULGARIEN

Note: When more than one factory, please report on page 2
Note: Lorsque il y a plus d'une usine, veuillez utiliser la 2^{ème} page

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

☒ Additional Information on page 2
133/230 V a.c.; 230/400 V a.c.; 440 V a.c.; 0,5 - 63 A
1-; 1+N-; 2-; 3-; 3+N-; 4-pole;
Instantaneous tripping current: type B; C

Trademark (if any)
Marque de fabrique (si elle existe)



Type of Manufacturer's Testing Laboratories used
Type de programme du laboratoire d'essais constructeur

WMT Procedure

Model / Type Ref.
Ref. De type

Series S200M
S201M; S202M; S203M; S204M; S201M-NA; S203M-NA

Additional information (if necessary may also be
reported on page 2)
Les informations complémentaires (si nécessaire,
peuvent être indiqués sur la 2^{ème} page)

Test Report Ref. 70000-4402-0008/177392-1

☒ Additional Information on page 2

PUBLICATION

EDITION

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

IEC 60947-1(ed.5);am1
IEC 60947-2(ed.4);am1

As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

70000-4402-0008/177392

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierungsstelle / Certification


Dr. G. Schipper

Date: 2013-05-21

Signature:



Ref. Certif. No.

DE1-52231

ABB S.A.
Ruta 157 - km 1233,5, 1661 BELLA VISTA
ARGENTINA

Additional information (if necessary)
Information complémentaire (si nécessaire)

Rating and principal characteristics:

Icu: 25 kA (133/230 V); 15 kA (230/400 V; 440 V)

Ics: 18,75 kA (133/230 V, 0,5 - 40 A); 15 kA (133/230 V, 50 - 63 A);

11,25 kA (230/400 V; 440 V, 0,5 - 40 A); 7,5 kA (230/400 V; 440 V, 50 - 63 A)

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierungsstelle / Certification


Dr. G. Schipper

Date: 2013-05-21

Signature: