AENOR

AENOR Product Certificate
Low Voltage Material

AENOR
Producto Certificado

030/002467

AENOR certifies that the organization

ABB STOTZ KONTAKT, GmbH

registered office	EPPELHEIMER STR. 82 - 69123 HEIDELBERG *(Alemania)*
supplies	Circuit-Breakers for overcurrent protection for household and similar installation
in compliance with	UNE-EN 60898-1:2004 *(EN 60898-1:2003; EN 60898-1:2003 CORR:2004)* UNE-EN 60898-1:2004/A11:2006 *(EN 60898-1:2003/A11:2005)* UNE-EN 60898-1:2004/A1:2005 *(EN 60898-1:2003/A1:2004)* UNE-EN 60898-1:2004/A12:2009 *(EN 60898-1:2003/A12:2008)* UNE-EN 60898-1:2004/A13:2013 *(EN 60898-1:2003/A13:2012)*
References	Specified in Annex to the Certificate
Production site	Plot, 28 Industrial Zone - 4150 RAKOVSKI *(Bulgaria)*
Certification scheme	In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP 030.15.
First issued on	2018-04-24
Validity date	2023-04-24

Rafael GARCÍA MEIRO
Chief Executive Officer

Original Electronic Certificate

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Trade mark: ABB

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH201 B10	1P	230/400 V-	10 A	6000 A	6000 A	3	B
SH201 B13	1P	230/400 V-	13 A	6000 A	6000 A	3	B
SH201 B16	1P	230/400 V-	16 A	6000 A	6000 A	3	B
SH201 B20	1P	230/400 V-	20 A	6000 A	6000 A	3	B
SH201 B25	1P	230/400 V-	25 A	6000 A	6000 A	3	B
SH201 B32	1P	230/400 V-	32 A	6000 A	6000 A	3	B
SH201 B40	1P	230/400 V-	40 A	6000 A	6000 A	3	B
SH201 B50	1P	230/400 V-	50 A	6000 A	6000 A	3	B
SH201 B6	1P	230/400 V-	6 A	6000 A	6000 A	3	B
SH201 B63	1P	230/400 V-	63 A	6000 A	6000 A	3	B
SH201 B8	1P	230/400 V-	8 A	6000 A	6000 A	3	B
SH201 C0,5	1P	230/400 V-	0,5 A	6000 A	6000 A	3	C
SH201 C1	1P	230/400 V-	1 A	6000 A	6000 A	3	C
SH201 C10	1P	230/400 V-	10 A	6000 A	6000 A	3	C
SH201 C13	1P	230/400 V-	13 A	6000 A	6000 A	3	C
SH201 C1,6	1P	230/400 V-	1,6 A	6000 A	6000 A	3	C
SH201 C16	1P	230/400 V-	16 A	6000 A	6000 A	3	C
SH201 C2	1P	230/400 V-	2 A	6000 A	6000 A	3	C
SH201 C20	1P	230/400 V-	20 A	6000 A	6000 A	3	C
SH201 C25	1P	230/400 V-	25 A	6000 A	6000 A	3	C
SH201 C3	1P	230/400 V-	3 A	6000 A	6000 A	3	C
SH201 C32	1P	230/400 V-	32 A	6000 A	6000 A	3	C
SH201 C4	1P	230/400 V-	4 A	6000 A	6000 A	3	C
SH201 C40	1P	230/400 V-	40 A	6000 A	6000 A	3	C
SH201 C50	1P	230/400 V-	50 A	6000 A	6000 A	3	C
SH201 C6	1P	230/400 V-	6 A	6000 A	6000 A	3	C
SH201 C63	1P	230/400 V-	63 A	6000 A	6000 A	3	C
SH201 C8	1P	230/400 V-	8 A	6000 A	6000 A	3	C

First issued on 2018-04-24
Validity date 2023-04-24

Original Electronic Certificate

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH201 D0,5	1P	230/400 V~	0,5 A	6000 A	6000 A	---	D
SH201 D1	1P	230/400 V~	1 A	6000 A	6000 A	---	D
SH201 D10	1P	230/400 V~	10 A	6000 A	6000 A	---	D
SH201 D13	1P	230/400 V~	13 A	6000 A	6000 A	---	D
SH201 D1,6	1P	230/400 V~	1,6 A	6000 A	6000 A	---	D
SH201 D16	1P	230/400 V~	16 A	6000 A	6000 A	---	D
SH201 D2	1P	230/400 V~	2 A	6000 A	6000 A	---	D
SH201 D20	1P	230/400 V~	20 A	6000 A	6000 A	---	D
SH201 D25	1P	230/400 V~	25 A	6000 A	6000 A	---	D
SH201 D3	1P	230/400 V~	3 A	6000 A	6000 A	---	D
SH201 D32	1P	230/400 V~	32 A	6000 A	6000 A	---	D
SH201 D4	1P	230/400 V~	4 A	6000 A	6000 A	---	D
SH201 D40	1P	230/400 V~	40 A	6000 A	6000 A	---	D
SH201 D50	1P	230/400 V~	50 A	6000 A	6000 A	---	D
SH201 D6	1P	230/400 V~	6 A	6000 A	6000 A	---	D
SH201 D63	1P	230/400 V~	63 A	6000 A	6000 A	---	D
SH201 D8	1P	230/400 V~	8 A	6000 A	6000 A	---	D
SH201L B10	1P	230/400 V~	10 A	4500 A	4500 A	3	B
SH201L B13	1P	230/400 V~	13 A	4500 A	4500 A	3	B
SH201L B16	1P	230/400 V~	16 A	4500 A	4500 A	3	B
SH201L B20	1P	230/400 V~	20 A	4500 A	4500 A	3	B
SH201L B25	1P	230/400 V~	25 A	4500 A	4500 A	3	B
SH201L B32	1P	230/400 V~	32 A	4500 A	4500 A	3	B
SH201L B40	1P	230/400 V~	40 A	4500 A	4500 A	3	B
SH201L B50	1P	230/400 V~	50 A	4500 A	4500 A	3	B
SH201L B6	1P	230/400 V~	6 A	4500 A	4500 A	3	B
SH201L B63	1P	230/400 V~	63 A	4500 A	4500 A	3	B
SH201L B8	1P	230/400 V~	8 A	4500 A	4500 A	3	B
SH201L C0,5	1P	230/400 V~	0,5 A	4500 A	4500 A	3	C

First issued on 2018-04-24
Validity date 2023-04-24

Original Electronic Certificate

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH201L C1	1P	230/400 V-	1 A	4500 A	4500 A	3	C
SH201L C10	1P	230/400 V-	10 A	4500 A	4500 A	3	C
SH201L C13	1P	230/400 V-	13 A	4500 A	4500 A	3	C
SH201L C1,6	1P	230/400 V-	1,6 A	4500 A	4500 A	3	C
SH201L C16	1P	230/400 V-	16 A	4500 A	4500 A	3	C
SH201L C2	1P	230/400 V-	2 A	4500 A	4500 A	3	C
SH201L C20	1P	230/400 V-	20 A	4500 A	4500 A	3	C
SH201L C25	1P	230/400 V-	25 A	4500 A	4500 A	3	C
SH201L C3	1P	230/400 V-	3 A	4500 A	4500 A	3	C
SH201L C32	1P	230/400 V-	32 A	4500 A	4500 A	3	C
SH201L C4	1P	230/400 V-	4 A	4500 A	4500 A	3	C
SH201L C40	1P	230/400 V-	40 A	4500 A	4500 A	3	C
SH201L C50	1P	230/400 V-	50 A	4500 A	4500 A	3	C
SH201L C6	1P	230/400 V-	6 A	4500 A	4500 A	3	C
SH201L C63	1P	230/400 V-	63 A	4500 A	4500 A	3	C
SH201L C8	1P	230/400 V-	8 A	4500 A	4500 A	3	C
SH201L D0,5	1P	230/400 V-	0,5 A	4500 A	4500 A	---	D
SH201L D1	1P	230/400 V-	1 A	4500 A	4500 A	---	D
SH201L D10	1P	230/400 V-	10 A	4500 A	4500 A	---	D
SH201L D13	1P	230/400 V-	13 A	4500 A	4500 A	---	D
SH201L D1,6	1P	230/400 V-	1,6 A	4500 A	4500 A	---	D
SH201L D16	1P	230/400 V-	16 A	4500 A	4500 A	---	D
SH201L D2	1P	230/400 V-	2 A	4500 A	4500 A	---	D
SH201L D20	1P	230/400 V-	20 A	4500 A	4500 A	---	D
SH201L D25	1P	230/400 V-	25 A	4500 A	4500 A	---	D
SH201L D3	1P	230/400 V-	3 A	4500 A	4500 A	---	D
SH201L D32	1P	230/400 V-	32 A	4500 A	4500 A	---	D
SH201L D4	1P	230/400 V-	4 A	4500 A	4500 A	---	D
SH201L D40	1P	230/400 V-	40 A	4500 A	4500 A	---	D

First issued on 2018-04-24
Validity date 2023-04-24

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Original Electronic Certificate

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH201L D50	1P	230/400 V~	50 A	4500 A	4500 A	---	D
SH201L D6	1P	230/400 V~	6 A	4500 A	4500 A	---	D
SH201L D63	1P	230/400 V~	63 A	4500 A	4500 A	---	D
SH201L D8	1P	230/400 V~	8 A	4500 A	4500 A	---	D
SH201L-NA B10	1P+N	230 V~	10 A	4500 A	4500 A	3	B
SH201L-NA B13	1P+N	230 V~	13 A	4500 A	4500 A	3	B
SH201L-NA B16	1P+N	230 V~	16 A	4500 A	4500 A	3	B
SH201L-NA B20	1P+N	230 V~	20 A	4500 A	4500 A	3	B
SH201L-NA B25	1P+N	230 V~	25 A	4500 A	4500 A	3	B
SH201L-NA B32	1P+N	230 V~	32 A	4500 A	4500 A	3	B
SH201L-NA B40	1P+N	230 V~	40 A	4500 A	4500 A	3	B
SH201L-NA B50	1P+N	230 V~	50 A	4500 A	4500 A	3	B
SH201L-NA B6	1P+N	230 V~	6 A	4500 A	4500 A	3	B
SH201L-NA B63	1P+N	230 V~	63 A	4500 A	4500 A	3	B
SH201L-NA B8	1P+N	230 V~	8 A	4500 A	4500 A	3	B
SH201L-NA C0,5	1P+N	230 V~	0,5 A	4500 A	4500 A	3	C
SH201L-NA C1	1P+N	230 V~	1 A	4500 A	4500 A	3	C
SH201L-NA C10	1P+N	230 V~	10 A	4500 A	4500 A	3	C
SH201L-NA C13	1P+N	230 V~	13 A	4500 A	4500 A	3	C
SH201L-NA C1,6	1P+N	230 V~	1,6 A	4500 A	4500 A	3	C
SH201L-NA C16	1P+N	230 V~	16 A	4500 A	4500 A	3	C
SH201L-NA C2	1P+N	230 V~	2 A	4500 A	4500 A	3	C
SH201L-NA C20	1P+N	230 V~	20 A	4500 A	4500 A	3	C
SH201L-NA C25	1P+N	230 V~	25 A	4500 A	4500 A	3	C
SH201L-NA C3	1P+N	230 V~	3 A	4500 A	4500 A	3	C
SH201L-NA C32	1P+N	230 V~	32 A	4500 A	4500 A	3	C
SH201L-NA C4	1P+N	230 V~	4 A	4500 A	4500 A	3	C
SH201L-NA C40	1P+N	230 V~	40 A	4500 A	4500 A	3	C
SH201L-NA C50	1P+N	230 V~	50 A	4500 A	4500 A	3	C

First issued on 2018-04-24
Validity date 2023-04-24

Original Electronic Certificate

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH201L-NA C6	1P+N	230 V~	6 A	4500 A	4500 A	3	C
SH201L-NA C63	1P+N	230 V~	63 A	4500 A	4500 A	3	C
SH201L-NA C8	1P+N	230 V~	8 A	4500 A	4500 A	3	C
SH201L-NA D0,5	1P+N	230 V~	0,5 A	4500 A	4500 A	---	D
SH201L-NA D1	1P+N	230 V~	1 A	4500 A	4500 A	---	D
SH201L-NA D10	1P+N	230 V~	10 A	4500 A	4500 A	---	D
SH201L-NA D13	1P+N	230 V~	13 A	4500 A	4500 A	---	D
SH201L-NA D1,6	1P+N	230 V~	1,6 A	4500 A	4500 A	---	D
SH201L-NA D16	1P+N	230 V~	16 A	4500 A	4500 A	---	D
SH201L-NA D2	1P+N	230 V~	2 A	4500 A	4500 A	---	D
SH201L-NA D20	1P+N	230 V~	20 A	4500 A	4500 A	---	D
SH201L-NA D25	1P+N	230 V~	25 A	4500 A	4500 A	---	D
SH201L-NA D3	1P+N	230 V~	3 A	4500 A	4500 A	---	D
SH201L-NA D32	1P+N	230 V~	32 A	4500 A	4500 A	---	D
SH201L-NA D4	1P+N	230 V~	4 A	4500 A	4500 A	---	D
SH201L-NA D40	1P+N	230 V~	40 A	4500 A	4500 A	---	D
SH201L-NA D50	1P+N	230 V~	50 A	4500 A	4500 A	---	D
SH201L-NA D6	1P+N	230 V~	6 A	4500 A	4500 A	---	D
SH201L-NA D63	1P+N	230 V~	63 A	4500 A	4500 A	---	D
SH201L-NA D8	1P+N	230 V~	8 A	4500 A	4500 A	---	D
SH201-NA B10	1P+N	230 V~	10 A	6000 A	6000 A	3	B
SH201-NA B13	1P+N	230 V~	13 A	6000 A	6000 A	3	B
SH201-NA B16	1P+N	230 V~	16 A	6000 A	6000 A	3	B
SH201-NA B20	1P+N	230 V~	20 A	6000 A	6000 A	3	B
SH201-NA B25	1P+N	230 V~	25 A	6000 A	6000 A	3	B
SH201-NA B32	1P+N	230 V~	32 A	6000 A	6000 A	3	B
SH201-NA B40	1P+N	230 V~	40 A	6000 A	6000 A	3	B
SH201-NA B50	1P+N	230 V~	50 A	6000 A	6000 A	3	B
SH201-NA B6	1P+N	230 V~	6 A	6000 A	6000 A	3	B

First issued on 2018-04-24
Validity date 2023-04-24

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Original Electronic Certificate

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH201-NA B63	1P+N	230 V~	63 A	6000 A	6000 A	3	B
SH201-NA B8	1P+N	230 V~	8 A	6000 A	6000 A	3	B
SH201-NA C0,5	1P+N	230 V~	0,5 A	6000 A	6000 A	3	C
SH201-NA C1	1P+N	230 V~	1 A	6000 A	6000 A	3	C
SH201-NA C10	1P+N	230 V~	10 A	6000 A	6000 A	3	C
SH201-NA C13	1P+N	230 V~	13 A	6000 A	6000 A	3	C
SH201-NA C1,6	1P+N	230 V~	1,6 A	6000 A	6000 A	3	C
SH201-NA C16	1P+N	230 V~	16 A	6000 A	6000 A	3	C
SH201-NA C2	1P+N	230 V~	2 A	6000 A	6000 A	3	C
SH201-NA C20	1P+N	230 V~	20 A	6000 A	6000 A	3	C
SH201-NA C25	1P+N	230 V~	25 A	6000 A	6000 A	3	C
SH201-NA C3	1P+N	230 V~	3 A	6000 A	6000 A	3	C
SH201-NA C32	1P+N	230 V~	32 A	6000 A	6000 A	3	C
SH201-NA C4	1P+N	230 V~	4 A	6000 A	6000 A	3	C
SH201-NA C40	1P+N	230 V~	40 A	6000 A	6000 A	3	C
SH201-NA C50	1P+N	230 V~	50 A	6000 A	6000 A	3	C
SH201-NA C6	1P+N	230 V~	6 A	6000 A	6000 A	3	C
SH201-NA C63	1P+N	230 V~	63 A	6000 A	6000 A	3	C
SH201-NA C8	1P+N	230 V~	8 A	6000 A	6000 A	3	C
SH201-NA D0,5	1P+N	230 V~	0,5 A	6000 A	6000 A	---	D
SH201-NA D1	1P+N	230 V~	1 A	6000 A	6000 A	---	D
SH201-NA D10	1P+N	230 V~	10 A	6000 A	6000 A	---	D
SH201-NA D13	1P+N	230 V~	13 A	6000 A	6000 A	---	D
SH201-NA D1,6	1P+N	230 V~	1,6 A	6000 A	6000 A	---	D
SH201-NA D16	1P+N	230 V~	16 A	6000 A	6000 A	---	D
SH201-NA D2	1P+N	230 V~	2 A	6000 A	6000 A	---	D
SH201-NA D20	1P+N	230 V~	20 A	6000 A	6000 A	---	D
SH201-NA D25	1P+N	230 V~	25 A	6000 A	6000 A	---	D
SH201-NA D3	1P+N	230 V~	3 A	6000 A	6000 A	---	D

First issued on 2018-04-24
Validity date 2023-04-24

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Original Electronic Certificate

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH201-NA D32	1P+N	230 V~	32 A	6000 A	6000 A	---	D
SH201-NA D4	1P+N	230 V~	4 A	6000 A	6000 A	---	D
SH201-NA D40	1P+N	230 V~	40 A	6000 A	6000 A	---	D
SH201-NA D50	1P+N	230 V~	50 A	6000 A	6000 A	---	D
SH201-NA D6	1P+N	230 V~	6 A	6000 A	6000 A	---	D
SH201-NA D63	1P+N	230 V~	63 A	6000 A	6000 A	---	D
SH201-NA D8	1P+N	230 V~	8 A	6000 A	6000 A	---	D
SH201-NAL C13	1P+N	230 V~	13 A	4500 A	4500 A	3	C
SH201-NAL C16	1P+N	230 V~	16 A	4500 A	4500 A	3	C
SH201T B10	1P	230/400 V~	10 A	3000 A	3000 A	3	B
SH201T B13	1P	230/400 V~	13 A	3000 A	3000 A	3	B
SH201T B16	1P	230/400 V~	16 A	3000 A	3000 A	3	B
SH201T B20	1P	230/400 V~	20 A	3000 A	3000 A	3	B
SH201T B25	1P	230/400 V~	25 A	3000 A	3000 A	3	B
SH201T B32	1P	230/400 V~	32 A	3000 A	3000 A	3	B
SH201T B40	1P	230/400 V~	40 A	3000 A	3000 A	3	B
SH201T B50	1P	230/400 V~	50 A	3000 A	3000 A	3	B
SH201T B6	1P	230/400 V~	6 A	3000 A	3000 A	3	B
SH201T B63	1P	230/400 V~	63 A	3000 A	3000 A	3	B
SH201T B8	1P	230/400 V~	8 A	3000 A	3000 A	3	B
SH201T C0,5	1P	230/400 V~	0,5 A	3000 A	3000 A	3	C
SH201T C1	1P	230/400 V~	1 A	3000 A	3000 A	3	C
SH201T C10	1P	230/400 V~	10 A	3000 A	3000 A	3	C
SH201T C13	1P	230/400 V~	13 A	3000 A	3000 A	3	C
SH201T C1,6	1P	230/400 V~	1,6 A	3000 A	3000 A	3	C
SH201T C16	1P	230/400 V~	16 A	3000 A	3000 A	3	C
SH201T C2	1P	230/400 V~	2 A	3000 A	3000 A	3	C
SH201T C20	1P	230/400 V~	20 A	3000 A	3000 A	3	C
SH201T C25	1P	230/400 V~	25 A	3000 A	3000 A	3	C

First issued on 2018-04-24
Validity date 2023-04-24

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Original Electronic Certificate

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH201T C3	1P	230/400 V-	3 A	3000 A	3000 A	3	C
SH201T C32	1P	230/400 V-	32 A	3000 A	3000 A	3	C
SH201T C4	1P	230/400 V-	4 A	3000 A	3000 A	3	C
SH201T C40	1P	230/400 V-	40 A	3000 A	3000 A	3	C
SH201T C50	1P	230/400 V-	50 A	3000 A	3000 A	3	C
SH201T C6	1P	230/400 V-	6 A	3000 A	3000 A	3	C
SH201T C63	1P	230/400 V-	63 A	3000 A	3000 A	3	C
SH201T C8	1P	230/400 V-	8 A	3000 A	3000 A	3	C
SH201T D0,5	1P	230/400 V-	0,5 A	3000 A	3000 A	---	D
SH201T D1	1P	230/400 V-	1 A	3000 A	3000 A	---	D
SH201T D10	1P	230/400 V-	10 A	3000 A	3000 A	---	D
SH201T D13	1P	230/400 V-	13 A	3000 A	3000 A	---	D
SH201T D1,6	1P	230/400 V-	1,6 A	3000 A	3000 A	---	D
SH201T D16	1P	230/400 V-	16 A	3000 A	3000 A	---	D
SH201T D2	1P	230/400 V-	2 A	3000 A	3000 A	---	D
SH201T D20	1P	230/400 V-	20 A	3000 A	3000 A	---	D
SH201T D25	1P	230/400 V-	25 A	3000 A	3000 A	---	D
SH201T D3	1P	230/400 V-	3 A	3000 A	3000 A	---	D
SH201T D32	1P	230/400 V-	32 A	3000 A	3000 A	---	D
SH201T D4	1P	230/400 V-	4 A	3000 A	3000 A	---	D
SH201T D40	1P	230/400 V-	40 A	3000 A	3000 A	---	D
SH201T D50	1P	230/400 V-	50 A	3000 A	3000 A	---	D
SH201T D6	1P	230/400 V-	6 A	3000 A	3000 A	---	D
SH201T D63	1P	230/400 V-	63 A	3000 A	3000 A	---	D
SH201T D8	1P	230/400 V-	8 A	3000 A	3000 A	---	D
SH201T-NA B10	1P+N	230 V-	10 A	3000 A	3000 A	3	B
SH201T-NA B13	1P+N	230 V-	13 A	3000 A	3000 A	3	B
SH201T-NA B16	1P+N	230 V-	16 A	3000 A	3000 A	3	B
SH201T-NA B20	1P+N	230 V-	20 A	3000 A	3000 A	3	B

First issued on 2018-04-24
Validity date 2023-04-24

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Original Electronic Certificate

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH201T-NA B25	1P+N	230 V~	25 A	3000 A	3000 A	3	B
SH201T-NA B32	1P+N	230 V~	32 A	3000 A	3000 A	3	B
SH201T-NA B40	1P+N	230 V~	40 A	3000 A	3000 A	3	B
SH201T-NA B50	1P+N	230 V~	50 A	3000 A	3000 A	3	B
SH201T-NA B6	1P+N	230 V~	6 A	3000 A	3000 A	3	B
SH201T-NA B63	1P+N	230 V~	63 A	3000 A	3000 A	3	B
SH201T-NA B8	1P+N	230 V~	8 A	3000 A	3000 A	3	B
SH201T-NA C0,5	1P+N	230 V~	0,5 A	3000 A	3000 A	3	C
SH201T-NA C1	1P+N	230 V~	1 A	3000 A	3000 A	3	C
SH201T-NA C10	1P+N	230 V~	10 A	3000 A	3000 A	3	C
SH201T-NA C13	1P+N	230 V~	13 A	3000 A	3000 A	3	C
SH201T-NA C1,6	1P+N	230 V~	1,6 A	3000 A	3000 A	3	C
SH201T-NA C16	1P+N	230 V~	16 A	3000 A	3000 A	3	C
SH201T-NA C2	1P+N	230 V~	2 A	3000 A	3000 A	3	C
SH201T-NA C20	1P+N	230 V~	20 A	3000 A	3000 A	3	C
SH201T-NA C25	1P+N	230 V~	25 A	3000 A	3000 A	3	C
SH201T-NA C3	1P+N	230 V~	3 A	3000 A	3000 A	3	C
SH201T-NA C32	1P+N	230 V~	32 A	3000 A	3000 A	3	C
SH201T-NA C4	1P+N	230 V~	4 A	3000 A	3000 A	3	C
SH201T-NA C40	1P+N	230 V~	40 A	3000 A	3000 A	3	C
SH201T-NA C50	1P+N	230 V~	50 A	3000 A	3000 A	3	C
SH201T-NA C6	1P+N	230 V~	6 A	3000 A	3000 A	3	C
SH201T-NA C63	1P+N	230 V~	63 A	3000 A	3000 A	3	C
SH201T-NA C8	1P+N	230 V~	8 A	3000 A	3000 A	3	C
SH201T-NA D0,5	1P+N	230 V~	0,5 A	3000 A	3000 A	---	D
SH201T-NA D1	1P+N	230 V~	1 A	3000 A	3000 A	---	D
SH201T-NA D10	1P+N	230 V~	10 A	3000 A	3000 A	---	D
SH201T-NA D13	1P+N	230 V~	13 A	3000 A	3000 A	---	D
SH201T-NA D1,6	1P+N	230 V~	1,6 A	3000 A	3000 A	---	D

First issued on 2018-04-24
Validity date 2023-04-24

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Original Electronic Certificate

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH201T-NA D16	1P+N	230 V~	16 A	3000 A	3000 A	---	D
SH201T-NA D2	1P+N	230 V~	2 A	3000 A	3000 A	---	D
SH201T-NA D20	1P+N	230 V~	20 A	3000 A	3000 A	---	D
SH201T-NA D25	1P+N	230 V~	25 A	3000 A	3000 A	---	D
SH201T-NA D3	1P+N	230 V~	3 A	3000 A	3000 A	---	D
SH201T-NA D32	1P+N	230 V~	32 A	3000 A	3000 A	---	D
SH201T-NA D4	1P+N	230 V~	4 A	3000 A	3000 A	---	D
SH201T-NA D40	1P+N	230 V~	40 A	3000 A	3000 A	---	D
SH201T-NA D50	1P+N	230 V~	50 A	3000 A	3000 A	---	D
SH201T-NA D6	1P+N	230 V~	6 A	3000 A	3000 A	---	D
SH201T-NA D63	1P+N	230 V~	63 A	3000 A	3000 A	---	D
SH201T-NA D8	1P+N	230 V~	8 A	3000 A	3000 A	---	D
SH202 B10	2P	400 V~	10 A	6000 A	6000 A	3	B
SH202 B13	2P	400 V~	13 A	6000 A	6000 A	3	B
SH202 B16	2P	400 V~	16 A	6000 A	6000 A	3	B
SH202 B20	2P	400 V~	20 A	6000 A	6000 A	3	B
SH202 B25	2P	400 V~	25 A	6000 A	6000 A	3	B
SH202 B32	2P	400 V~	32 A	6000 A	6000 A	3	B
SH202 B40	2P	400 V~	40 A	6000 A	6000 A	3	B
SH202 B50	2P	400 V~	50 A	6000 A	6000 A	3	B
SH202 B6	2P	400 V~	6 A	6000 A	6000 A	3	B
SH202 B63	2P	400 V~	63 A	6000 A	6000 A	3	B
SH202 B8	2P	400 V~	8 A	6000 A	6000 A	3	B
SH202 C0,5	2P	400 V~	0,5 A	6000 A	6000 A	3	C
SH202 C1	2P	400 V~	1 A	6000 A	6000 A	3	C
SH202 C10	2P	400 V~	10 A	6000 A	6000 A	3	C
SH202 C13	2P	400 V~	13 A	6000 A	6000 A	3	C
SH202 C1,6	2P	400 V~	1,6 A	6000 A	6000 A	3	C
SH202 C16	2P	400 V~	16 A	6000 A	6000 A	3	C

First issued on 2018-04-24
Validity date 2023-04-24

Original Electronic Certificate

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH202 C2	2P	400 V~	2 A	6000 A	6000 A	3	C
SH202 C20	2P	400 V~	20 A	6000 A	6000 A	3	C
SH202 C25	2P	400 V~	25 A	6000 A	6000 A	3	C
SH202 C3	2P	400 V~	3 A	6000 A	6000 A	3	C
SH202 C32	2P	400 V~	32 A	6000 A	6000 A	3	C
SH202 C4	2P	400 V~	4 A	6000 A	6000 A	3	C
SH202 C40	2P	400 V~	40 A	6000 A	6000 A	3	C
SH202 C50	2P	400 V~	50 A	6000 A	6000 A	3	C
SH202 C6	2P	400 V~	6 A	6000 A	6000 A	3	C
SH202 C63	2P	400 V~	63 A	6000 A	6000 A	3	C
SH202 C8	2P	400 V~	8 A	6000 A	6000 A	3	C
SH202 D0,5	2P	400 V~	0,5 A	6000 A	6000 A	---	D
SH202 D1	2P	400 V~	1 A	6000 A	6000 A	---	D
SH202 D10	2P	400 V~	10 A	6000 A	6000 A	---	D
SH202 D13	2P	400 V~	13 A	6000 A	6000 A	---	D
SH202 D1,6	2P	400 V~	1,6 A	6000 A	6000 A	---	D
SH202 D16	2P	400 V~	16 A	6000 A	6000 A	---	D
SH202 D2	2P	400 V~	2 A	6000 A	6000 A	---	D
SH202 D20	2P	400 V~	20 A	6000 A	6000 A	---	D
SH202 D25	2P	400 V~	25 A	6000 A	6000 A	---	D
SH202 D3	2P	400 V~	3 A	6000 A	6000 A	---	D
SH202 D32	2P	400 V~	32 A	6000 A	6000 A	---	D
SH202 D4	2P	400 V~	4 A	6000 A	6000 A	---	D
SH202 D40	2P	400 V~	40 A	6000 A	6000 A	---	D
SH202 D50	2P	400 V~	50 A	6000 A	6000 A	---	D
SH202 D6	2P	400 V~	6 A	6000 A	6000 A	---	D
SH202 D63	2P	400 V~	63 A	6000 A	6000 A	---	D
SH202 D8	2P	400 V~	8 A	6000 A	6000 A	---	D
SH202L B10	2P	400 V~	10 A	4500 A	4500 A	3	B

First issued on 2018-04-24
Validity date 2023-04-24

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Original Electronic Certificate

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH202L B13	2P	400 V~	13 A	4500 A	4500 A	3	B
SH202L B16	2P	400 V~	16 A	4500 A	4500 A	3	B
SH202L B20	2P	400 V~	20 A	4500 A	4500 A	3	B
SH202L B25	2P	400 V~	25 A	4500 A	4500 A	3	B
SH202L B32	2P	400 V~	32 A	4500 A	4500 A	3	B
SH202L B40	2P	400 V~	40 A	4500 A	4500 A	3	B
SH202L B50	2P	400 V~	50 A	4500 A	4500 A	3	B
SH202L B6	2P	400 V~	6 A	4500 A	4500 A	3	B
SH202L B63	2P	400 V~	63 A	4500 A	4500 A	3	B
SH202L B8	2P	400 V~	8 A	4500 A	4500 A	3	B
SH202L C0,5	2P	400 V~	0,5 A	4500 A	4500 A	3	C
SH202L C1	2P	400 V~	1 A	4500 A	4500 A	3	C
SH202L C10	2P	400 V~	10 A	4500 A	4500 A	3	C
SH202L C13	2P	400 V~	13 A	4500 A	4500 A	3	C
SH202L C1,6	2P	400 V~	1,6 A	4500 A	4500 A	3	C
SH202L C16	2P	400 V~	16 A	4500 A	4500 A	3	C
SH202L C2	2P	400 V~	2 A	4500 A	4500 A	3	C
SH202L C20	2P	400 V~	20 A	4500 A	4500 A	3	C
SH202L C25	2P	400 V~	25 A	4500 A	4500 A	3	C
SH202L C3	2P	400 V~	3 A	4500 A	4500 A	3	C
SH202L C32	2P	400 V~	32 A	4500 A	4500 A	3	C
SH202L C4	2P	400 V~	4 A	4500 A	4500 A	3	C
SH202L C40	2P	400 V~	40 A	4500 A	4500 A	3	C
SH202L C50	2P	400 V~	50 A	4500 A	4500 A	3	C
SH202L C6	2P	400 V~	6 A	4500 A	4500 A	3	C
SH202L C63	2P	400 V~	63 A	4500 A	4500 A	3	C
SH202L C8	2P	400 V~	8 A	4500 A	4500 A	3	C
SH202L D0,5	2P	400 V~	0,5 A	4500 A	4500 A	---	D
SH202L D1	2P	400 V~	1 A	4500 A	4500 A	---	D

First issued on 2018-04-24
Validity date 2023-04-24

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Original Electronic Certificate

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH202L D10	2P	400 V~	10 A	4500 A	4500 A	---	D
SH202L D13	2P	400 V~	13 A	4500 A	4500 A	---	D
SH202L D1,6	2P	400 V~	1,6 A	4500 A	4500 A	---	D
SH202L D16	2P	400 V~	16 A	4500 A	4500 A	---	D
SH202L D2	2P	400 V~	2 A	4500 A	4500 A	---	D
SH202L D20	2P	400 V~	20 A	4500 A	4500 A	---	D
SH202L D25	2P	400 V~	25 A	4500 A	4500 A	---	D
SH202L D3	2P	400 V~	3 A	4500 A	4500 A	---	D
SH202L D32	2P	400 V~	32 A	4500 A	4500 A	---	D
SH202L D4	2P	400 V~	4 A	4500 A	4500 A	---	D
SH202L D40	2P	400 V~	40 A	4500 A	4500 A	---	D
SH202L D50	2P	400 V~	50 A	4500 A	4500 A	---	D
SH202L D6	2P	400 V~	6 A	4500 A	4500 A	---	D
SH202L D63	2P	400 V~	63 A	4500 A	4500 A	---	D
SH202L D8	2P	400 V~	8 A	4500 A	4500 A	---	D
SH202T B10	2P	400 V~	10 A	3000 A	3000 A	3	B
SH202T B13	2P	400 V~	13 A	3000 A	3000 A	3	B
SH202T B16	2P	400 V~	16 A	3000 A	3000 A	3	B
SH202T B20	2P	400 V~	20 A	3000 A	3000 A	3	B
SH202T B25	2P	400 V~	25 A	3000 A	3000 A	3	B
SH202T B32	2P	400 V~	32 A	3000 A	3000 A	3	B
SH202T B40	2P	400 V~	40 A	3000 A	3000 A	3	B
SH202T B50	2P	400 V~	50 A	3000 A	3000 A	3	B
SH202T B6	2P	400 V~	6 A	3000 A	3000 A	3	B
SH202T B63	2P	400 V~	63 A	3000 A	3000 A	3	B
SH202T B8	2P	400 V~	8 A	3000 A	3000 A	3	B
SH202T C0,5	2P	400 V~	0,5 A	3000 A	3000 A	3	C
SH202T C1	2P	400 V~	1 A	3000 A	3000 A	3	C
SH202T C10	2P	400 V~	10 A	3000 A	3000 A	3	C

First issued on 2018-04-24
Validity date 2023-04-24

Original Electronic Certificate

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH202T C13	2P	400 V~	13 A	3000 A	3000 A	3	C
SH202T C1,6	2P	400 V~	1,6 A	3000 A	3000 A	3	C
SH202T C16	2P	400 V~	16 A	3000 A	3000 A	3	C
SH202T C2	2P	400 V~	2 A	3000 A	3000 A	3	C
SH202T C20	2P	400 V~	20 A	3000 A	3000 A	3	C
SH202T C25	2P	400 V~	25 A	3000 A	3000 A	3	C
SH202T C3	2P	400 V~	3 A	3000 A	3000 A	3	C
SH202T C32	2P	400 V~	32 A	3000 A	3000 A	3	C
SH202T C4	2P	400 V~	4 A	3000 A	3000 A	3	C
SH202T C40	2P	400 V~	40 A	3000 A	3000 A	3	C
SH202T C50	2P	400 V~	50 A	3000 A	3000 A	3	C
SH202T C6	2P	400 V~	6 A	3000 A	3000 A	3	C
SH202T C63	2P	400 V~	63 A	3000 A	3000 A	3	C
SH202T C8	2P	400 V~	8 A	3000 A	3000 A	3	C
SH202T D0,5	2P	400 V~	0,5 A	3000 A	3000 A	---	D
SH202T D1	2P	400 V~	1 A	3000 A	3000 A	---	D
SH202T D10	2P	400 V~	10 A	3000 A	3000 A	---	D
SH202T D13	2P	400 V~	13 A	3000 A	3000 A	---	D
SH202T D1,6	2P	400 V~	1,6 A	3000 A	3000 A	---	D
SH202T D16	2P	400 V~	16 A	3000 A	3000 A	---	D
SH202T D2	2P	400 V~	2 A	3000 A	3000 A	---	D
SH202T D20	2P	400 V~	20 A	3000 A	3000 A	---	D
SH202T D25	2P	400 V~	25 A	3000 A	3000 A	---	D
SH202T D3	2P	400 V~	3 A	3000 A	3000 A	---	D
SH202T D32	2P	400 V~	32 A	3000 A	3000 A	---	D
SH202T D4	2P	400 V~	4 A	3000 A	3000 A	---	D
SH202T D40	2P	400 V~	40 A	3000 A	3000 A	---	D
SH202T D50	2P	400 V~	50 A	3000 A	3000 A	---	D
SH202T D6	2P	400 V~	6 A	3000 A	3000 A	---	D

First issued on 2018-04-24
Validity date 2023-04-24

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Original Electronic Certificate

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH202T D63	2P	400 V~	63 A	3000 A	3000 A	---	D
SH202T D8	2P	400 V~	8 A	3000 A	3000 A	---	D
SH203 B10	3P	400 V~	10 A	6000 A	6000 A	3	B
SH203 B13	3P	400 V~	13 A	6000 A	6000 A	3	B
SH203 B16	3P	400 V~	16 A	6000 A	6000 A	3	B
SH203 B20	3P	400 V~	20 A	6000 A	6000 A	3	B
SH203 B25	3P	400 V~	25 A	6000 A	6000 A	3	B
SH203 B32	3P	400 V~	32 A	6000 A	6000 A	3	B
SH203 B40	3P	400 V~	40 A	6000 A	6000 A	3	B
SH203 B50	3P	400 V~	50 A	6000 A	6000 A	3	B
SH203 B6	3P	400 V~	6 A	6000 A	6000 A	3	B
SH203 B63	3P	400 V~	63 A	6000 A	6000 A	3	B
SH203 B8	3P	400 V~	8 A	6000 A	6000 A	3	B
SH203 C0,5	3P	400 V~	0,5 A	6000 A	6000 A	3	C
SH203 C1	3P	400 V~	1 A	6000 A	6000 A	3	C
SH203 C10	3P	400 V~	10 A	6000 A	6000 A	3	C
SH203 C13	3P	400 V~	13 A	6000 A	6000 A	3	C
SH203 C1,6	3P	400 V~	1,6 A	6000 A	6000 A	3	C
SH203 C16	3P	400 V~	16 A	6000 A	6000 A	3	C
SH203 C2	3P	400 V~	2 A	6000 A	6000 A	3	C
SH203 C20	3P	400 V~	20 A	6000 A	6000 A	3	C
SH203 C25	3P	400 V~	25 A	6000 A	6000 A	3	C
SH203 C3	3P	400 V~	3 A	6000 A	6000 A	3	C
SH203 C32	3P	400 V~	32 A	6000 A	6000 A	3	C
SH203 C4	3P	400 V~	4 A	6000 A	6000 A	3	C
SH203 C40	3P	400 V~	40 A	6000 A	6000 A	3	C
SH203 C50	3P	400 V~	50 A	6000 A	6000 A	3	C
SH203 C6	3P	400 V~	6 A	6000 A	6000 A	3	C
SH203 C63	3P	400 V~	63 A	6000 A	6000 A	3	C

First issued on 2018-04-24
Validity date 2023-04-24

Original Electronic Certificate

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH203 C8	3P	400 V~	8 A	6000 A	6000 A	3	C
SH203 D0,5	3P	400 V~	0,5 A	6000 A	6000 A	---	D
SH203 D1	3P	400 V~	1 A	6000 A	6000 A	---	D
SH203 D10	3P	400 V~	10 A	6000 A	6000 A	---	D
SH203 D13	3P	400 V~	13 A	6000 A	6000 A	---	D
SH203 D1,6	3P	400 V~	1,6 A	6000 A	6000 A	---	D
SH203 D16	3P	400 V~	16 A	6000 A	6000 A	---	D
SH203 D2	3P	400 V~	2 A	6000 A	6000 A	---	D
SH203 D20	3P	400 V~	20 A	6000 A	6000 A	---	D
SH203 D25	3P	400 V~	25 A	6000 A	6000 A	---	D
SH203 D3	3P	400 V~	3 A	6000 A	6000 A	---	D
SH203 D32	3P	400 V~	32 A	6000 A	6000 A	---	D
SH203 D4	3P	400 V~	4 A	6000 A	6000 A	---	D
SH203 D40	3P	400 V~	40 A	6000 A	6000 A	---	D
SH203 D50	3P	400 V~	50 A	6000 A	6000 A	---	D
SH203 D6	3P	400 V~	6 A	6000 A	6000 A	---	D
SH203 D63	3P	400 V~	63 A	6000 A	6000 A	---	D
SH203 D8	3P	400 V~	8 A	6000 A	6000 A	---	D
SH203L B10	3P	400 V~	10 A	4500 A	4500 A	3	B
SH203L B13	3P	400 V~	13 A	4500 A	4500 A	3	B
SH203L B16	3P	400 V~	16 A	4500 A	4500 A	3	B
SH203L B20	3P	400 V~	20 A	4500 A	4500 A	3	B
SH203L B25	3P	400 V~	25 A	4500 A	4500 A	3	B
SH203L B32	3P	400 V~	32 A	4500 A	4500 A	3	B
SH203L B40	3P	400 V~	40 A	4500 A	4500 A	3	B
SH203L B50	3P	400 V~	50 A	4500 A	4500 A	3	B
SH203L B6	3P	400 V~	6 A	4500 A	4500 A	3	B
SH203L B63	3P	400 V~	63 A	4500 A	4500 A	3	B
SH203L B8	3P	400 V~	8 A	4500 A	4500 A	3	B

First issued on 2018-04-24
Validity date 2023-04-24

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Original Electronic Certificate

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH203L C0,5	3P	400 V~	0,5 A	4500 A	4500 A	3	C
SH203L C1	3P	400 V~	1 A	4500 A	4500 A	3	C
SH203L C10	3P	400 V~	10 A	4500 A	4500 A	3	C
SH203L C13	3P	400 V~	13 A	4500 A	4500 A	3	C
SH203L C1,6	3P	400 V~	1,6 A	4500 A	4500 A	3	C
SH203L C16	3P	400 V~	16 A	4500 A	4500 A	3	C
SH203L C2	3P	400 V~	2 A	4500 A	4500 A	3	C
SH203L C20	3P	400 V~	20 A	4500 A	4500 A	3	C
SH203L C25	3P	400 V~	25 A	4500 A	4500 A	3	C
SH203L C3	3P	400 V~	3 A	4500 A	4500 A	3	C
SH203L C32	3P	400 V~	32 A	4500 A	4500 A	3	C
SH203L C4	3P	400 V~	4 A	4500 A	4500 A	3	C
SH203L C40	3P	400 V~	40 A	4500 A	4500 A	3	C
SH203L C50	3P	400 V~	50 A	4500 A	4500 A	3	C
SH203L C6	3P	400 V~	6 A	4500 A	4500 A	3	C
SH203L C63	3P	400 V~	63 A	4500 A	4500 A	3	C
SH203L C8	3P	400 V~	8 A	4500 A	4500 A	3	C
SH203L D0,5	3P	400 V~	0,5 A	4500 A	4500 A	---	D
SH203L D1	3P	400 V~	1 A	4500 A	4500 A	---	D
SH203L D10	3P	400 V~	10 A	4500 A	4500 A	---	D
SH203L D13	3P	400 V~	13 A	4500 A	4500 A	---	D
SH203L D1,6	3P	400 V~	1,6 A	4500 A	4500 A	---	D
SH203L D16	3P	400 V~	16 A	4500 A	4500 A	---	D
SH203L D2	3P	400 V~	2 A	4500 A	4500 A	---	D
SH203L D20	3P	400 V~	20 A	4500 A	4500 A	---	D
SH203L D25	3P	400 V~	25 A	4500 A	4500 A	---	D
SH203L D3	3P	400 V~	3 A	4500 A	4500 A	---	D
SH203L D32	3P	400 V~	32 A	4500 A	4500 A	---	D
SH203L D4	3P	400 V~	4 A	4500 A	4500 A	---	D

First issued on 2018-04-24
Validity date 2023-04-24

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Original Electronic Certificate

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH203L D40	3P	400 V~	40 A	4500 A	4500 A	---	D
SH203L D50	3P	400 V~	50 A	4500 A	4500 A	---	D
SH203L D6	3P	400 V~	6 A	4500 A	4500 A	---	D
SH203L D63	3P	400 V~	63 A	4500 A	4500 A	---	D
SH203L D8	3P	400 V~	8 A	4500 A	4500 A	---	D
SH203L-NA B10	3P+N	400 V~	10 A	4500 A	4500 A	3	B
SH203L-NA B13	3P+N	400 V~	13 A	4500 A	4500 A	3	B
SH203L-NA B16	3P+N	400 V~	16 A	4500 A	4500 A	3	B
SH203L-NA B20	3P+N	400 V~	20 A	4500 A	4500 A	3	B
SH203L-NA B25	3P+N	400 V~	25 A	4500 A	4500 A	3	B
SH203L-NA B32	3P+N	400 V~	32 A	4500 A	4500 A	3	B
SH203L-NA B40	3P+N	400 V~	40 A	4500 A	4500 A	3	B
SH203L-NA B50	3P+N	400 V~	50 A	4500 A	4500 A	3	B
SH203L-NA B6	3P+N	400 V~	6 A	4500 A	4500 A	3	B
SH203L-NA B63	3P+N	400 V~	63 A	4500 A	4500 A	3	B
SH203L-NA B8	3P+N	400 V~	8 A	4500 A	4500 A	3	B
SH203L-NA C0,5	3P+N	400 V~	0,5 A	4500 A	4500 A	3	C
SH203L-NA C1	3P+N	400 V~	1 A	4500 A	4500 A	3	C
SH203L-NA C10	3P+N	400 V~	10 A	4500 A	4500 A	3	C
SH203L-NA C13	3P+N	400 V~	13 A	4500 A	4500 A	3	C
SH203L-NA C1,6	3P+N	400 V~	1,6 A	4500 A	4500 A	3	C
SH203L-NA C16	3P+N	400 V~	16 A	4500 A	4500 A	3	C
SH203L-NA C2	3P+N	400 V~	2 A	4500 A	4500 A	3	C
SH203L-NA C20	3P+N	400 V~	20 A	4500 A	4500 A	3	C
SH203L-NA C25	3P+N	400 V~	25 A	4500 A	4500 A	3	C
SH203L-NA C3	3P+N	400 V~	3 A	4500 A	4500 A	3	C
SH203L-NA C32	3P+N	400 V~	32 A	4500 A	4500 A	3	C
SH203L-NA C4	3P+N	400 V~	4 A	4500 A	4500 A	3	C
SH203L-NA C40	3P+N	400 V~	40 A	4500 A	4500 A	3	C

First issued on 2018-04-24
Validity date 2023-04-24

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Original Electronic Certificate

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH203L-NA C50	3P+N	400 V~	50 A	4500 A	4500 A	3	C
SH203L-NA C6	3P+N	400 V~	6 A	4500 A	4500 A	3	C
SH203L-NA C63	3P+N	400 V~	63 A	4500 A	4500 A	3	C
SH203L-NA C8	3P+N	400 V~	8 A	4500 A	4500 A	3	C
SH203L-NA D0,5	3P+N	400 V~	0,5 A	4500 A	4500 A	---	D
SH203L-NA D1	3P+N	400 V~	1 A	4500 A	4500 A	---	D
SH203L-NA D10	3P+N	400 V~	10 A	4500 A	4500 A	---	D
SH203L-NA D13	3P+N	400 V~	13 A	4500 A	4500 A	---	D
SH203L-NA D1,6	3P+N	400 V~	1,6 A	4500 A	4500 A	---	D
SH203L-NA D16	3P+N	400 V~	16 A	4500 A	4500 A	---	D
SH203L-NA D2	3P+N	400 V~	2 A	4500 A	4500 A	---	D
SH203L-NA D20	3P+N	400 V~	20 A	4500 A	4500 A	---	D
SH203L-NA D25	3P+N	400 V~	25 A	4500 A	4500 A	---	D
SH203L-NA D3	3P+N	400 V~	3 A	4500 A	4500 A	---	D
SH203L-NA D32	3P+N	400 V~	32 A	4500 A	4500 A	---	D
SH203L-NA D4	3P+N	400 V~	4 A	4500 A	4500 A	---	D
SH203L-NA D40	3P+N	400 V~	40 A	4500 A	4500 A	---	D
SH203L-NA D50	3P+N	400 V~	50 A	4500 A	4500 A	---	D
SH203L-NA D6	3P+N	400 V~	6 A	4500 A	4500 A	---	D
SH203L-NA D63	3P+N	400 V~	63 A	4500 A	4500 A	---	D
SH203L-NA D8	3P+N	400 V~	8 A	4500 A	4500 A	---	D
SH203-NA B10	3P+N	400 V~	10 A	6000 A	6000 A	3	B
SH203-NA B13	3P+N	400 V~	13 A	6000 A	6000 A	3	B
SH203-NA B16	3P+N	400 V~	16 A	6000 A	6000 A	3	B
SH203-NA B20	3P+N	400 V~	20 A	6000 A	6000 A	3	B
SH203-NA B25	3P+N	400 V~	25 A	6000 A	6000 A	3	B
SH203-NA B32	3P+N	400 V~	32 A	6000 A	6000 A	3	B
SH203-NA B40	3P+N	400 V~	40 A	6000 A	6000 A	3	B
SH203-NA B50	3P+N	400 V~	50 A	6000 A	6000 A	3	B

First issued on 2018-04-24
Validity date 2023-04-24

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Original Electronic Certificate

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH203-NA B6	3P+N	400 V~	6 A	6000 A	6000 A	3	B
SH203-NA B63	3P+N	400 V~	63 A	6000 A	6000 A	3	B
SH203-NA B8	3P+N	400 V~	8 A	6000 A	6000 A	3	B
SH203-NA C0,5	3P+N	400 V~	0,5 A	6000 A	6000 A	3	C
SH203-NA C1	3P+N	400 V~	1 A	6000 A	6000 A	3	C
SH203-NA C10	3P+N	400 V~	10 A	6000 A	6000 A	3	C
SH203-NA C13	3P+N	400 V~	13 A	6000 A	6000 A	3	C
SH203-NA C1,6	3P+N	400 V~	1,6 A	6000 A	6000 A	3	C
SH203-NA C16	3P+N	400 V~	16 A	6000 A	6000 A	3	C
SH203-NA C2	3P+N	400 V~	2 A	6000 A	6000 A	3	C
SH203-NA C20	3P+N	400 V~	20 A	6000 A	6000 A	3	C
SH203-NA C25	3P+N	400 V~	25 A	6000 A	6000 A	3	C
SH203-NA C3	3P+N	400 V~	3 A	6000 A	6000 A	3	C
SH203-NA C32	3P+N	400 V~	32 A	6000 A	6000 A	3	C
SH203-NA C4	3P+N	400 V~	4 A	6000 A	6000 A	3	C
SH203-NA C40	3P+N	400 V~	40 A	6000 A	6000 A	3	C
SH203-NA C50	3P+N	400 V~	50 A	6000 A	6000 A	3	C
SH203-NA C6	3P+N	400 V~	6 A	6000 A	6000 A	3	C
SH203-NA C63	3P+N	400 V~	63 A	6000 A	6000 A	3	C
SH203-NA C8	3P+N	400 V~	8 A	6000 A	6000 A	3	C
SH203-NA D0,5	3P+N	400 V~	0,5 A	6000 A	6000 A	---	D
SH203-NA D1	3P+N	400 V~	1 A	6000 A	6000 A	---	D
SH203-NA D10	3P+N	400 V~	10 A	6000 A	6000 A	---	D
SH203-NA D13	3P+N	400 V~	13 A	6000 A	6000 A	---	D
SH203-NA D1,6	3P+N	400 V~	1,6 A	6000 A	6000 A	---	D
SH203-NA D16	3P+N	400 V~	16 A	6000 A	6000 A	---	D
SH203-NA D2	3P+N	400 V~	2 A	6000 A	6000 A	---	D
SH203-NA D20	3P+N	400 V~	20 A	6000 A	6000 A	---	D
SH203-NA D25	3P+N	400 V~	25 A	6000 A	6000 A	---	D

First issued on 2018-04-24
Validity date 2023-04-24

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Original Electronic Certificate

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH203-NA D3	3P+N	400 V~	3 A	6000 A	6000 A	---	D
SH203-NA D32	3P+N	400 V~	32 A	6000 A	6000 A	---	D
SH203-NA D4	3P+N	400 V~	4 A	6000 A	6000 A	---	D
SH203-NA D40	3P+N	400 V~	40 A	6000 A	6000 A	---	D
SH203-NA D50	3P+N	400 V~	50 A	6000 A	6000 A	---	D
SH203-NA D6	3P+N	400 V~	6 A	6000 A	6000 A	---	D
SH203-NA D63	3P+N	400 V~	63 A	6000 A	6000 A	---	D
SH203-NA D8	3P+N	400 V~	8 A	6000 A	6000 A	---	D
SH203-NAL C13	3P+N	400 V~	13 A	4500 A	4500 A	3	C
SH203T B10	3P	400 V~	10 A	3000 A	3000 A	3	B
SH203T B13	3P	400 V~	13 A	3000 A	3000 A	3	B
SH203T B16	3P	400 V~	16 A	3000 A	3000 A	3	B
SH203T B20	3P	400 V~	20 A	3000 A	3000 A	3	B
SH203T B25	3P	400 V~	25 A	3000 A	3000 A	3	B
SH203T B32	3P	400 V~	32 A	3000 A	3000 A	3	B
SH203T B40	3P	400 V~	40 A	3000 A	3000 A	3	B
SH203T B50	3P	400 V~	50 A	3000 A	3000 A	3	B
SH203T B6	3P	400 V~	6 A	3000 A	3000 A	3	B
SH203T B63	3P	400 V~	63 A	3000 A	3000 A	3	B
SH203T B8	3P	400 V~	8 A	3000 A	3000 A	3	B
SH203T C0,5	3P	400 V~	0,5 A	3000 A	3000 A	3	C
SH203T C1	3P	400 V~	1 A	3000 A	3000 A	3	C
SH203T C10	3P	400 V~	10 A	3000 A	3000 A	3	C
SH203T C13	3P	400 V~	13 A	3000 A	3000 A	3	C
SH203T C1,6	3P	400 V~	1,6 A	3000 A	3000 A	3	C
SH203T C16	3P	400 V~	16 A	3000 A	3000 A	3	C
SH203T C2	3P	400 V~	2 A	3000 A	3000 A	3	C
SH203T C20	3P	400 V~	20 A	3000 A	3000 A	3	C
SH203T C25	3P	400 V~	25 A	3000 A	3000 A	3	C

First issued on 2018-04-24
Validity date 2023-04-24

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Original Electronic Certificate

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH203T C3	3P	400 V~	3 A	3000 A	3000 A	3	C
SH203T C32	3P	400 V~	32 A	3000 A	3000 A	3	C
SH203T C4	3P	400 V~	4 A	3000 A	3000 A	3	C
SH203T C40	3P	400 V~	40 A	3000 A	3000 A	3	C
SH203T C50	3P	400 V~	50 A	3000 A	3000 A	3	C
SH203T C6	3P	400 V~	6 A	3000 A	3000 A	3	C
SH203T C63	3P	400 V~	63 A	3000 A	3000 A	3	C
SH203T C8	3P	400 V~	8 A	3000 A	3000 A	3	C
SH203T D0,5	3P	400 V~	0,5 A	3000 A	3000 A	---	D
SH203T D1	3P	400 V~	1 A	3000 A	3000 A	---	D
SH203T D10	3P	400 V~	10 A	3000 A	3000 A	---	D
SH203T D13	3P	400 V~	13 A	3000 A	3000 A	---	D
SH203T D1,6	3P	400 V~	1,6 A	3000 A	3000 A	---	D
SH203T D16	3P	400 V~	16 A	3000 A	3000 A	---	D
SH203T D2	3P	400 V~	2 A	3000 A	3000 A	---	D
SH203T D20	3P	400 V~	20 A	3000 A	3000 A	---	D
SH203T D25	3P	400 V~	25 A	3000 A	3000 A	---	D
SH203T D3	3P	400 V~	3 A	3000 A	3000 A	---	D
SH203T D32	3P	400 V~	32 A	3000 A	3000 A	---	D
SH203T D4	3P	400 V~	4 A	3000 A	3000 A	---	D
SH203T D40	3P	400 V~	40 A	3000 A	3000 A	---	D
SH203T D50	3P	400 V~	50 A	3000 A	3000 A	---	D
SH203T D6	3P	400 V~	6 A	3000 A	3000 A	---	D
SH203T D63	3P	400 V~	63 A	3000 A	3000 A	---	D
SH203T D8	3P	400 V~	8 A	3000 A	3000 A	---	D
SH203T-NA B10	3P+N	400 V~	10 A	3000 A	3000 A	3	B
SH203T-NA B13	3P+N	400 V~	13 A	3000 A	3000 A	3	B
SH203T-NA B16	3P+N	400 V~	16 A	3000 A	3000 A	3	B
SH203T-NA B20	3P+N	400 V~	20 A	3000 A	3000 A	3	B

First issued on 2018-04-24
Validity date 2023-04-24

Original Electronic Certificate

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH203T-NA B25	3P+N	400 V~	25 A	3000 A	3000 A	3	B
SH203T-NA B32	3P+N	400 V~	32 A	3000 A	3000 A	3	B
SH203T-NA B40	3P+N	400 V~	40 A	3000 A	3000 A	3	B
SH203T-NA B50	3P+N	400 V~	50 A	3000 A	3000 A	3	B
SH203T-NA B6	3P+N	400 V~	6 A	3000 A	3000 A	3	B
SH203T-NA B63	3P+N	400 V~	63 A	3000 A	3000 A	3	B
SH203T-NA B8	3P+N	400 V~	8 A	3000 A	3000 A	3	B
SH203T-NA C0,5	3P+N	400 V~	0,5 A	3000 A	3000 A	3	C
SH203T-NA C1	3P+N	400 V~	1 A	3000 A	3000 A	3	C
SH203T-NA C10	3P+N	400 V~	10 A	3000 A	3000 A	3	C
SH203T-NA C13	3P+N	400 V~	13 A	3000 A	3000 A	3	C
SH203T-NA C1,6	3P+N	400 V~	1,6 A	3000 A	3000 A	3	C
SH203T-NA C16	3P+N	400 V~	16 A	3000 A	3000 A	3	C
SH203T-NA C2	3P+N	400 V~	2 A	3000 A	3000 A	3	C
SH203T-NA C20	3P+N	400 V~	20 A	3000 A	3000 A	3	C
SH203T-NA C25	3P+N	400 V~	25 A	3000 A	3000 A	3	C
SH203T-NA C3	3P+N	400 V~	3 A	3000 A	3000 A	3	C
SH203T-NA C32	3P+N	400 V~	32 A	3000 A	3000 A	3	C
SH203T-NA C4	3P+N	400 V~	4 A	3000 A	3000 A	3	C
SH203T-NA C40	3P+N	400 V~	40 A	3000 A	3000 A	3	C
SH203T-NA C50	3P+N	400 V~	50 A	3000 A	3000 A	3	C
SH203T-NA C6	3P+N	400 V~	6 A	3000 A	3000 A	3	C
SH203T-NA C63	3P+N	400 V~	63 A	3000 A	3000 A	3	C
SH203T-NA C8	3P+N	400 V~	8 A	3000 A	3000 A	3	C
SH203T-NA D0,5	3P+N	400 V~	0,5 A	3000 A	3000 A	---	D
SH203T-NA D1	3P+N	400 V~	1 A	3000 A	3000 A	---	D
SH203T-NA D10	3P+N	400 V~	10 A	3000 A	3000 A	---	D
SH203T-NA D13	3P+N	400 V~	13 A	3000 A	3000 A	---	D
SH203T-NA D1,6	3P+N	400 V~	1,6 A	3000 A	3000 A	---	D

First issued on 2018-04-24
Validity date 2023-04-24

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Original Electronic Certificate

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH203T-NA D16	3P+N	400 V~	16 A	3000 A	3000 A	---	D
SH203T-NA D2	3P+N	400 V~	2 A	3000 A	3000 A	---	D
SH203T-NA D20	3P+N	400 V~	20 A	3000 A	3000 A	---	D
SH203T-NA D25	3P+N	400 V~	25 A	3000 A	3000 A	---	D
SH203T-NA D3	3P+N	400 V~	3 A	3000 A	3000 A	---	D
SH203T-NA D32	3P+N	400 V~	32 A	3000 A	3000 A	---	D
SH203T-NA D4	3P+N	400 V~	4 A	3000 A	3000 A	---	D
SH203T-NA D40	3P+N	400 V~	40 A	3000 A	3000 A	---	D
SH203T-NA D50	3P+N	400 V~	50 A	3000 A	3000 A	---	D
SH203T-NA D6	3P+N	400 V~	6 A	3000 A	3000 A	---	D
SH203T-NA D63	3P+N	400 V~	63 A	3000 A	3000 A	---	D
SH203T-NA D8	3P+N	400 V~	8 A	3000 A	3000 A	---	D
SH204 B10	4P	400 V~	10 A	6000 A	6000 A	3	B
SH204 B13	4P	400 V~	13 A	6000 A	6000 A	3	B
SH204 B16	4P	400 V~	16 A	6000 A	6000 A	3	B
SH204 B20	4P	400 V~	20 A	6000 A	6000 A	3	B
SH204 B25	4P	400 V~	25 A	6000 A	6000 A	3	B
SH204 B32	4P	400 V~	32 A	6000 A	6000 A	3	B
SH204 B40	4P	400 V~	40 A	6000 A	6000 A	3	B
SH204 B50	4P	400 V~	50 A	6000 A	6000 A	3	B
SH204 B6	4P	400 V~	6 A	6000 A	6000 A	3	B
SH204 B63	4P	400 V~	63 A	6000 A	6000 A	3	B
SH204 B8	4P	400 V~	8 A	6000 A	6000 A	3	B
SH204 C0,5	4P	400 V~	0,5 A	6000 A	6000 A	3	C
SH204 C1	4P	400 V~	1 A	6000 A	6000 A	3	C
SH204 C10	4P	400 V~	10 A	6000 A	6000 A	3	C
SH204 C13	4P	400 V~	13 A	6000 A	6000 A	3	C
SH204 C1,6	4P	400 V~	1,6 A	6000 A	6000 A	3	C
SH204 C16	4P	400 V~	16 A	6000 A	6000 A	3	C

First issued on 2018-04-24
Validity date 2023-04-24

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Original Electronic Certificate

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH204 C2	4P	400 V~	2 A	6000 A	6000 A	3	C
SH204 C20	4P	400 V~	20 A	6000 A	6000 A	3	C
SH204 C25	4P	400 V~	25 A	6000 A	6000 A	3	C
SH204 C3	4P	400 V~	3 A	6000 A	6000 A	3	C
SH204 C32	4P	400 V~	32 A	6000 A	6000 A	3	C
SH204 C4	4P	400 V~	4 A	6000 A	6000 A	3	C
SH204 C40	4P	400 V~	40 A	6000 A	6000 A	3	C
SH204 C50	4P	400 V~	50 A	6000 A	6000 A	3	C
SH204 C6	4P	400 V~	6 A	6000 A	6000 A	3	C
SH204 C63	4P	400 V~	63 A	6000 A	6000 A	3	C
SH204 C8	4P	400 V~	8 A	6000 A	6000 A	3	C
SH204 D0,5	4P	400 V~	0,5 A	6000 A	6000 A	---	D
SH204 D1	4P	400 V~	1 A	6000 A	6000 A	---	D
SH204 D10	4P	400 V~	10 A	6000 A	6000 A	---	D
SH204 D13	4P	400 V~	13 A	6000 A	6000 A	---	D
SH204 D1,6	4P	400 V~	1,6 A	6000 A	6000 A	---	D
SH204 D16	4P	400 V~	16 A	6000 A	6000 A	---	D
SH204 D2	4P	400 V~	2 A	6000 A	6000 A	---	D
SH204 D20	4P	400 V~	20 A	6000 A	6000 A	---	D
SH204 D25	4P	400 V~	25 A	6000 A	6000 A	---	D
SH204 D3	4P	400 V~	3 A	6000 A	6000 A	---	D
SH204 D32	4P	400 V~	32 A	6000 A	6000 A	---	D
SH204 D4	4P	400 V~	4 A	6000 A	6000 A	---	D
SH204 D40	4P	400 V~	40 A	6000 A	6000 A	---	D
SH204 D50	4P	400 V~	50 A	6000 A	6000 A	---	D
SH204 D6	4P	400 V~	6 A	6000 A	6000 A	---	D
SH204 D63	4P	400 V~	63 A	6000 A	6000 A	---	D
SH204 D8	4P	400 V~	8 A	6000 A	6000 A	---	D
SH204L B10	4P	400 V~	10 A	4500 A	4500 A	3	B

First issued on 2018-04-24
Validity date 2023-04-24

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Original Electronic Certificate

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH204L B13	4P	400 V~	13 A	4500 A	4500 A	3	B
SH204L B16	4P	400 V~	16 A	4500 A	4500 A	3	B
SH204L B20	4P	400 V~	20 A	4500 A	4500 A	3	B
SH204L B25	4P	400 V~	25 A	4500 A	4500 A	3	B
SH204L B32	4P	400 V~	32 A	4500 A	4500 A	3	B
SH204L B40	4P	400 V~	40 A	4500 A	4500 A	3	B
SH204L B50	4P	400 V~	50 A	4500 A	4500 A	3	B
SH204L B6	4P	400 V~	6 A	4500 A	4500 A	3	B
SH204L B63	4P	400 V~	63 A	4500 A	4500 A	3	B
SH204L B8	4P	400 V~	8 A	4500 A	4500 A	3	B
SH204L C0,5	4P	400 V~	0,5 A	4500 A	4500 A	3	C
SH204L C1	4P	400 V~	1 A	4500 A	4500 A	3	C
SH204L C10	4P	400 V~	10 A	4500 A	4500 A	3	C
SH204L C13	4P	400 V~	13 A	4500 A	4500 A	3	C
SH204L C1,6	4P	400 V~	1,6 A	4500 A	4500 A	3	C
SH204L C16	4P	400 V~	16 A	4500 A	4500 A	3	C
SH204L C2	4P	400 V~	2 A	4500 A	4500 A	3	C
SH204L C20	4P	400 V~	20 A	4500 A	4500 A	3	C
SH204L C25	4P	400 V~	25 A	4500 A	4500 A	3	C
SH204L C3	4P	400 V~	3 A	4500 A	4500 A	3	C
SH204L C32	4P	400 V~	32 A	4500 A	4500 A	3	C
SH204L C4	4P	400 V~	4 A	4500 A	4500 A	3	C
SH204L C40	4P	400 V~	40 A	4500 A	4500 A	3	C
SH204L C50	4P	400 V~	50 A	4500 A	4500 A	3	C
SH204L C6	4P	400 V~	6 A	4500 A	4500 A	3	C
SH204L C63	4P	400 V~	63 A	4500 A	4500 A	3	C
SH204L C8	4P	400 V~	8 A	4500 A	4500 A	3	C
SH204L D0,5	4P	400 V~	0,5 A	4500 A	4500 A	---	D
SH204L D1	4P	400 V~	1 A	4500 A	4500 A	---	D

First issued on 2018-04-24
Validity date 2023-04-24

Original Electronic Certificate

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH204L D10	4P	400 V~	10 A	4500 A	4500 A	---	D
SH204L D13	4P	400 V~	13 A	4500 A	4500 A	---	D
SH204L D1,6	4P	400 V~	1,6 A	4500 A	4500 A	---	D
SH204L D16	4P	400 V~	16 A	4500 A	4500 A	---	D
SH204L D2	4P	400 V~	2 A	4500 A	4500 A	---	D
SH204L D20	4P	400 V~	20 A	4500 A	4500 A	---	D
SH204L D25	4P	400 V~	25 A	4500 A	4500 A	---	D
SH204L D3	4P	400 V~	3 A	4500 A	4500 A	---	D
SH204L D32	4P	400 V~	32 A	4500 A	4500 A	---	D
SH204L D4	4P	400 V~	4 A	4500 A	4500 A	---	D
SH204L D40	4P	400 V~	40 A	4500 A	4500 A	---	D
SH204L D50	4P	400 V~	50 A	4500 A	4500 A	---	D
SH204L D6	4P	400 V~	6 A	4500 A	4500 A	---	D
SH204L D63	4P	400 V~	63 A	4500 A	4500 A	---	D
SH204L D8	4P	400 V~	8 A	4500 A	4500 A	---	D
SH204T B10	4P	400 V~	10 A	3000 A	3000 A	3	B
SH204T B13	4P	400 V~	13 A	3000 A	3000 A	3	B
SH204T B16	4P	400 V~	16 A	3000 A	3000 A	3	B
SH204T B20	4P	400 V~	20 A	3000 A	3000 A	3	B
SH204T B25	4P	400 V~	25 A	3000 A	3000 A	3	B
SH204T B32	4P	400 V~	32 A	3000 A	3000 A	3	B
SH204T B40	4P	400 V~	40 A	3000 A	3000 A	3	B
SH204T B50	4P	400 V~	50 A	3000 A	3000 A	3	B
SH204T B6	4P	400 V~	6 A	3000 A	3000 A	3	B
SH204T B63	4P	400 V~	63 A	3000 A	3000 A	3	B
SH204T B8	4P	400 V~	8 A	3000 A	3000 A	3	B
SH204T C0,5	4P	400 V~	0,5 A	3000 A	3000 A	3	C
SH204T C1	4P	400 V~	1 A	3000 A	3000 A	3	C
SH204T C10	4P	400 V~	10 A	3000 A	3000 A	3	C

First issued on 2018-04-24
Validity date 2023-04-24

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Original Electronic Certificate

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH204T C13	4P	400 V~	13 A	3000 A	3000 A	3	C
SH204T C1,6	4P	400 V~	1,6 A	3000 A	3000 A	3	C
SH204T C16	4P	400 V~	16 A	3000 A	3000 A	3	C
SH204T C2	4P	400 V~	2 A	3000 A	3000 A	3	C
SH204T C20	4P	400 V~	20 A	3000 A	3000 A	3	C
SH204T C25	4P	400 V~	25 A	3000 A	3000 A	3	C
SH204T C3	4P	400 V~	3 A	3000 A	3000 A	3	C
SH204T C32	4P	400 V~	32 A	3000 A	3000 A	3	C
SH204T C4	4P	400 V~	4 A	3000 A	3000 A	3	C
SH204T C40	4P	400 V~	40 A	3000 A	3000 A	3	C
SH204T C50	4P	400 V~	50 A	3000 A	3000 A	3	C
SH204T C6	4P	400 V~	6 A	3000 A	3000 A	3	C
SH204T C63	4P	400 V~	63 A	3000 A	3000 A	3	C
SH204T C8	4P	400 V~	8 A	3000 A	3000 A	3	C
SH204T D0,5	4P	400 V~	0,5 A	3000 A	3000 A	---	D
SH204T D1	4P	400 V~	1 A	3000 A	3000 A	---	D
SH204T D10	4P	400 V~	10 A	3000 A	3000 A	---	D
SH204T D13	4P	400 V~	13 A	3000 A	3000 A	---	D
SH204T D1,6	4P	400 V~	1,6 A	3000 A	3000 A	---	D
SH204T D16	4P	400 V~	16 A	3000 A	3000 A	---	D
SH204T D2	4P	400 V~	2 A	3000 A	3000 A	---	D
SH204T D20	4P	400 V~	20 A	3000 A	3000 A	---	D
SH204T D25	4P	400 V~	25 A	3000 A	3000 A	---	D
SH204T D3	4P	400 V~	3 A	3000 A	3000 A	---	D
SH204T D32	4P	400 V~	32 A	3000 A	3000 A	---	D
SH204T D4	4P	400 V~	4 A	3000 A	3000 A	---	D
SH204T D40	4P	400 V~	40 A	3000 A	3000 A	---	D
SH204T D50	4P	400 V~	50 A	3000 A	3000 A	---	D
SH204T D6	4P	400 V~	6 A	3000 A	3000 A	---	D

First issued on 2018-04-24
Validity date 2023-04-24

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Original Electronic Certificate

AENOR

AENOR Product Certificate
Low Voltage Material

030/002467

Annex to Certificate

Type Ref.	No. of poles	Rated voltage	Rated current	Short circuit capacity	Individual pole capacity	Energy limiting class	Tripping current
SH204T D63	4P	400 V~	63 A	3000 A	3000 A	---	D
SH204T D8	4P	400 V~	8 A	3000 A	3000 A	---	D

First issued on 2018-04-24
Validity date 2023-04-24

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

Original Electronic Certificate