

접 수 번 호 : 13-023819-01
(Receipt No.)



전 기 용 품 안 전 인 증 서

Electrical Appliances Safety Certificate

안 전 인 증 번 호 : SU05043-13001
(Certificate No.)

제 조 업 자 명 : ABB LV Installation Materials Co.,Ltd Beijing
(Factory)

대 표 자 명 : Zhongdan Wang
(President)

제 조 공 장 의 : No. 17, Kangding Street Beijing Economic-Techn.Developm.
소 재 지 : Area, Beijing, P.R.China
(Factory Address)

제 품 명 : 배선용차단기
(Product) (Circuit-Breaker)

기 본 모 델 명 : SH201 B13
(Basic Model)

정 격 : 220/380 V 13 A 1P 6 kA
(Rating)

파 생 모 델 명 : See the attachment 2
(Series Model)

적 용 기 준 : K60898-1(2008-12)
(Standard)

「전기용품안전 관리법 시행규칙」 제6조제2항에 따라 위의 전기용품에 대하여 안전인증
서를 발급합니다.

We Issue Electrical Appliances Safety Certification as above product by Article 6 Section 2 of the Electrical Appliances Safety Control Law Enforcement Regulation.

2013년 08월 09일



한국산업기술시험원장
KOREA TESTING LABORATORY



※ 이 인증서는 「전기용품안전 관리법」에 따른 전기용품 안전성 확인에 한정된 것이며, 그 밖의 다른
법률이 적용되는 제품의 경우에는 해당 법률에 따라 추가로 인증·허가 등을 받아야 합니다.

첨 부 :
(Annex)

1. 안전관리부품 및 재질목록 (List of Critical Components)
2. 기본모델·파생모델의 내용 (General Descriptions of Certified Products)
3. 전기용품안전인증의 변경 현황 (Status of Certificate Revisions)

□ 첨부 2 : 기본모델 · 파생모델의 내용
General description of Certified Products

파생모델명 Derivative model	기본모델과의 차이점 Differences between the basic and derivative model(s)
SH201 B6	Only current different
SH201 B8	Only current different
SH201 B10	Only current different
SH201 C0.5	Current different and Curve is C
SH201 C1	Current different and Curve is C
SH201 C1.6	Current different and Curve is C
SH201 C2	Current different and Curve is C
SH201 C3	Current different and Curve is C
SH201 C4	Current different and Curve is C
SH201 C6	Current different and Curve is C
SH201 C8	Current different and Curve is C
SH201 C10	Current different and Curve is C
SH201 C13	Curve is C
SH201 D0.5	Current different and Curve is D
SH201 D1	Current different and Curve is D
SH201 D1.6	Current different and Curve is D
SH201 D2	Current different and Curve is D
SH201 D3	Current different and Curve is D
SH201 D4	Current different and Curve is D
SH201 D6	Current different and Curve is D
SH201 D8	Current different and Curve is D
SH201 D10	Current different and Curve is D
SH201 D13	Curve is D
SH201-NA B6	Only current different and poles 1+N 220(230) V
SH201-NA B8	Only current different and poles 1+N 220(230) V
SH201-NA B10	Only current different and poles 1+N 220(230) V
SH201-NA B13	Poles 1+N 220(230) V
SH201-NA C0.5	Current different poles 1+N 220(230) V and Curve is C
SH201-NA C1	Current different poles 1+N 220(230) V and Curve is C
SH201-NA C1.6	Current different poles 1+N 220(230) V and Curve is C
SH201-NA C2	Current different poles 1+N 220(230) V and Curve is C

파생모델명 Derivative model	기본모델과의 차이점 Differences between the basic and derivative model(s)
SH201-NA C3	Current different poles 1+N 220(230) V and Curve is C
SH201-NA C4	Current different poles 1+N 220(230) V and Curve is C
SH201-NA C6	Current different poles 1+N 220(230) V and Curve is C
SH201-NA C8	Current different poles 1+N 220(230) V and Curve is C
SH201-NA C10	Current different poles 1+N 220(230) V and Curve is C
SH201-NA C13	Poles 1+N 220(230) V and Curve is C
SH201-NA D0.5	Current different poles 1+N 220(230) V and Curve is D
SH201-NA D1	Current different poles 1+N 220(230) V and Curve is D
SH201-NA D1.6	Current different poles 1+N 220(230) V and Curve is D
SH201-NA D2	Current different poles 1+N 220(230) V and Curve is D
SH201-NA D3	Current different poles 1+N 220(230) V and Curve is D
SH201-NA D4	Current different poles 1+N 220(230) V and Curve is D
SH201-NA D6	Current different poles 1+N 220(230) V and Curve is D
SH201-NA D8	Current different poles 1+N 220(230) V and Curve is D
SH201-NA D10	Current different poles 1+N 220(230) V and Curve is D
SH201-NA D13	Poles 1+N 220(230) V and Curve is D
제품특기사항 및 시험조건 Remarks & Test conditions	
<p>1. Test Report Ref. No. : 13-023819-01 (2013.06.25.)</p> <p>2. Product Description</p> <p>- circuit breaker</p>	
<p>□ 본 제품의 시험내용에 관하여 문의하실 사항이 있으시면 아래 연락처로 문의하시기 바랍니다. 시험담당자: 전기전자본부 광융합/부품평가센터 박갑수 / (02)860-1427</p> <p>□ If you have any question on product testing, please contact the person below: Job holder : Electrical and Electronic Division Lighting Appliance & Electrical Testing Center, G.S., Park/ +82 2 860-1427</p>	

☐ 첨부 3 : 전기용품안전인증의 변경 현황
Status of Certificate Revisions

변경발급 내용 Contents of Certificate Revisions
Not applicable

FP511-11-00