Ref. Certif. No.

DE1-58240

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Circuit-breaker
Name and address of the applicant	ABB-Stotz-Kontakt GmbH Eppelheimer Straße 82, 69123 Heidelberg GERMANY
Name and address of the manufacturer	ABB-Stotz-Kontakt GmbH Eppelheimer Straße 82, 69123 Heidelberg GERMANY
Name and address of the factory *Note: When more than one factory, please report on page 2*	ABB Bulgaria EOOD - Rakovski Branch - Industrial Zone Rakovski Municipality, 4150 RAKOVSKI BULGARIA ☐ Additional Information on page 2
Ratings and principal characteristics	AC 230/400 V; B 6 - 63 A; C/D 0,5 - 63 A Number of poles: 1;2;3;4; 1+N; 3+N; Icn: 10 kA
Trademark (if any)	ABB
Customer's Testing Facility (CTF) Stage used	CTF Stage 2
Model / Type Ref.	Serie SH20.M
Additional information (if necessary may also be reported on page 2)	☐ Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60898-1:2015
As shown in the Test Report Ref. No. which forms part of this Certificate	233981-CC2-000 to 233981-CC2-069

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE *Testing and Certification Institute*
Zertifizierung Produkte / *Certification Products*

Date: 2017-11-10

Signature:

R. Nickel