



Certificate of Compliance

Certificate: 2649433

Master Contract: 183691 (098793_0_000)

Project: 70155421

Date Issued: 2017-09-22

Issued to: ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82
Heidelberg, Baden-Württemberg 69123
GERMANY
Attention: Lillian Cheng Zhang

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C', 'US' and ▲



Issued by: *Ramana Tangirala*
Ramana Tangirala

PRODUCTS

CLASS - C321530 - SUPPLEMENTARY PROTECTORS-COMPONENT ACCEPTANCE PROGRAM

CLASS - C321590 - SUPPLEMENTARY PROTECTORS-Component Acceptance-Certified to U.S. Standards

ACCESSORIES FOR SUPPLEMENTARY PROTECTORS:

Following accessories are accepted for use in conjunction with ABB Stotz-Kontakt GmbH “Supplementary Protectors” as listed under Master Contact #183691/LR 98793 (Series S20x, S20xP, S20xM, S20xMxxUC, S20xPR and RP20xM).

PART-A: Auxillary Contacts:

- **Model S2C-H6R and S2C-S/H6R**, rated 1A, 480V ac; 2A, 277V ac; 1.5A, 125V dc; 2A, 60V dc and 4A, 24V dc.
- **Model S2C-H01 and S2C-H10**, rated 2A, 230V ac; Pilot Duty (Normal 2A, 230V ac, Inrush: 12A, 230Vac); 2A, 30Vdc; 1A, 50V dc and Pilot Duty (2A, 30V dc and 1A, 50V dc).
- **Model S2C-H6-11R, S2C-H6-20R and S2C-H6-02R**, rated 1A, 400V ac; 2A, 230V ac; 1A, 50V dc and 2A, 30V dc.
- **Model S2C-H11R, S2C-H20R and S2C-H02R**, rated 1A, 400V ac; 2A, 230V ac; 1A, 220V dc; 1.5A, 110V dc, 2A, 60V dc and 4A, 24V dc.



Certificate: 2649433
Project: 70155421

Master Contract: 183691
Date Issued: 2017-09-22

PART –B: Shunt Trip:

- **Model S2C-A1**, 12-60V ac/dc
- **Model S2C-A2**, 110-415V ac and 110-250V dc.

PART -C: BUS:

- **KS2/56, KS2/12 and VB45.32**

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 235 - Supplementary Protectors
UL1077 - Supplementary Protectors for Use in Electrical Equipment