



Certificate of Compliance

Certificate: 1530107 (LR 98793)

Master Contract: 183691

Project: 2629473

Date Issued: October 3, 2013

Issued to: ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82
Heidelberg, Baden-Wurttemberg 69123
Germany
Attention: Mr. Eric Englert

*The products listed below are eligible to bear
the CSA Mark shown with adjacent indicator*



Ramana Tangirala

Issued by: Ramana Tangirala, P.Eng.

PRODUCTS

CLASS 3215 30 - SUPPLEMENTARY PROTECTORS - COMPONENT ACCEPTANCE PROGRAM

PART -A:

- **Series S200, Model "S20x" followed by suffixes**, Supplementary Protectors, General Industrial, manual reset, thermo-magnetic trip units; 0.5 to 63A, 1 to 4 pole, Tripping Characteristic: B, C, D, K or Z.

Current Ratings: S20x -B: 6 to 63A; S20x -C, D, K and Z: 0.5 to 63A

Voltage Ratings: 1 pole: 277V ac max and 60V dc max; Multi-pole: 480V ac max and 125V dc max(3 phase or 2 pole breaking minimum)

Application Codes: TC2, OL0, SC: U1, 6kA, 277V ac(1 pole); U1, 6kA, 480V ac (multipole); U1, 10kA, 120V ac or 60V dc (1 pole) and U1, 10kA, 240V ac or 125V dc (multipole)

PART-B:

Accessories:



Certificate: 1530107 (LR 98793)

Master Contract: 183691

Project: 2629473

Date Issued: October 3, 2013

Accessories (Auxiliary Switches, Shunt trip and Busbars) evaluated in conjunction with “Series S20x”
Supplementary Protectors are covered under Report #2649433.

Notes:

1. Open type devices are Accepted as components for use in assemblies where the suitability of the combination is to be determined by the CSA International.
2. These are intended for rail mounting.
3. The terminals are suitable for factory wiring.
4. These devices are not suitable for branch circuit protection.
5. Short circuit tests were conducted without series fuse.
6. These devices may or may not be provided with auxiliary switches/shunt trip.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 235 - Supplementary Protectors