



Certificate of Compliance

Certificate: 2530541 **Master Contract:** 183691 (098793_0_000)
Project: 70134033 **Date Issued:** 2017-05-09
Issued to: ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82
Heidelberg, Baden-Württemberg 69123
GERMANY
Attention: Lillian Cheng Zhang

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C', 'US' and ▲



Issued by: Ramana Tangirala
Ramana Tangirala

PRODUCTS

CLASS - C321530 - SUPPLEMENTARY PROTECTORS-COMPONENT ACCEPTANCE PROGRAM

CLASS - C321590 - SUPPLEMENTARY PROTECTORS-Component Acceptance-Certified to U.S. Standards

PART -A:

- **Series S200, Model “S20xM” followed by suffixes**, Supplementary Protectors, General Industrial, manual reset, thermo-magnetic trip units; 0.5 to 63A, 1 to 4 pole, Tripping Characteristic: B, C, D, K or Z.
Current Ratings: S20x -B: 1 to 63A; S20x -C, D, K and Z: 0.5 to 63A
Voltage Ratings: 1 pole: 277V ac max and 60V dc max; Multi-pole: 480V ac max and 125V dc max(3 phase or 2 pole breaking minimum)
Application Codes: TC2, OL0, SC: U1, 6kA, 277V ac(1 pole); U1, 6kA, 480V ac (multipole); U1, 10kA, 120V ac or 60V dc (1 pole) and U1, 10kA, 240V ac or 125V dc (multipole)

PART B:

Accessories:

Accessories (Auxiliary Switches, Shunt trip and Busbars) evaluated in conjunction with “Series S20xM” Supplementary Protectors are covered under Report #2649433.



Certificate: 2530541
Project: 70134033

Master Contract: 183691
Date Issued: 2017-05-09

Notes:

1. Open type devices are Accepted as components for use in assemblies where the suitability of the combination is to be determined by the CSA Group.
2. These are intended for rail mounting.
3. 1 and 2 pole unit terminals are suitable for field wiring and 3 and 4 pole units terminals are suitable for factory wiring.
4. These devices are not suitable for branch circuit protection.
5. Short circuit tests were conducted without series fuse.
6. These devices may or may not be provided with auxiliary switches/shunt trip.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 235 - Supplementary Protectors

UL1077 - Supplementary Protectors for Use in Electrical Equipment