



Certificate of Compliance

Certificate: 1546332 **Master Contract:** 183691 (098793_0_000)
Project: 70218821 **Date Issued:** 2019-03-20
Issued to: ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82
Heidelberg, Baden-Württemberg 69123
GERMANY
Attention: Lilian Cheng Zhang

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Ramana Tangirala*
Ramana Tangirala

PRODUCTS

CLASS - C143201 - CIRCUIT BREAKERS-Moulded Case Type
CLASS - C143701 - CIRCUIT BREAKERS-Accessories

PART -A:

- **Series S200, Model S20xU followed by suffixes**, 0.2A to 63A, 1 to 4 poles, Common-Trip, 25C Uncompensated, 1 to 4 poles rated 240V ac; Tripping Characteristic: K or Z or C, HIC 10kA, 240V ac.

PART-B:

- **Series S200, Model S20xUP followed by suffixes**, 0.2A to 25A, 1 to 4 poles, Common-Trip, 25C Uncompensated, 1-pole rated 277V ac, 2 to 4 poles rated 277/480V ac, Tripping Characteristic: K or Z or C, IR 10kA.

PART-C:

- **Series S200, Model S20xUDC followed by suffixes**, 1 pole, 1A to 63A, 60V dc and 1A to 40A, 125 Vdc, 25C Uncompensated, Tripping Characteristic: K or Z, HIC 14kA at 60V dc and 125 Vdc.
- **Series S200, Model S20xUDC followed by suffixes**, 2 pole, 1A to 63A, 125V dc and 1A to 40A 250 Vdc (2 pole break), Common-Trip, 25C Uncompensated, Tripping Characteristic: K or Z or C, HIC 14kA at 125V dc and 250 Vdc (2 pole break).



Certificate: 1546332
Project: 70218821

Master Contract: 183691
Date Issued: 2019-03-20

CLASS 1437 01 - CIRCUIT BREAKERS - Accessories

PART-D:

- Breaker Accessories for Models S20xU/S20xUP/S20XUDC:
 - Auxiliary Contact **S2C-H6RU** and Alarm (Signal) contact **S2C-S6RU** with ratings - 1A, 480V ac; 2A, 277V ac; 1.5A, 125V dc, 2A, 60V dc and 4A, 24V dc;
 - Shunt Trip, **S2C-A1U**, 12-60V ac/dc; **S2C-A2U**, 110-415V ac and 110-250V dc.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and
Circuit-Breaker Enclosures.