



Certificate of Compliance

Certificate: 2709392 (098793_0_000)

Master Contract: 183691

Project: 70078169

Date Issued: 2016-06-09

Issued to: ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82
Heidelberg, Baden-Württemberg 69123
GERMANY
Attention: Cheng Zhang

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Ramana
Tangirala*
Ramana Tangirala

PRODUCTS

CLASS - C143201 - CIRCUIT BREAKERS-Moulded Case Type

CLASS - C143701 - CIRCUIT BREAKERS-Accessories

PART -A:

- **Model “SU20x PR” or Model “SU200xMR” followed by suffixes**, 0.2A to 63A, 1 to 4 poles, Common-Trip, 40°C Uncompensated, 1 to 4 poles rated 480V ac max; Tripping Characteristic: K, HIC 10kA, 240V ac. 48V dc (Single Pole), 96V dc (2 Pole) - 10kA;

Current and Voltage Ratings:

Characteristic K:

0.2A to 35A, 277V ac (one pole) and 480Y/277V ac (multi-pole);

0.2A to 63A, 240V ac (one pole) and 240V ac (multi-pole);

0,2A to 63A, 48Vdc (single pole)

0,2A to 63A, 96Vdc (minimum two pole)

SWD and HACR Type: 15A and 20A, 277V ac max.

PART-B:



Certificate: 2709392
Project: 70078169

Master Contract: 183691
Date Issued: 2016-06-09

Breaker Accessories for **Models SU20x PR or SU200xMR:**

- Auxiliary Contact **S2C-H6RU** and Alarm (Signal) contact **S2C-S6RU** with ratings - 1A, 480V ac; 2A, 277V ac; 1.5A, 125V dc, 2A, 60V dc and 4A, 24V dc;
- Shunt Trip, **S2C-A1U**, 12-60V ac/dc; **S2C-A2U**, 110-415V ac and 110-250V dc.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures