



中国国家强制性产品认证证书

证书编号: 2015010307775087

委托人名称、地址

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

生产者(制造商)名称、地址

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

生产企业名称、地址

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

产品名称和系列、规格、型号

塑料外壳式断路器

S201MTUC, S202MTUC, S203MTUC, S204MTUC; 详见型号解释

产品标准和技术要求

GB 14048.2-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2015年05月20日

有效期至: 2020年05月20日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1144174



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2015010307775087

NAME AND ADDRESS OF THE APPLICANT

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND ADDRESS OF THE MANUFACTURER

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND ADDRESS OF THE FACTORY

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME, MODEL AND SPECIFICATION

Moulded Case Circuit-breaker

S201MTUC, S202MTUC, S203MTUC, S204MTUC; See the appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.2-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification (REF NO. CNCA-C03-02:2014).

Date of issue: May.20,2015

Date of expiry: May.20,2020

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1144174



中国国家强制性产品认证证书

附录:

第 1 页 共 3 页

证书编号: 2015010307775087

纸号: 1144174

S201MTUC, S202MTUC, S203MTUC, S204MTUC

Ui: 440V;

Ue: AC253V/DC110V/220V (1P), AC440V/DC220V/440V (2P, 3P, 4P);

In: B: 6A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A;

C: 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A;

Z: 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A;

K: 0.2A, 0.3A, 0.5A, 0.75A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A;

Ics:

7.5kA (AC253V, 1P, In: $\leq 40A$); 6kA (AC253V, 1P; In: 50, 63A);

7.5kA (AC440V, 2P, 3P, 4P, In: $\leq 40A$); 6kA (AC440V, 2P, 3P, 4P, In: 50, 63A);

10kA (DC110V, 1P 外形); 10kA (DC220V, 1P 外形); 20kA (DC220V, 2P 外形, 3P 外形, 4P 外形);

10kA (DC440V, 2P 外形, 3P 外形, 4P 外形);

Icu:

10kA (AC253V, 1P, In: $\leq 40A$); 6kA (AC253V, 1P; In: 50, 63A);

10kA (AC440V, 2P, 3P, 4P, In: $\leq 40A$); 6kA (AC440V, 2P, 3P, 4P, In: 50, 63A);

20kA (DC110V, 1P); 10kA (DC220V, 1P); 25kA (DC220V, 2P 外形, 3P 外形, 4P 外形);

10kA (DC440V, 2P 外形, 3P 外形, 4P 外形);

使用类别: A; 过电流脱扣器类型: 热磁式;

极数: 1P, 2P, 3P, 4P;

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 3 页

证书编号: 2015010307775087

纸号: 1144174


型号的解释:

$\frac{S20}{1}$ $\frac{2}{2}$ $\frac{MT}{1}$ $\frac{B}{3}$ $\frac{16A}{4}$ $\frac{UC}{5}$

- 1 — Product type
- 2 — Number of protection pole 1-1pole, 2-2pole, 3-3pole, 4-4pole
- 3 — Tripping characteristic B-B Cha.; C-C Cha.; K-K Cha.; Z-Z Cha.
- 4 — Rated current
B: 6A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A;
C/Z: 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A
K: 0.2A, 0.3A, 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A
- 5 — UC: Applicable both AC/DC

直流接线图如下:

a. S20...MTUC 2P 产品在直流系统中应用的接线示意图



注: 此附录与证书同时使用时有效。



主 任:

(Signature)

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书


附录:

第 3 页 共 3 页


证书编号: 2015010307775087

纸号: 1144174


b. S20.MT UC 3P 产品在直流系统中应用的接线示意图




c. S20.MT UC 4P 产品在直流系统中应用的接线示意图



第一种接线方式 A



第二种接线方式 B



第三种接线方式 C

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

