



中国国家强制性产品认证证书

证书编号: 2014010307688142

委托人名称、地址

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg, Germany

生产者(制造商)名称、地址

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg, Germany

生产企业名称、地址

ABB Bulgaria EOOD - Rakovski branch
Industrial Zone, Plovdiv District, Rakovski Municipality, 4150 RAKOVSKI,
BULGARIA

产品名称和系列、规格、型号

塑料外壳式断路器

S201M, S201M-NA, S202M, S203M, S203M-NA, S204M; 详见参数附件

产品标准和技术要求

GB 14048.2-2008

上述产品符合强制性产品认证实施规则
CNCA-01C-011: 2007的要求, 特发此证。

发证日期: 2014年05月28日

有效期至: 2019年04月18日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2014年04月18日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 0925732



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010307688142

NAME AND ADDRESS OF THE APPLICANT

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg, Germany

NAME AND ADDRESS OF THE MANUFACTURER

ABB STOTZ-KONTAKT GmbH
Eppelheimer Strasse 82 69123 Heidelberg, Germany

NAME AND ADDRESS OF THE FACTORY

ABB Bulgaria EOOD – Rakovski branch
Industrial Zone, Plovdiv District, Rakovski Municipality, 4150 RAKOVSKI,
BULGARIA

NAME, MODEL AND SPECIFICATION

Moulded Case Circuit-breaker

S201M, S201M-NA, S202M, S203M, S203M-NA, S204M; See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.2-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification (REF NO. CNCA-01C-011:2007).

Date of issue: May. 28, 2014 Date of expiry: Apr. 18, 2019

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Apr. 18, 2014

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>



Q 0925732



中国国家强制性产品认证证书

附录:

第 1 页 共 2 页

证书编号: 2014010307688142

纸号: 925732

S201M, S201M-NA, S202M, S203M, S203M-NA, S204M

Ui: 440V;

Ue: AC133/230V(1P, 2P(1个保护极, N极可开闭)),

AC230/400/440V(2P, 3P, 4P(3个保护极, N极可开闭), 4P);

In: 0.5A, 1A, 1.6A, 2A, 3A, 4A, 6A, 8A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A;

AC133/230V: 0.5-40A: Ics=18.75kA(AC133V), 11.25kA(AC230V);

50-63A: Ics=15kA(AC133V), 7.5kA(AC230V);

0.5-63A: Icu=25kA(AC133V), 15kA(AC230V);

AC230/400/440V: 0.5-40A: Ics=18.75kA(AC230V), 11.25kA(AC400/440V);

50-63A: Ics=15kA(AC230V), 7.5kA(AC400/440V);

0.5-63A: Icu=25kA(AC230V), 15kA(AC400/440V);

使用类别: A; 过电流脱扣器类型: 热磁式;

1P, 2P(1个保护极, N极可开闭), 2P, 3P, 4P(3个保护极, N极可开闭), 4P

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 2 页

证书编号: 2014010307688142

纸号: 925732

型号的解释:

S20	1	M	-NA	K	0.5
I	II	I	III	IV	V

I: S20 / M - Basic Type 基本型号

II: Number of Pole 极数

1- 1 Pole
2- 2 Pole
3- 3 Pole
4- 4 Pole

III: blank: without N Pole 不带中性极

-NA: with N Pole could close and open 带可以开闭的中性极

IV: Setting current 电流设定

K: Setting current Ii: 12 In
Z: Setting current Ii: 2.5 In

V: Rated Current 额定电流

K and Z: 0.5A; 1A; 1.6A; 2A; 3A; 4A; 6A; 8A; 10A; 13A; 16A; 20A; 25A;
32A; 40A; 50A; 63A

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

