

RCC

(REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO

ABB SOUTH AFRICA (PTY) LTD

IN TERMS OF SANS 10142 CLAUSE 4.

ISSUED BY

National Regulator for Compulsory Specifications

PRODUCT: MINIAUTURE CIRCUIT-BREAKERS (ABB); S200M Series (Characteristic B, C, D);

$U_e = 130/230V, 230/400V, 440V AC; 50/60Hz; U_i = 440V, U_{imp} = 4kV; I_{cu} = 25, 15kA; I_{cs} = 18, 75, 15kA; 11.25, 7.5kA;$
 $I_e = 0.5, 1, 1.6, 2, 3, 4, 6, 8, 10, 13, 16, 20, 25, 32, 40, 50, 63A; 1P, 2P, 3P, 4P, 1P+N, 3P+N; IP20; Category A$

Test Laboratory:

VDE Testing and Certification Institute

Test report no: 70000-4402-0008/153700-1

RCC No: 1406098

In accordance to(Standards):

IEC 60947-2:2006 + A1:2009

Period of Validity

12/06/2014 to 12/06/2016


NRCs - Electrotechnical General Manager.

DATE

12/06/2014

