

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Leitungsschutzschalter / Circuit-breaker

Name and address of the applicant

ABB-Stotz-Kontakt GmbH  
Eppelheimer Straße 82, 69123 Heidelberg  
GERMANY

Name and address of the manufacturer

ABB-Stotz-Kontakt GmbH  
Eppelheimer Straße 82, 69123 Heidelberg  
GERMANY

Name and address of the factory

ABB-Stotz-Kontakt GmbH  
Eppelheimer Straße 82, 69123 Heidelberg  
GERMANY*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

☐ Additional Information on page 2AC 230/400 V; B/C 80 A - 100A  
Number of poles: 1, 2, 3, 4, 1 + N, 3 + N  
Instantaneous tripping current: B, C, Icn: 6 kA

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

Series S20.

Additional information (if necessary may also be reported on page 2)

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

259061-TL3-000 bis/to 014

This CB Test Certificate is issued by the National Certification Body

**VDE** Prüf- und Zertifizierungsinstitut GmbH  
**VDE** Testing and Certification Institute  
Zertifizierung Produkte / Certification Products

Date: 2019-02-27

Signature:



A. Fabian