

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit breaker

Name and address of the applicant

ABB-Stotz-Kontakt GmbH
Eppelheimer Straße 82, 69123 Heidelberg
GERMANY

Name and address of the manufacturer

ABB-Stotz-Kontakt GmbH
Eppelheimer Straße 82, 69123 Heidelberg
GERMANY

Name and address of the factory

ABB-Stotz-Kontakt GmbH
Eppelheimer Straße 82, 69123 Heidelberg
GERMANY*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

☐ Additional Information on page 2133/230 V a.c., 230/400 V a.c.; $I_n = 80\text{ A}, 100\text{ A}$;
Characteristic B, C; $I_{cu} = 6 / 20\text{ kA}$; $I_{cs} = 6 / 10\text{ kA}$

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

Series S 200

Additional information (if necessary may also
be reported on page 2)☒ Additional Information on page 2A sample of the product was tested and found
to be in conformity withIEC 60947-1:2007
IEC 60947-1:2007/AMD1:2010
IEC 60947-1:2007/AMD2:2014
IEC 60947-2:2016As shown in the Test Report Ref. No. which
forms part of this Certificate

243320-TL3-1

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH**VDE** Testing and Certification Institute

Zertifizierungsstelle und internat. Angelegenheiten

Certification Body and internat. Affairs

Date: 2019-05-09

Signature:


R. Nickel

Additional information (if necessary)

Requirements according to national standard VC 8036:2015; Government Notice 1023 of 2015 (Government Gazette No. 39324); SANS 556-1:2018 (power factor 0,5; recovery voltage 252/436 V a.c.) were tested.

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierungsstelle und internat. Angelegenheiten
Certification Body and internat. Affairs

Date: 2019-05-09

Signature:


R. Nickel