



## Certificate of Conformity

**Certificate No.:** SAA-142660-EA

**Certificate Holder:** ABB Stotz-Kontakt GmbH  
Eppelheimer Strasse 82,  
69123 Heidelberg  
Germany

**Class Description:** Miniature Overcurrent Circuit-Breaker  
**Product Description:** Miniature Overcurrent Circuit Breaker  
**Trade Name:** ABB  
**Model No.:** S 201 B 80  
**Markings:** Ue: AC240/415V (1P), 50/60Hz  
In: 80A Icn=6kA Uimp 4kV  
**Standard:** AS/NZS 60898.1:2004  
**Conditions:** Nil

**Approval Mark:** RCM and SAA-142660-EA

**Date First Registered:** 21 January 2015  
**Date of Expiry:** 21 January 2025

For and on Behalf of  
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd is accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Old Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 15-11-19 142660/1a  
Renewed, updated to RECS Scheme



# Certificate of Conformity

## \*Addendum\*

**Certificate No.:** SAA-142660-EA

**Date of Issue:** 15 November 2019

**Class Description:** Miniature Overcurrent Circuit-Breaker  
**Product Description:** Miniature Overcurrent Circuit Breaker

**General Modification:**

For model S 201 B 80:  
1 pole Type B

Models sold in New Zealand shall be marked with '230V/400V'.

Additional Models	Trade Name	Rating	Description
S 201 B 100	ABB	Ue: AC240/415V (1P), 50/60Hz In: 100A Icn=6kA Uimp 4kV	1 pole Type B
S 201 C 80	ABB	Ue: AC240/415V (1P), 50/60Hz In: 80A Icn=6kA Uimp 4kV	1 pole Type C
S 201 C 100	ABB	Ue: AC240/415V (1P), 50/60Hz In: 100A Icn=6kA Uimp 4kV	1 pole Type C
S 201 NA B 80	ABB	Ue: AC240V (1P+NA), 50/60Hz In: 80A Icn=6kA Uimp 4kV	1 pole+NA Type B
S 201 NA B 100	ABB	Ue: AC240V (1P+NA), 50/60Hz In: 100A Icn=6kA Uimp 4kV	1 pole+NA Type B
S 201 NA C 80	ABB	Ue: AC240V (1P+NA), 50/60Hz In: 80A Icn=6kA Uimp 4kV	1 pole+NA Type C
S 201 NA C 100	ABB	Ue: AC240V (1P+NA), 50/60Hz In: 100A Icn=6kA Uimp 4kV	1 pole+NA Type C
S 202 B 80	ABB	Ue: AC415V (2P), 50/60Hz In: 80A Icn=6kA Uimp 4kV	2 pole Type B
S 202 B 100	ABB	Ue: AC415V (2P), 50/60Hz In: 100A Icn=6kA Uimp 4kV	2 pole Type B

For and on Behalf of  
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd is accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Old Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 20-11-19 142660/3a  
Addition to General Modification and  
correction to Rating





# Certificate of Conformity

## \*Addendum\*

**Certificate No.:** SAA-142660-EA

**Date of Issue:** 15 November 2019

**Class Description:** Miniature Overcurrent Circuit-Breaker  
**Product Description:** Miniature Overcurrent Circuit Breaker

Additional Models	Trade Name	Rating	Description
S 202 C 80	ABB	Ue: AC415V (2P), 50/60Hz In: 80A Icn=6kA Uimp 4kV	2 pole Type C
S 202 C 100	ABB	Ue: AC415V (2P), 50/60Hz In: 100A Icn=6kA Uimp 4kV	2 pole Type C
S 203 B 80	ABB	Ue: AC415V (3P), 50/60Hz In: 80A Icn=6kA Uimp 4kV	3 pole Type B
S 203 B 100	ABB	Ue: AC415V (3P), 50/60Hz In: 100A Icn=6kA Uimp 4kV	3 pole Type B
S 203 C 80	ABB	Ue: AC415V (3P), 50/60Hz In: 80A Icn=6kA Uimp 4kV	3 pole Type C
S 203 C 100	ABB	Ue: AC415V (3P), 50/60Hz In: 100A Icn=6kA Uimp 4kV	3 pole Type C
S 203 NA B 80	ABB	Ue: AC415V (3P+NA), 50/60Hz In: 80A Icn=6kA Uimp 4kV	3 pole+NA Type B
S 203 NA B 100	ABB	Ue: AC415V (3P+NA), 50/60Hz In: 100A Icn=6kA Uimp 4kV	3 pole+NA Type B
S 203 NA C 80	ABB	Ue: AC415V (3P+NA), 50/60Hz In: 80A Icn=6kA Uimp 4kV	3 pole+NA Type C
S 203 NA C 100	ABB	Ue: AC415V (3P+NA), 50/60Hz In: 100A Icn=6kA Uimp 4kV	3 pole+NA Type C

For and on Behalf of  
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Old Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



Issued: 15-11-19 142660/4

[www.jas-anz.org/register](http://www.jas-anz.org/register)



# Certificate of Conformity

## \*Addendum\*

**Certificate No.:** SAA-142660-EA

**Date of Issue:** 15 November 2019

**Class Description:** Miniature Overcurrent Circuit-Breaker  
**Product Description:** Miniature Overcurrent Circuit Breaker

Additional Models	Trade Name	Rating	Description
S 204 B 80	ABB	Ue: AC415V (4P), 50/60Hz In: 80A Icn=6kA Uimp 4kV	4 pole Type B
S 204 B 100	ABB	Ue: AC415V (4P), 50/60Hz In: 100A Icn=6kA Uimp 4kV	4 pole Type B
S 204 C 80	ABB	Ue: AC415V (4P), 50/60Hz In: 80A Icn=6kA Uimp 4kV	4 pole Type C
S 204 C 100	ABB	Ue: AC415V (4P), 50/60Hz In: 100A Icn=6kA Uimp 4kV	4 pole Type C

For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd is accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Old Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



Issued: 15-11-19 142660/5

[www.jas-anz.org/register](http://www.jas-anz.org/register)