

Certificate of Suitability

Certificate No.: SAA142650

Certificate Holder: ABB Stotz-Kontakt GmbH

Eppelheimer Strasse 82, 69123 Heidelberg

Germany

Class Description: Non-Declared

Product Description: Miniature Overcurrent Circuit Breaker

(For Industrial Use)

Brand Name: ABB

Model No.: S20abcd Series

Markings: 80A-100A; 253/440V; 6kA;

number of poles 1, 1+N, 2, 3, 3+N, 4;

instantaneous tripping current B,C

Standard: AS/NZS 60947.2:2005

AS/NZS 60947.1:2004

Conditions: Nil

Certification Mark: SAA142650 or RCM

Date First Registered: 21 January 2015
Date of Expiry: 21 January 2020

For and on Behalf of SAA Approvals Pty Ltd

SAA Approvals Pty Ltd Electrical Product Safety Certification Scheme as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum electrical safety requirements for which the application has been made.







Issued: 21-01-15 142650/1



Certificate of Suitability

Addendum

Certificate No.: SAA142650

Date of Issue: 21 January 2015

Class Description: Non-Declared

Product Description: Miniature Overcurrent Circuit Breaker

(For Industrial Use)

General Modification:

For S20abcd Series:

'a' denotes number of poles and can be '1', '1+N', '2', '3', '3+N' or '4';


'b' denotes neutral pole and can be 'NA';

'c' denotes instantaneous tripping current characteristic and can be 'B' or 'C'; and

'd' denotes rated current and can be '80A' or '100A'.

For and on Behalf of SAA Approvals Pty Ltd

SAA Approvals Pty Ltd Electrical Product Safety Certification Scheme as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum electrical safety requirements for which the application has been made.





www.jas-anz.org/register



Issued: 21-01-15 142650/2