

WSPCert Certificate

No. BAC-0083-03

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5:2012. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed in the annex of this certificate.

The BACnet Application Specific Controller (B-ASC)

**HVAC micro drive
ACS320**

with the software version:

0526

of

ABB Oy / Drives

Hiomotie 13, 00381 Helsinki, Finland

has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 9.0 and the Certification Rules of the BACnet Interest Group Europe, see **MBS Test Report No. VG 2012_6876**.

The certificate is valid
until 2016/04/01

Date of renewal
2015/03/31



2013/03/22

Date of initial certification

A handwritten signature in black ink, likely belonging to Dipl.-Ing. G. Weinmann.

Dipl.-Ing. G. Weinmann
Head of Certification Body

Annex to Certificate No. BAC-0083-03

The certification of the BACnet Implementation

HVAC micro drive ACS320

of **ABB Oy / Drives**

refers to the BACnet Interoperability Building Blocks (BIBBs) listed below. BIBBs other than listed are not part of the certification.

BACnet Interoperability Building Blocks	
DS-RP-B	Data Sharing – Read Property – B
DS-WP-B	Data Sharing – Write Property – B
DM-DDB-B	Device Management – Dynamic Device Binding – B
DM-DOB-B	Device Management – Dynamic Object Binding – B
DM-DCC-B	Device Management – Device Communication Control – B
DM-RD-B	Device Management – Reinitialize Device – B