Intertek Intertek Intertek Intertek Intertek Intertek Intertek

EU-Type Examination Certificate





1 EU-TYPE EXAMINATION CERTIFICATE

2. Equipment or Protective System Intended for use in Potentially Explosive Atmospheres
Directive 2014/34/EU

3. EU-Type Examination Certificate Number: ITS13ATEX17809X Issue 1

4. Product: Buoyancy Level Switch, Model MS50

Manufacturer: ABB Inc

6. Address: 17100 Manchac Park Lane, (Suite B),

Baton Rouge, LA 70817; USA

- 7. This product and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.
- 8. Intertek Testing and Certification Limited, Notified Body number 0359 in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council dated 26 February 2014, certifies that the product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential Intertek Reports102612865CRT-004a and 102612865CRT-004b dated 2017-05-12.

- 9. Compliance with the Essential Health and Safety Requirements has been assured by compliance with EN 60079-0: 2012; EN 60079-1: 2007; EN 60079-31: 2009; & EN60079-26: 2007 except in respect of those requirements referred to at item 16 of the Schedule.
- 10. If the sign "X" is placed after the certificate number, it indicates that the product is subject to Specific Conditions of Safe Use specified in the Schedule to this certificate.
- 11. This EU-Type Examination Certificate relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.
- 12. The marking of the product shall include the following:



II 1/2 G Ex d IIC T6...T1 Ga/Gb

II 1 D Ex ta IIIC T80°C...T430°C Da

-40°C ≤ Tamb ≤ +70°C

Kein J. Wolf

Intertek Testing & Certification Limited
Intertek House, Cleeve Road, Leatherhead, Surrey, KT22 7SB
Tel: +44 (0)1372 370900 Fax: +44 (0)1372 370977
www.intertek.com

Kevin J. Wolf Certification Officer 28th April 2018

Registered No 3272281 Registered Office: Academy Place, 1-9 Brook Street, Brentwood, Essex, CM14 5NQ.

Page 1 of 5

This certificate may only be reproduced in its entirety and without any change, schedule included and is subject to Intertek Testing and Certification's Conditions for Granting Certification.





SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE NUMBER ITS13ATEX17809X Issue 1

13. Description of Equipment or Protective System

The buoyancy level switch, Model MS50 is an applicable switching mechanism for level sensing that uses buoyancy to detect the level or interface of liquids. The apparatus is composed of a sensor head and a probe. The probe can be between 0.2 to 6 meters long depending on the end users requirements. The sensor head is to be used with a blank cover only.

The equipment has been evaluated with types of protection 'd' and 'ta' independently. For equipment installed in atmospheres that rely on type protection 'ta', the conditions of safe use listed in section 17(a)(ii) must be met. For equipment installed in atmospheres that rely on type protection 'd', the conditions of safe use listed in section 17(a)(i) must be met.

The probe has been evaluated as being suitable for use in EPL Ga atmospheres. If the equipment is to be used in this manner, the conditions of safe use listed in section 17(a)(iii) must be met.

AMBIENT TEMPERATURE:

Ambient temperature range is -40°C to +66°C for the housing.

The probe can be placed in process temperatures between -45°C to +196°C when installed as per the manufacturers' instructions.

TEMPERATURE CODE:

The maximum temperature code (for gas) and maximum surface temperature (for dust) is directly related to the maximum process temperature the equipment is designed for. The requirements are as follows:

Maximum Process Temperature	Temperature Code	
≤76°C	T6	
≤91°C	T5	
≤126°C	T4	
≤149°C	Т3	

NOMENCLATURE:

MS50.a.b.c.d.e.f.g

Examples: MS50.A1.SS6.CE.P1.F70B.HT MS50.A1.SS6.CE.P7.F71B.HT.MF2

.a Housing

A1 Aluminium housing

.b Probe Material

SS6 Type 316L Stainless Steel

A20 Alloy 20

HSC C-276 Hastelloy

PVC, this is an outer casing that is mounted around a metal probe CPV CPVC, this is an outer casing that is mounted around a metal probe KYNAR, this is an outer casing that is mounted around a metal probe

Page 2 of 5

This Certificate is the property of Intertek Testing and Certification Ltd and is subject to Intertek Testing and Certification's Conditions for Granting Certification RFT-EU-NB-OP-23k1 June 29, 2016





SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE NUMBER ITS13ATEX17809X Issue 1

.c Approvals

E2 ATEX

.d Process Connection

P7 3/4" MNPT P1 1.0" 150# Flange SR13 1.0" MNPT SR11 1.0" 300# Flange P15 1.5" MNPT SR151 1.5" 150# Flange SR153 1.5" 300# Flange 2.0" 150# Flange SR23 2.0" 300# Flange 2.0" MNPT SR21 P2 3.0" 150# Flange SR33 3.0" 300# Flange P3 3.0" MNPT SR31 P4 4.0" MNPT SR41 4.0" 150# Flange SR43 4.0" 300# Flange P7A 3/4" MNPT with compression fitting for adjustable length "L"

.e Float

FX Float:

This option is selected from SLG-0003-1

.f Options

HT High Temperature Option:

This is required for process temperatures between +93°C and +149°C

.g Multi-Float Option

MF2 Dual-switch configuration
 MF3 Three-switches configuration
 MF4 Four- switches configuration
 MF5 Five- switches configuration
 MF6 Six- switches configuration

14. Report Number

Intertek Reports102612865CRT-004a and 102612865CRT-004b dated 2017-05-12.

15. Special Conditions of Certification

- (a). Specific Conditions of Safe Use
 - i) Installation Requirements (Ex d):

Appropriate Ex d blanking plugs, cable glands, and wiring need to be suitable for +75°C or greater.

With the use of cable or conduit entries, a certified sealing device shall be provided immediately on the entrance of the enclosure.

There may be no more than 3 switches per 0.6 m

The yield stress of all special fasteners is not less than 200 MPa (30,000 psi).

Temperature codes are based on the following table in relation to the maximum surface temperature:

Maximum Process Temperature Temperature Code

≤76°C T6 ≤91°C T5

Page 3 of 5

This Certificate is the property of Intertek Testing and Certification Ltd and is subject to Intertek Testing and Certification's Conditions for Granting Certification





SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE NUMBER ITS13ATEX17809X Issue 1

≤126°C T4 ≤149°C T3

(ii) Installation Requirements (Ex ta):

Cable entries and blanking elements must be used which maintain the ingress protection of the enclosure to at least IP6X.

Temperature codes are based on the following table in relation to the maximum surface

Maximum Process Temperature Temperature Code

≤76°C T6 ≤91°C T5

≤126°C T4

≤149°C T3

(iii) Installation Requirements (EPL Ga):

When non-metallic probe materials are used (PVC, CPVC, and PVD), there is a risk of ignition from electrostatic discharge due to the flow of non-conductive media (for example in stirring vessels or pipes). The user must decide on the suitability of the equipment for the particular application.

- (b). Conditions of Manufacture Routine Tests
 - Due to welded construction, the probe must be subject to routine testing according to clause 15.1.3.1 of EN 60079-1 to a pressure of at least 186 bar.



This Certificate is the property of Intertek Testing and Certification Ltd and is subject to Intertek Testing and Certification's Conditions for Granting Certification





SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE NUMBER ITS13ATEX17809X Issue 1

16. Essential Health and Safety Requirements (EHSRs)

The relevant Essential Health and Safety Requirements (EHSRs) have been identified and assessed in Intertek Reports102612865CRT-004a and 102612865CRT-004b dated 2017-05-12.

17. Drawings and Documents

Drawing No.:	Rev. Level:	Date:
MS50-0000-1	Α	10/23/2013
MS50-0005-1	D	05/17/2013
MS50-0005-2	D	05/17/2013
MS50-0005-3	D	05/17/2013
MS50-0005-4	D	06/25/2013
MS50-0005-5	D	06/25/2013
MS50-0005-6	В	05/17/2013
MS50-0005-8	В	05/17/2013
SLG-0003-1	E	7-2012
HSG2020	D	10/16/2013
FAB2301	NC	06/25/2013
FAB2302	NC	06/25/2013
FAB2304	NC	06/25/2013
TAG0255	A	02/22/16
	MS50-0005-1 MS50-0005-2 MS50-0005-3 MS50-0005-4 MS50-0005-5 MS50-0005-6 MS50-0005-8 SLG-0003-1 HSG2020 FAB2301 FAB2302 FAB2304	MS50-0005-1 D MS50-0005-2 D MS50-0005-3 D MS50-0005-4 D MS50-0005-5 D MS50-0005-6 B MS50-0005-8 B SLG-0003-1 E HSG2020 D FAB2301 NC FAB2302 NC FAB2304 NC

18. Details of Certificate changes Issue 1

Update manufacture and applicant address, fixed typo in description

Update the QAR for new address

Updated drawing list

Page 5 of 5

This Certificate is the property of Intertek Testing and Certification Ltd and is subject to Intertek Testing and Certification's Conditions for Granting Certification RFT-EU-NB-OP-23k1 June 29, 2016

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.