



ASSOCIAZIONE PER LA CERTIFICAZIONE  
DELLE APPARECCHIATURE ELETTRICHE

Via Tito Livio, 5 - 24123 - BERGAMO (Italy)

Tel. +390354175244 fax. +390354534662 e-mail: acae@acaecert.it



# Certificate of Conformity

LOVAG-Certificate No. IT 14.087

This certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designation with that tested rests with the manufacturer or responsible vendor.

This certificate has been prepared according to LOVAG (Low Voltage Agreement Group) Objectives and Operating Principles of mutual recognition. The responsible certification body as member of LOVAG issues a Certificate of Conformity with the above mentioned Standard(s) following the exclusive use of LOVAG Test Instructions wherever applicable.

Only integral reproduction of this Certificate or reproductions of this page accompanied by any page(s) on which are stated the tests performed and the assigned rated characteristics of the apparatus Tested, are permitted without written permission from the LOVAG Signatory responsible for this Certificate.

## Apparatus

Low voltage cubicle with busbars -  
415V ( $U_e$ ) - 1000A ( $I_{na}$ ) - 50kA ( $I_{cw}$ ) - 8kV ( $U_{imp}$ ) - 50Hz(f) - IP65

## Designation

**System Pro E Power 1000A**

## Manufacturer or responsible vendor

**ABB S.p.A. - ABB SACE Division**

Via Italia, 58 - 23846 Garbagnate Monastero (LC) Italy

**Tested for: ABB S.p.A. - ABB SACE Division**

Via Italia, 58 - 23846 Garbagnate Monastero (LC) Italy

**Tested by: ACAE Laboratory IV 01**

The apparatus, constructed in accordance with the description mentioned in the Test Report listed on this Certificate has been subjected to the series of proving tests in accordance with IEC 61439-2 Ed.2.0 (2011-08) and EN 61439-2(2011) .

( This standard complies also with the requirements of the previous standard IEC 60439 )

- Verification of temperature rise-limits (10.10)
- Dielectric properties (10.09)
- Short-circuit withstand strength (10.11)

The results are shown in the Test Report in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristics assigned by the manufacturer as stated below:

-Verification of temperature rise-limits :

Circuit	A (I0)	B
Test current ( $I_{nc}$ ) A	1000	1000

- Dielectric properties: 1000V - 50Hz - 8kV 1.2/50 $\mu$ s

- Short-circuit withstand strength : circuit A (I0) - B 50kA for 1s / 30kA for 1s on protective circuit

This document includes Test report No. : 8018/VNL  
Issue date : 2014.07.21

Responsible Certification Body : ACAE  
Virginia Scarioni



PRD N°0708  
Signatory of EA, IAF and ILAC  
Mutual Recognition Agreements

Authorized signature

Date: 2014.09.30