



CERTIFICATE FI 30590

Our Ref. 294466

Product Residual current operated circuit-breaker

Type Series F200

Trade mark ABB

Certificate Holder ABB S.p.A
Via Vittor Pisani, 16, 20124 MILANO, ITALY

Manufacturer ABB S.p.A
ABB SACE Division
Viale dell'Industria, 18, 20010 VITTUONE (MI), ITALY

Technical information 2P (Un = 230 V) and 3P+N (Un = 400 V); type A, AC, AS and ACS;
In = 16, 25, 32, 40, 63 A; IΔn = 10, 30, 100, 300, 500 and 1000 mA
Im = 1000 A; IΔm = 1000 A; Inc = 10000 A; IΔc = 10000 A

Other information Version 2
Type AC is not applicable in Finland

The product is certified according to the following standard(s) EN 61008-1:2012 + A1:2014 + A2:2014 + A11:2015
EN 61008-2-1:1994 + A11:1998

Validity This certificate is valid until 02 October 2023 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that product changes (if any) will be approved at SGS Fimko before the product is brought onto market.

Directive information The certified product(s) fulfils requirements of above mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) at the date of issue of the certificate.

Date of issue 02 October 2018

SGS Fimko Ltd

Signature


Seppo Lautamies
Project Manager

This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Fimko Ltd

Särkiniementie 3 P.O Box 30 FI-00211 Helsinki, Finland
t. +358 9 696 361 f. +358 9 692 5474 www.sgs.fi

Business ID 0978538-5

Member of the SGS Group (SGS SA)

Manufacturing site

ABB S.p.A.
ABB SACE Division
Via Ardeatina, 2491
00040 SANTA PALOMBA (RM), ITALY


Additional information

The product has certificate NTR/30987 issued by IMQ S.p.A Italy in accordance with CENELEC Certification Agreement system.



This certificate replaces previous FI Certificate no. 28411 dated 23 January 2014 certificate date has been extended.

2 - Description of the code of RCCBs F200 series



⁽¹⁾ - Neutral pole may be on the left or on the right

Our ref:

294466-2