中国国家强制性产品认证证书

证书编号：2007010307235399

委托人名称、地址

ABB S.p.A.

Via Vittor Pisani 16-20124 Milano (MI)-Italy

生产者（制造商）名称、地址

ABB S.p.A.

Viale dell'Industria 18-20010 Vittuone (MI)-Italy

生产企业名称、地址

ABB S.p.A.

Via Ardeatina 2491-00040 Santa Palomba (RM)-意大利

产品名称和系列、规格、型号

剩余电流动作断路器

F202，F204:Uimp：4kV；Ui：500V;Ue:AC230V/400V;In 和 I△n 见附表;剩余电流动作类型：电磁式;A/AC 型;I△m:1000A;适用频率：50Hz;Im=1kA;2P,3P+N（N 极可开闭，适用于隔离）（具体规格详见附件）

产品标准和技术要求

GB/T16916.1-2014;GB/T16916.21-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，特发此证。

发证日期：2018 年 05 月 09 日　　有效期至：2023 年 05 月 09 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2007 年 06 月 05 日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询

主　任：

中国质量认证中心

http://www.cqc.com.cn　　中国・北京・南四环西路188号9区 100070　　电话：+86 10 83886666

Q 1950437

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2007010307235399

NAME AND ADDRESS OF THE APPLICANT

ABB S.p.A.

Via Vittor Pisani 16-20124 Milano (MI)-Italy

NAME AND ADDRESS OF THE MANUFACTURER

ABB S.p.A.

Viale dell'Industria 18-20010 Vittuone (MI)-Italy

NAME AND ADDRESS OF THE FACTORY

ABB S.p.A.

Via Ardeatina 2491-00040 Santa Palomba (RM) - Italy

PRODUCT NAME, MODEL AND SPECIFICATION

Residual Current Operated Circuit-breaker Without Integral Overcurrent Protection

F202，F204:Uimp：4kV ；Ui：500V;Ue:AC230V/400V;In 和 I△ n;Thermal-magnetic Over-current Trip Unit; A/AC Type;I△ m: 1000A;Applicable frequency：50Hz; Im=1kA;2P,3P+N（with a switched neutral pole，Suitable for isolation）

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T16916.1-2014;GB/T16916.21-2008

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: May.09,2018 **Valid until:** May.09,2023

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Jun.05,2007

The certificate information is available through CNCA's website: www.cnca.gov.cn

President: Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE 中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

http://www.cqc.com.cn Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P. R. China Tel: +86 10 83886666

Q 1950437

中国国家强制性产品认证证书

附　　录　　第 1 页 共 2 页

证书编号：2007010307235399　　纸　号：1950437

极数	动作特性	额定电流	额定剩余动作电流
2 P	type AC	25A,40 A,63 A,80A, 100A	30,100,300,500mA
	type A	25A,40 A,63 A,80A, 100A	30,100,300,500mA
	type AC AP-R	25A,40 A,63 A	30mA
	type A AP-R	25A,40 A,63 A,80A, 100A	30mA
	type A G	40 A,63 A	30,100mA
	type AC G	40 A,63 A	30,100mA
	typeA　S	40 A,63 A,80A, 100A	100,300,500,1000mA
	type AC S	40 A,63 A	100,300,500,1000mA
3P+N	type AC	25A,40 A,63 A,80A, 100A	30,100,300,500mA
	type A	25A,40 A,63 A,80A, 100A	30,100,300,500mA
	type AC AP-R	25A,40 A,63 A	30mA
	type A AP-R	25A,40 A,63 A,80A, 100A	30mA
	type A G	40 A,63 A	30,100mA
	type AC G	40 A,63 A	30,100mA
	typeA　S	40 A,63 A,100A	100,300,500,1000mA
	type AC S	40 A,63 A	100,300,500,1000mA
	type AC T	25A	30mA
	type A T	25A	30mA
	type AC T	40 A,63 A	30,100mA

注：此附录与证书同时使用时有效。

主　任：


中国质量认证中心

中国国家强制性产品认证证书

附　　录　　第 2 页 共 2 页

证书编号：2007010307235399　　纸　号：1950437

型号解释：



注：此附录与证书同时使用时有效。

主　任：

中国质量认证中心