



CONFIRMATION
2CDN070019P1004

ABB STOTZ-KONTAKT GmbH
D-69123 Heidelberg / GERMANY

We hereby confirm, that ABB's Miniature Circuit Breakers of the series

S200MT, S200P, S280UC
all characteristics and ratings

comply with the requirements regarding

Fire exposure
acc. to NF F16-101/-102, prEN 45545-1/-2, hazard level HL3

Vibration and shock resistance
acc. to DIN EN 60068, DIN EN 50155, EN 61373

This confirmation is valid for the present design of the products.

Heidelberg, 2013-05-15

ABB STOTZ-KONTAKT GmbH
Quality Management

i. A. Walter Kahl

ABB STOTZ-KONTAKT GmbH



Postal address:
Postfach 10 16 80
69006 Heidelberg

Visiting address:
Eppelheimer Straße 82
69123 Heidelberg
Phone: +49 6221 701 0
Telefax: +49 6221 701 693
Internet: www.abb.de/stotz-kontakt

Head Office:
Heidelberg
Registry Court:
Mannheim
Commercial Register:
HRB 336474

Chairman of the Supervisory Board:
Hans-Georg Krabbe
Managing Board:
Uwe Laudenklos (Chairman)
Robert Doran

Bankers:
Bayerische Hypo- und Vereinsbank AG
München
Account: 667 930 375
Sorting Code: 700 202 70
IBAN: DE07700202700667930375
BIC: HYVEDEMMXXX
USt-IdNr: DE811176562