中国国家强制性产品认证证书

证书编号：2010010302445951

委托人名称、地址

ABB Oy, Breakers and Switches
Muottitie 2A, FI-65320 VAASA, Finland

生产者(制造商)名称、地址

ABB Oy, Breakers and Switches
Muottitie 2A, FI-65320 VAASA, Finland

生产企业名称、地址

ABB Oy, Breakers and Switches
Muottitie 2A, FI-65320 VAASA, Finland

产品名称和系列、规格、型号

隔离开关熔断器组

OS1200L_, OS1250D_, OS1250B_, OS1250DA_; 型号规格见附件

产品标准和技术要求

GB 14048.3-2008

上述产品符合强制性产品认证实施规则
CNCA-01C-011:2007的要求，特发此证。

发证日期：2014年09月25日　　有效期至：2015年11月30日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2010年11月30日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询

主　任：

中国质量认证中心

中国 · 北京 · 南四环西路188号9区 100070

http://www.cqc.com.cn

Q 0991574

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2010010302445951

NAME AND ADDRESS OF THE APPLICANT

ABB Oy, Breakers and Switches
Muottitie 2A, FI-65320 VAASA, Finland

NAME AND ADDRESS OF THE MANUFACTURER

ABB Oy, Breakers and Switches
Muottitie 2A, FI-65320 VAASA, Finland

NAME AND ADDRESS OF THE FACTORY

ABB Oy, Breakers and Switches
Muottitie 2A, FI-65320 VAASA, Finland

NAME, MODEL AND SPECIFICATION

Switch-Disconnector-fuse

OS1200L_, OS1250D_, OS1250B_, OS1250DA_; Model and specification see the appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.3-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-011:2007).

Date of issue: Sep.25, 2014 Date of expiry: Nov.30, 2015

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Nov.30, 2010

This certificate can be verified through CNCA's website: www.cnca.gov.cn

President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9,No.188,Nansihuan Xilu, Beijing 100070 P.R.China

http://www.cqc.com.cn

Q 0991574

中国国家强制性产品认证证书

附录：　　第 1 页 共 1 页

证书编号：2010010302445951　　纸号：991574

型号：OS1200L,OS1250D,OS1250B,OS1250DA；
额定绝缘电压(Ui)：AC1000V;
约定发热电流(Ith)：1200A(OS1200L),1250A(OS1250D, OS1250B, OS1250DA);
Ue/Ie：
AC-21A：415V/1250A(OS1250D, OS1250B, OS1250DA)
AC-22A：415V/1250A(OS1250D, OS1250B, OS1250DA)
AC-23A：415V/1000A(OS1250D, OS1250B, OS1250DA)
AC-21B：690V/1250A(OS1250D, OS1250B, OS1250DA),600V/1200A(OS1200L)
AC-22B：690V/1250A(OS1250D, OS1250B, OS1250DA),600V/1200A(OS1200L)
AC-23B：690V/1000A(OS1250D, OS1250B, OS1250DA),600V/1000A(OS1200L)
额定限制短路电流：
2P：500V/100kA, 690V/80kA(OS1250D, OS1250B, OS1250DA)
600V/100kA(OS1200L)；
3P：500V/80kA, 690V/80kA(OS1250D, OS1250B, OS1250DA)
600V/ 100kA(OS1200L)；
4P：500V/100kA , 690V/80kA(OS1250D, OS1250B, OS1250DA)
600V/ 100kA(OS1200L);
使用类别：AC-21A, AC-22A, AC-23A , AC-21B, AC-22B, AC-23B;
极数：2P,3P,4P

注：此附录与证书同时使用时有效。

主　任：

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

http://www.cqc.com.cn