

# WSPCert Certificate

**No. BAC-0082-04**

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5:2012. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed in the annex of this certificate.

The BACnet Application Specific Controller (B-ASC)

**Drive for HVAC  
ACH550**

with the software version:

**0511**

of

**ABB Oy / Drives**

Hiomotie 13, 00381 Helsinki, Finland

has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 9.0 and the Certification Rules of the BACnet Interest Group Europe, see **MBS Test Report No. VG 2013\_7835**.

The certificate is valid  
until 2017/04/01

Date of renewal  
2016/04/11



2013/03/22

Date of initial certification

Dipl.-Ing. G. Weinmann  
Head of Certification Body

## Annex to Certificate No. BAC-0082-04

The certification of the BACnet Implementation

### **Drive for HVAC ACH550**

of **ABB Oy / Drives**

refers to the BACnet Interoperability Building Blocks (BIBBs) listed below. BIBBs other than listed are not part of the certification.

| BACnet Interoperability Building Blocks |  |
|---|--|
| DS-RP-B                                 | Data Sharing – Read Property – B                     |
| DS-WP-B                                 | Data Sharing – Write Property – B                    |
| DM-DDB-B                                | Device Management – Dynamic Device Binding – B       |
| DM-DOB-B                                | Device Management – Dynamic Object Binding – B       |
| DM-DCC-B                                | Device Management – Device Communication Control – B |
| DM-RD-B                                 | Device Management – Reinitialize Device – B          |