

ASSOCIAZIONE PER LA CERTIFICAZIONE DELLE APPARECCHIATURE ELETTRICHE

DELLE APPARECCHIATURE ELETTRICHE

V.le delle Brigate Partigiane 6/21 - 16129 - GENOVA (Italy) tel. +10/565197 fax. +10/5848607 e-mail: acaecert@tin.it



Certificate of Conformity

LOVAG-Certificate No. IT 99.025 page 1 of 2

Apparatus

Low voltage swithchgear and controlgear assembly - 3 phases + neutral - 400 V (U_c) - 690 V (U,) - frequency 50 Hz

This Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designation with that tested rests with the manufacturer or responsible vendor.

This certificate has been prepared according to LOVAG (Low Voltage Agreement Group) Objectives and Operating Principles of mutual recognition. The responsible certification body as member of LOVAG issues a Certificate of Conformity with the above mentioned Standard(s) following the exclusive use of LOVAG Test Instructions wherever applicable.

Only integral reproduction of this Certificate or reproductions of this page accompanied by any page(s) on which are stated the tests performed and the assigned rated characteristics of the apparatus tested, are permitted without written permission from the LOVAG Signatory responsible for this Certificate.

Designation

ARTU K

Manufacturer or responsible vendor

ABB TURATI SpA - Via Italia 38/42 - 23846 Garbagnate Monastero (LC)

Tested for: ABB TURATI SpA - Via Italia 38/42 - 23846 Garbagnate Monastero (LC) (Italy)

Tested by: ACAE Laboratory IA.01

The apparatus, constructed in accordance with the description mentioned in the Test Report listed on this Certificate has been subjected to the series of proving tests in accordance with

IEC 439-1 (1992-11) ed. 3; EN 60439-1 (1994-01)

The results are shown in the Test Report in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristic assigned by the manufacturer as stated below.

- Verification of temperature rise-limits :
 Rated currents see page 2 of 2 Outgoing circuits diversity factor = 0,83
- Verification of short-circuit withstand strength
- Verification of the effectiveness of the protective circuit
- Verification of the dielectric properties (declared U = 6 kV)

See following page 2 of 2

This document includes Report No.: 98.193/T01 Issue Date: 1999.02.19

Responsible Certification Body

Authorized Signature

Date: 1999.04.01



ASSOCIAZIONE PER LA CERTIFICAZIONE DELLE APPARECCHIATURE ELETTRICHE

40 p. Borgo Pila - 16129 - GENOVA (Italy)

tel. +10/565197 fax. +10/582395

Certificate of Conformity

LOVAG-Certificate No. IT 99.025 Page 2 of 2

This Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designation with that tested rests with the manufacturer or responsible vendor.

This certificate has been prepared according to LOVAG (Low Voltage Agreement Group) Objectives and Operating Principles of mutual recognition. The responsible certification body as member of LOVAG issues a Certificate of Conformity with the above mentioned Standard(s) following the exclusive use of LOVAG Test Instructions wherever applicable.

Only integral reproduction of this Certificate or reproductions of this page accompanied by any page(s) on which are stated the tests performed and the assigned rated characteristics of the apparatus tested, are permitted without written permission from the LOVAG Signatory responsible for this Certificate.

Circuit	Rated current A	Rated conditional short-circuit current
IG	1200	50 (N = 30)
11	320	50 (N = 30)
12	300	50 (N = 30)
13	300	50 (N = 30)
14	220	50 (N = 30)
15	100	50 (N = 30)
16	100	50 (N = 30)
17	100	50 (N = 30)

For distribution bars:

- Rated short-time withstand current I w/kA 50 (N = 30)

- Rated peak withstand current I NA : 105 (N = 63)

Responsible Certification Body

Authorized Signature

Date:1999.04.01