

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20190606- E332693  
**Report Reference** E332693-20110310  
**Issue Date** 2019-JUNE-06

**Issued to:** ABB Automation Products GmbH  
Eppelheimer Str. 82  
69123 Heidelberg GERMANY

**This certificate confirms that  
representative samples of**

PROGRAMMABLE CONTROLLERS FOR USE IN  
HAZARDOUS LOCATIONS  
See Addendum Page

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

Standard No. ANSI/ISA-12.12.01, Nonincendive Electrical  
Equipment for Use in Class I and II, Division 2 and Class III,  
Divisions 1 and 2 Hazardous (Classified) Locations  
Standard No. CAN/CSA C22.2 No. 213-16, Nonincendive  
Electrical Equipment for Use in Class I and II, Division 2  
and Class III, Divisions 1 and 2 Hazardous (Classified)  
Locations


**Additional Information:**

See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20190606- E332693  
**Report Reference** E332693-20110310  
**Issue Date** 2019-JUNE-06

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## Models:

USL, CNL – Programmable Controllers and modules, Open Type, for use in Class I, Division 2, Groups A, B, C and D Hazardous Locations.

## Programmable Controllers:

AC500-eCo Series, Models PM554-T, PM554-T-ETH, PM564-T, PM564-T-ETH, PM554-R, PM564-R, PM564-R-ETH, PM554-R-AC, PM564-R-AC, PM564-R-ETH-AC, , PM554-TP, PM554-TP-ETH, PM564-TP, PM564-TP-ETH, PM566-TP-ETH . PM554-RP, PM564-RP, PM564-RP-ETH, PM554-RP-AC, PM564-RP-AC, PM564-RP-ETH-AC, PM556-TP-ETH, AX561, AI561, AO561, AI562, AI563, DX561, DO561, DO562, DI561, DI562, DC561, DC562, DX571, DO571, DI571, DI572, DO572, DO573 and FM562.

## ACCESSORIES:


The following accessories intended to be used with Listed devices under “PRODUCT COVERED” may be shipped with the Listed product.

### Accessories for use with AC500-eCo series:

Models TA562-RS-RTC - Combined Real Time Clock option with RS485 serial adapter COM2 for CPU's PM554 and PM564; TA562-RTC - Real Time Clock option for CPU's PM554 and PM564; TA562-RS - RS485 serial adapter; TK503, TK504, TK506 - Programming cable; TA566 - Wall mounting accessory; TA560 – For use with TA562-RS-RTC and TA562-RS. TA570; MC503 - SD-Card adapter, TA569-RS-ISO – RS485 serial adapter with galvanic isolation.

### Accessories

TA562-RS-RTC - Combined Real Time Clock option with RS485 serial adapter COM2 for CPU's PM554 and PM564; TA562-RTC - Real Time Clock option for CPU's PM554 and PM564; TA562-RS - RS485 serial adapter; TK503, TK504 - Programming cable; TA566 - Wall mounting accessory; TA560 – For use with TA562-RS-RTC and TA562-RS. TA570; MC503 - SD-Card adapter.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

