



Certificate of Compliance

Certificate: 80011766

Master Contract: 155295

Project: 80011766

Date Issued: 2019-11-25

Issued to: ABB Inc.
3400 Rue Pierre-Ardouin
Quebec, Quebec G1P 0B2
CANADA

Attention: Jean-Francois Ferland

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only



Issued by: A Traverse
A Traverse

PRODUCTS

CLASS 2258 03 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe and Non - Incendive Systems - For Hazardous Locations

CLASS 2258 83 - PROCESS CONTROL EQUIPMENT-Intrinsically Safe and Non-Incendive - Systems-For Hazardous Locations-Certified to U.S. Standards

Class I, Division 1, Groups C and D T6...T1 (Provides I.S. output to Sensor)

Class II, Division 1, Groups E, F and G T6...T1

Class I, Zone 0/1 AEx ia/db IIB T6...T1 Ga/Gb

Zone 20/21 AEx ia/tb IIIC T77°C...T358°C Da/Db

Ex ia/db IIB T6...T1 Ga/Gb


Ex ia/tb IIIC T77°C...T358°C Da/Db

-50°C < T_{amb} < 70°C

-50°C < T_{amb} < 75°C

-50°C < T_{amb} < 85°C

***See conditions of acceptability for Temperature Class Assignment**





Certificate: 80011766
Project: 80011766

Master Contract: 155295
Date Issued: 2019-11-25

Conditions of Acceptability:

1. Installation in USA shall be in accordance with the manufacturer's instructions and the National Electrical Code®, ANSI/NFPA 70. Installations in Canada shall comply with the relevant requirements of the Canadian Electrical Code (CSA C22.1).
2. For installation in US, Seal all conduits within 18 inches.
3. For installation in Canada, Seal all conduits within 50mm.
4. Flameproof joint repair must not be conducted by the end user.
5. The equipment presents a potential risk of electrostatic sparking. Clean only with a damp cloth.
6. The following temperature matrix applies to the transmitter electronics and housing. Probes are simple apparatus, not subject to electrical-self heating under normal or fault conditions. Probe temperature in service will be a function of the ambient and process temperatures:

Coupler Type	Max T _{process} °C	Max T _{ambient} °C	Transmitter Temperature Class			
			Ex db	XP Cl I Div 1	Dust Cl II Div 1	Ex tb (T _{__} °C)
Local Probe Configuration						
S, H1	80	75	T6		77	
S, H1	95	85	T5		89	
S, H1	130	85	T4		105	
S, H1	204	85	T3		138	
H2	80	75	T6		79	
H2	95	85	T5		92	
H2	130	85	T4		118	
H2	230	85	T3		192	
H2	343	75	T2		272	
H3	80	75	T6		79	
H3	95	85	T5		93	
H3	130	85	T4		119	
H3	230	85	T3		195	
H3	340	75	T2		276	
H3	450	70	T1		358	
C1	80	75	T6		77	
C1	95	85	T5		89	
C1	100	85	T4		92	
Remote Probe Configuration						
All Versions	-	75	T6		77	
All Versions	-	85	T5		87	

7. Cable glands and blanking elements (when used to blank unused entries) must be suitably certified for the protection type selected for equipment installation.
8. Cable glands for Zone 21 US applications must comply with UL 2225.
9. Light metals can generate ignition-capable sparks when subjected to impact or friction.
 - a. Transmitter enclosure: When installed in Zone 0, 1, 20, 21 (EPL Ga, Gb, Da, Db required), transmitter enclosures which are constructed of aluminum alloy shall be protected such that sparks resulting from impact or friction cannot occur, taking into account rare malfunctions. Where special housing type is present, it is the responsibility of the installer to determine if the transmitter housing is constructed of aluminum alloy.
 - b. Probe: When installed in Zone 0, 1, 20, 21 (EPL Ga, Gb, Da, Db required), probes which are constructed of light metals, including aluminum, magnesium, titanium or zirconium shall be protected such that sparks resulting from impact or friction cannot occur, taking into account rare malfunctions. Where special probe type is present, it is the responsibility of the installer to determine if the probe incorporates light metals.
10. The transmitter does not provide isolation from earth. When installed as Ex ia, the associated apparatus used to limit energy to the transmitter shall provide isolation from earth at not less than 500 Vrms.



Certificate: 80011766

Project: 80011766

Master Contract: 155295

Date Issued: 2019-11-25

APPLICABLE REQUIREMENTS

CSA 22.2 No.30 M1986 (R2007)	- Explosion-proof enclosures for use in class I hazardous locations
CSA 22.2 No.25 – 17	- Enclosures for use in Class II, Division 1, Groups E, F, and G hazardous locations
FM 3600:2018	- Electrical Equipment for Use in Hazardous (Classified) Locations – General Requirements
FM 3615:2018	- Approval Standard for Explosion proof Electrical Equipment, General Requirements
FM 3616:2011	- Approval Standard for Dust-Ignition proof Electrical Equipment General Requirements
CSA C22.2 No.60079-0:2019	- Explosive atmospheres. Equipment general requirements
CSA C22.2 No.60079-1:2016	- Explosive atmospheres. Equipment protection by flameproof enclosures "d"
CSA C22.2 No.60079-11:2014	- Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
CSA C22.2 No.60079-26:2016	- Explosive atmospheres. Equipment with Equipment Protection Level (EPL) Ga
CSA C22.2 No.60079-31:2015	- Explosive atmospheres. Equipment dust ignition protection by enclosure "t"
ANSI/UL 60079-0:2019	- Explosive atmospheres. Equipment general requirements
ANSI/UL 60079-1:2015	- Explosive atmospheres. Equipment protection by flameproof enclosures "d"
ANSI/ISA 60079-11:2014	- Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
ANSI/UL 60079-26:2017	- Explosive atmospheres. Equipment with Equipment Protection Level (EPL) Ga
ANSI/UL 60079-31:2015	- Explosive atmospheres. Equipment dust ignition protection by enclosure "t"
CSA 22.2 No.61010-1:2012	- Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 1: General requirements
ANSI/ISA 61010-1:2012	- Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use – Part 1: General requirements
ANSI/ISA 12.27.01:2011	- Requirements for Process Sealing Between Electrical Systems and Flammable or Combustible Process Fluids
ANSI/IEC 60529:2004	- Degrees of Protection Provided by Enclosures (IP Code)
CSA C22.2 No. 60529:2005 (R2015)	- Degrees of Protection Provided by Enclosures (IP Code)
UL 50E:2015	- Enclosures for electrical equipment, environmental considerations
CSA C22.2 No. 94.2:2015	- Enclosures for electrical equipment, environmental considerations



Certificate: 80011766

Project: 80011766

Master Contract: 155295

Date Issued: 2019-11-25

MARKINGS

The manufacturer is required to apply the following markings:

- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.

Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.

The products listed are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US (indicating that products have been manufactured to the requirements of both Canadian and U.S. Standards) or with adjacent indicator 'US' for US only or without either indicator for Canada only.

Equipment is marked with the following:

- Company Name
- Model number
- Serial number
- Date code
- Electrical rating
- Ambient Temperature Range
- Hazardous locations designation
- A reference to installation instructions
- CSA19CA80011766
- The following statement, or its equivalent: For USA: “SEAL ALL CONDUITS WITHIN 18 INCHES”, or For Canada: “SEAL ALL CONDUITS WITHIN 50mm” and ‘UN SCELLEMENT DOIT ENTRE INSTALLEA MOINS DE 50mm DU BOITIER’.
- Single Seal/Dual Seal
- IP 66/68
- Type 4X, 6P



Supplement to Certificate of Compliance

Certificate: 80011766

Master Contract: 155295

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80011766	2019-11-25	Prime model certification of LWT300/400 MODBUS communication protocol.